

GENERATOR INTERCONNECTION APPLICATION

Category 3

For All Projects with Aggregate Generator Output of More Than 150 kW but Less Than or Equal to 550 kW

ELECTRIC UTILITY CONTACT INFORMATION		FOR OFFICE USE ONLY			
			Applicatio	on Number	
Consumers E	nergy				
Interconnection C	oordinator		Date and	Time Application Received	d
1945 West Parnall Road	(Room P14-205)				
Jackson, MI 4	19201				
(517)788-1	432				
Net Metering E-mail: net_metering@cmsenergy.com		m			
Flectri	CUSTOMER / ACCC	UNT INFOR		N lity bill)	
Customer Name (Last First Middle)		Customer Mail	ing Addres	ss	
			ing / touree	55	
Customer Phone Number		Customer E-m	ail Addres	s (Ontional)	
() Electric Service Account #		Electric Service	Electric Service Motor Number		
Are you interested in selling Renewable Energy	Credits (REC's)?				
Yes No					
GE	NERATION SYSTEM	M SITE INFO	RMATIC	ON	
Physical Site Service Address (If Not Billing Addres	SS)				
Annual Site Requirements Without Generation in k	Wh Peak Annual Site D	Demand in kW (o	nly for custo	mers billed on Demand Rates)	Attached Site Plan
kWh/year	kW				Page #
Attached Electrical One-Line Drawing					<u> </u>
Page #					
(Der MDSC Order in Case No. 11 15797 The One	Line Drowing must be sid	and and appled	l hy a liaar	and profossional anginas	· licensed in the State of
Michigan or by an electrical contractor licensed by	the State of Michigan with	the electrical co	ntractor's	license number noted on the	he diagram.)
See Page 5 for sample Site Plan	Ū				o ,
See Page 6 for sample of Inverter Gen	erator Electrical One-Lin	e Drawing			
See Page 7 for sample of Synchronou	s Generator Electrical O	ne-Line Drawin	g		
See Page 8 for sample of Induction Ge	enerator Electrical One-L	ine Drawing	-		
GENERA	TION SYSTEM MAN	UFACTURE	R INFOR	RMATION	
System Type (Solar, Wind, Biomass Methane Digester, etc)		Generator Type (Inverter, Induction, Synchronous)			
Generator Nameplate Rating		Expected Annual Output in Kilowatt Hours			
kW		kWh/year			
A.C. Operating Voltage		Wiring Configuration (Single Phase, Three Phase)			
Certified Test Record No. (Testing to Standard UI	1741 scope 1.1a)				
INVERTER GENERATOR - BASED SYSTEMS					
Manufacturer	Model (Name/Number)			Inverter Power Rating (kv	V)

SYNCHRONOUS AND INDUCTION GENERATOR - BASED SYSTEMS (Must complete either Page 3 or Page 4 and attach Electrical One-Line Drawing

The following information on these system components shall appear on the Electrical One-Line Drawing:

- Breakers Rating, location and normal operating status (open or closed)
- Buses Operating voltage
- Capacitors Size of bank in Kvar
- Circuit Switchers Rating, location and normal operating status (open or closed)
- Current Transformers Overall ratio, connected ratio
- Fuses Normal operating status, rating (Amps), type
- Generators Capacity rating (kVA), location, type, method of grounding
- Grounding Resistors Size (ohms), current (Amps)
- Isolating Transformers Capacity rating (kVA), location, impedance, voltage ratings, primary and secondary connections and method of grounding
- Potential Transformers Ratio, connection
- Reactors Ohms/phase
- Relays Types, quantity, IEEE device number, operator lines indicating the device initiated by the relays
- Switches Location and normal operating status (open or closed), type, rating
- Tagging Point Location, identification

Manufacturer	Model Name	Model Number	
	INSTALLATION INFORM	ATION	
Project Single Po	int of Contact: (Electric Utility C	ustomer, Developer or Other)	
Name	Company (If Applicable)	Phone Number	
		()	
E-Mail Address		Requested In Service Date	
Licensed Contractor(Name of Firm or Self)			
Contractor's Name (Last, First, MI)	Contractor's Phone #	Contractor's E-mail	
CUSTOMER AND P	ROJECT DEVELOPER/CONTRA	CTOR SIGNATURES AND FEES	
Attached \$150 Interconnection	Application Eco		
	Application ree		
Check # Money	v Order #		
Sign and Return Completed Applic	ation with Application Fee to Ele	ectric Utility Contact	
To the best of my knowledge, all the information provided in this application form is complete and correct.			
Customer Signature:		Date	
Project Developer/Contractor Signature (if appl	icable):	Date	
Note: Refer to the applicable "Michigan Electric Utility Generator Interconnection Requirements" for a detailed explanation of the			

SYNCHRONOUS GENERATORS					
GENERATOR INFORMATION					
Generator Nameplate Voltage	Generator Nameplate Watts or Volt-Amperes				
Generator Nameplate Power Factor (pf)	RPM				
TECHNICAL INFORMATION					
Minimum and Maximum Acceptable Terminal Voltage	Direct Axis Reactance (saturated)				
Direct Axis Reactance (unsaturated)	Quadrature Axis Reactance (unsaturated)				
Direct Axis Transient Reactance (saturated)	Direct Axis Transient Reactance (unsaturated)				
Quadrature Axis Transient Reactance (unsaturated)	Direct Axis Sub-Transient Reactance (saturated)				
Direct Axis Sub-Transient Reactance (unsaturated)	Leakage Reactance				
Direct Axis Transient Open Circuit Time Constant	Quadrature Axis Transient Open Circuit Time Constant				
Direct Axis Sub-Transient Open Circuit Time Constant	Quadrature Axis Sub-Transient Open Circuit Time Constant				
Open Circuit Saturation Curve					
Reactive Capability Curve Showing Overexcited and Underexcited Limits (R	eactive Information if Non-Synchronous)				
Excitation System Block Diagram with Values for Gains and Time Constants	(Laplace Transforms)				
Short Circuit Current Contribution From Generator at the Point of Common C	Coupling				
Rotating Inertia of Overall Combination Generator, Prime Mover, Couplers a	nd Gear Drives				
Station Power Load When Generator is Off-Line, Watts, pf	Station Power Load During Start-Up, Watts, pf				
Station Power Load During Operation, Watts, pf					

INDUCTION GENERATORS						
GENERATOR INFORMATION						
Generator Nameplate Voltage	Generator Nameplate Watts or Volt-Amperes					
Generator Nameplate Power Factor (pf)	RPM					
TECHNICAL INFORMATION						
Synchronous Rotational Speed	Rotation Speed at Rated Power					
Slip at Rated Power	Minimum and Maximum Acceptable Terminal Voltage					
Motoring Power (kW)	Neutral Grounding Resistor (If Applicable)					
I2 2t or K (Heating Time Constant)	Rotor Resistance					
Stator Resistance	Stator Reactance					
Rotor Reactance	Magnetizing Reactance					
Short Circuit Reactance	Exciting Current					
Temperature Rise	Frame Size					
Design Letter	Reactive Power Required in Vars (No Load)					
Reactive Power Required in Vars (Full Load)						
Short Circuit Current Contribution from Generator at the Point of Common C	oupling					
Rotating Inertia, H in Per Unit on kVA Base, of Overall Combination General	or, Prime Mover, Couplers and Gear Drives					
Station Power Load When Generator is Off-Line, Watts, pf	Station Power Load During Start-Up, Watts, pf					
Station Power Load During Operation, Watts, pf						

SAMPLE SITE PLAN – PROVIDED FOR REFERENCE ONLY





STREET

Weblink to State of Michigan / Plats:

http://www.cis.state.mi.us/platmaps/sr_subs.asp

Note: Legible hand drawn site plans are acceptable

SAMPLE ONE-LINE DRAWING – PROVIDED FOR REFERENCE ONLY

INVERTER GENERATOR UL 1741 SCOPE 1.1A COMPLIANT



Note: Legible Hand Drawn One-Line is Acceptable

SAMPLE ELECTRICAL ONE-LINE DRAWING – PROVIDED FOR REFERENCE ONLY TYPICAL ISOLATION AND FAULT PROTECTION FOR SYNCHRONOUS GENERATOR

ONE-LINE DRAWING			
Licensed PE/Contractor	PE/Contractor License Number		
PE/Contractor Address	PE/Contractor Signature		



LEGEND

27 Undervoltage

- 32 Reverse Power (Not Required for Flow-Back)
- 51N Neutral overcurrent (required for grounded secondary)
- 59 Overvoltage
- 59N Zero sequence overvoltage (assuming ungrounded secondary on power transformer)

81o/u Over/Underfrequency

NOTES

- A) See technical requirements for permissible connection configurations and protection. Transformer connections proposed shall be shown on the one-line drawing by the Project Developer. Transformer connection and secondary grounding to be approved by Utility.
- B) Protection alternatives for the various acceptable transformer connections are shown. Only one protection alternative will ultimately be used, depending on the actual transformer winding connections. VT's for 59, 27, 81o/u and 32 are shown connected on the primary (Project side) of the power transformer, but may instead be connected on the secondary (Utility side). VT's are required on the secondary of the power transformer if a 59N is required for an ungrounded secondary connection. IEEE std 1547 requirements for voltage and frequency must be met at the PCC. IEEE Std. 1547 permits the VT's to be connected at the point of generator connection in certain cases.
- C) Main breaker protection, generator protection and synchronizing equipment are not shown.
- D) Trip of all 52G breakers or the 52M breaker is acceptable, depending upon whether the Project Developer wants to serve its own isolated load after loss of Utility service.

SAMPLE ELECTRICAL ONE-LINE DRAWING – PROVIDED FOR REFERENCE ONLY TYPICAL ISOLATION AND FAULT PROTECTION FOR INDUCTION GENERATOR



- 27 Undervoltage
- 32 Reverse Power (Not Required for Flow-Back)
- 51N Neutral overcurrent (required for grounded secondary)
- 59 Overvoltage
- 59N Zero sequence overvoltage (assuming ungrounded secondary on power transformer)
- 81o/u Over/Underfrequency

NOTES

- A) See technical requirements for permissible connection configurations and protection. Transformer connections proposed shall be shown on the one-line drawing by the Project Developer. Transformer connection and secondary grounding to be approved by Utility.
- B) Protection alternatives for the various acceptable transformer connections are shown. Only one protection alternative will ultimately be used, depending on the actual transformer winding connections. VT's for 59, 27, 81o/u and 32 are shown connected on the primary (Project side) of the power transformer, but may instead be connected on the secondary (Utility side). VT's are required on the secondary of the power transformer if a 59N is required for an ungrounded secondary connection. IEEE std 1547 requirements for voltage and frequency must be met at the PCC. IEEE Std. 1547 permits the VT's to be connected at the point of generator connection in certain cases.
- C) Main breaker protection, generator protection and synchronizing equipment are not shown.
- D) Trip of all 52G breakers or the 52M breaker is acceptable, depending upon whether the Project Developer wants to serve its own isolated load after loss of Utility service.