



**2019 Annual Groundwater Monitoring and
Corrective Action Report**

JH Campbell Power Plant
Ponds 1-2 North and 1-2 South CCR Unit
West Olive, Michigan

January 2020



2019 Annual Groundwater Monitoring and Corrective Action Report

**JH Campbell Power Plant
Ponds 1-2 North and 1-2 South CCR Unit**

West Olive, Michigan

January 2020

*Prepared For
Consumers Energy Company*

A handwritten signature in black ink, appearing to read "Sarah B. Holmstrom", written over a horizontal line.

Sarah B. Holmstrom, P.G.
Project Hydrogeologist

A handwritten signature in black ink, appearing to read "Graham Crockford", written over a horizontal line.

Graham Crockford, C.P.G.
Program Manager

TRC | Consumers Energy

Final

X:\WPAAM\PT2\322174\0000\GMR\PONDS 1-2\R322174.0 PONDS 1-2.DOCX

Table of Contents

| | |
|--|-----|
| Executive Summary | iii |
| Section 1 Introduction | 1-1 |
| 1.1 Program Summary | 1-1 |
| 1.2 Site Overview..... | 1-2 |
| 1.3 Geology/Hydrogeology..... | 1-3 |
| Section 2 Groundwater Monitoring..... | 2-1 |
| 2.1 Monitoring Well Network | 2-1 |
| 2.1.1 Monitoring Well Replacement | 2-2 |
| 2.2 November 2018 Assessment Groundwater Monitoring..... | 2-2 |
| 2.3 Semiannual Groundwater Monitoring | 2-2 |
| 2.3.1 Data Summary..... | 2-3 |
| 2.3.2 Data Quality Review..... | 2-3 |
| 2.3.3 Groundwater Flow Rate and Direction..... | 2-3 |
| Section 3 Statistical Evaluation..... | 3-1 |
| 3.1 Establishing Groundwater Protection Standards..... | 3-1 |
| 3.2 Data Comparison to Groundwater Protection Standards..... | 3-1 |
| Section 4 Corrective Action | 4-1 |
| 4.1 Nature and Extent Groundwater Sampling | 4-1 |
| 4.2 Assessment of Corrective Measures..... | 4-2 |
| 4.3 Remedy Selection | 4-2 |
| Section 5 Conclusions and Recommendations | 5-1 |
| Section 6 References..... | 6-1 |

List of Tables

| | |
|---------|--|
| Table 1 | Summary of Groundwater Elevation Data – April & October 2019 |
| Table 2 | Summary of Field Parameter Results – April & October 2019 |
| Table 3 | Summary of Background Well Groundwater Sampling Results (Analytical) – April & October 2019 |
| Table 4 | Summary of Pond 1-2 Groundwater Sampling Results (Analytical) – April & October 2019 |
| Table 5 | Summary of Groundwater Protection Standard Exceedances – April 2019 |

| | |
|---------|--|
| Table 6 | Summary of Groundwater Protection Standard Exceedances – October 2019 |
| Table 7 | Summary of Nature and Extent Groundwater Sampling Results (Analytical) – February to October 2019 |

List of Figures

| | |
|----------|--|
| Figure 1 | Site Location Map |
| Figure 2 | Site Plan with CCR Monitoring Well Locations |
| Figure 3 | Groundwater Contour Map – April 22, 2019 |
| Figure 4 | Groundwater Contour Map – October 7, 2019 |

List of Appendices

| | |
|------------|--|
| Appendix A | Groundwater Monitoring System Certification |
| Appendix B | Monitoring Well Installation & Decommissioning Logs |
| Appendix C | November 2018 Assessment Monitoring Data Summary |
| Appendix D | Data Quality Review |
| Appendix E | June 2018 Statistical Evaluation of Initial Assessment Monitoring Sampling Event |
| Appendix F | April 2019 Assessment Monitoring Statistical Evaluation |
| Appendix G | October 2019 Assessment Monitoring Statistical Evaluation |
| Appendix H | ACM Extension Certification |
| Appendix I | Semiannual Progress Report |

Executive Summary

On behalf of Consumers Energy, TRC has prepared this report for JH Campbell (JHC) Pond 1-2 CCR unit to cover the period of January 1, 2019 to December 31, 2019. Pond 1-2 was in assessment monitoring at the beginning and at the end of the period covered by this report. Data that have been collected and evaluated in 2019, including assessment monitoring data from November 2018, are presented in this report.

Consumers Energy first reported the potential for statistically significant increases (SSIs) for Appendix III constituents in the *Annual Groundwater Monitoring Report, JH Campbell Power Plant, Unit 1-2 North and 1-2 South CCR Unit* (TRC, January 2018). The statistical evaluation of the Appendix III indicator parameters confirming SSIs over background were as follows:

- Boron at JHC-MW-15001, JHC-MW-15002, JHC-MW-15003, JHC-MW-15004, and JHC-MW-15005;
- Calcium at JHC-MW-15001 and JHC-MW-15004;
- Chloride at JHC-MW-15001;
- pH at JHC-MW-15002 and JHC-MW-15003;
- Sulfate at JHC-MW-15001, JHC-MW-15002, JHC-MW-15003, JHC-MW-15004, and JHC-MW-15005; and
- Total dissolved solids (TDS) at JHC-MW-15001, JHC-MW-15004, and JHC-MW-15005.

On April 25, 2018, Consumers Energy entered assessment monitoring upon determining that an Alternate Source Demonstration for the Appendix III constituents was not successful. After subsequent sampling for Appendix IV constituents, Consumers Energy provided notification that arsenic was present at statistically significant levels above the federal groundwater protection standard (GWPS) established at 10 ug/L (TRC, 2019) in two out of five downgradient monitoring wells at Ponds 1-2 as follows:

- Arsenic at JHC-MW-15002 and JHC-MW-15003.

The *Assessment of Corrective Measures* (ACM) was initiated on April 15, 2019 and was certified and submitted to EGLE on September 11, 2019 in accordance with the schedule in §257.96. The certification for a 60-day time extension to the 90-day completion period of the ACM required per §257.96(a) is included in this report.

The ACM documents that the groundwater nature and extent has been defined, as required in §257.95(g)(1). Although arsenic concentrations exceed the GWPS in on-site groundwater, the property containing the site is owned and operated by Consumers Energy and on-site

groundwater is not used for drinking water. The nearest residential drinking water wells are located north and east of the Dry Ash Landfill (north of the background monitoring wells and upgradient of Ponds 1-2) and to the south-southeast of Pond 1-2, on the opposite side of the Pigeon River. Per §257.96(b), Consumers Energy is continuing to monitor groundwater in accordance with the assessment monitoring program as specified in §257.95. Overall, the assessment monitoring statistical evaluations have confirmed that arsenic is the only Appendix IV constituent present at statistically significant levels above the GWPS and groundwater monitoring downgradient from Ponds 1-2 further demonstrate that there are currently no adverse effects on human health or the environment from either surface water or groundwater due to the CCR management at Ponds 1-2.

Consumers Energy has not selected a remedy pursuant to §257.97. The semiannual progress report describing the progress in selecting and designing the remedy required pursuant to §257.97(a) is included in this report. The *“JH Campbell Generating Facility Bottom Ash Ponds 1-2 Closure Plan,”* prepared by Golder in January 2018 was submitted to and approved by EGLE. Dewatering and removal of ash from Ponds 1-2 for beneficial reuse began in June 2018 and continued through September 2018. CCR removal activities at Ponds 1-2 were completed in October 2018 and Consumers Energy submitted final documentation of CCR removal to EGLE in August 2019. On October 22, 2019 EGLE provided written concurrence that all bottom ash had been removed from Ponds 1-2 based on multiple lines of evidence described in the approved closure work plan.

Consumers Energy will continue to evaluate corrective measures in accordance with §257.96 and §257.97 as outlined in the ACM and will continue executing the self-implementing groundwater compliance schedule in conformance with §257.90 - §257.98, which includes semiannual assessment monitoring in accordance with §257.95 to monitor site groundwater conditions and inform the remedy selection. The next semiannual assessment monitoring events are scheduled to occur in the second and fourth calendar quarters of 2020.

Section 1

Introduction

On April 17, 2015, the United States Environmental Protection Agency (USEPA) published the final rule for the regulation and management of Coal Combustion Residuals (CCR) under the Resource Conservation and Recovery Act (RCRA) (the CCR Rule) (USEPA, April 2015 as amended). Standards for groundwater monitoring and corrective action codified in the CCR Rule (40 CFR 257.90 – 257.98), apply to the Consumers Energy Company (Consumers Energy) Ponds 1-2 North and 1-2 South bottom ash pond CCR Unit at the JH Campbell Power Plant Site (JHC Ponds 1-2). Pursuant to the CCR Rule, no later than January 31, 2018, and annually thereafter, the owner or operator of a CCR unit must prepare an annual groundwater monitoring and corrective action report for the CCR unit documenting the status of groundwater monitoring and corrective action for the preceding year in accordance with §257.90(e).

On behalf of Consumers Energy, TRC has prepared this Annual Groundwater Monitoring Report for JHC Ponds 1-2 to cover the period of January 1, 2019 to December 31, 2019. Ponds 1-2 was in assessment monitoring at the beginning and at the end of the period covered by this report. Data that have been collected and evaluated in 2019, including assessment monitoring data from November 2018, are presented in this report.

1.1 Program Summary

As discussed in the *2018 Annual Groundwater Monitoring Report for the JH Campbell Power Plant Units 1-2 North and 1-2 South CCR Unit* (2018 Annual Report)(TRC, January 2019), Consumers Energy initiated an Assessment Monitoring Program for the Ponds 1-2 pursuant to §257.95 of the CCR Rule that included sampling and analyzing groundwater within the groundwater monitoring system for all constituents listed in Appendix III and Appendix IV.

On April 25, 2018, Consumers Energy entered assessment monitoring upon determining that an Alternate Source Demonstration for the Appendix III constituents was not successful. After subsequent sampling for Appendix IV constituents, Consumers Energy provided notification that arsenic was present at statistically significant levels above the federal groundwater protection standard (GWPS) established at 10 ug/L (TRC, 2019) in two out of five downgradient monitoring wells at Ponds 1-2 as follows:

- Arsenic at JHC-MW-15002 and JHC-MW-15003.

The CCR Rule 40 CFR §257.96(a) requires that an owner or operator initiate an assessment of corrective measures to prevent further release, to remediate any releases, and to restore impacted areas to original conditions if any Appendix IV constituent has been detected at a

statistically significant level exceeding a GWPS. The *Assessment of Corrective Measures* report (ACM) (TRC, September 2019) was initiated on April 15, 2019 and was certified and submitted on September 11, 2019 in accordance with the schedule in §257.96.

The ACM documents that the groundwater nature and extent has been defined, as required in §257.95(g)(1), based on the site-specific hydrogeology and data collected from existing monitoring wells. Although arsenic concentrations exceed the GWPS in on-site groundwater, an evaluation of risk demonstrates that there are currently no adverse effects on human health or the environment from either surface water or groundwater due to CCR management at Ponds 1-2.

Consumers Energy will continue to evaluate corrective measures in accordance with §257.96 and §257.97 as outlined in the ACM and will continue executing the self-implementing groundwater compliance schedule in conformance with §257.90 - §257.98, which includes semiannual assessment monitoring in accordance with §257.95 as presented in this report.

1.2 Site Overview

The JH Campbell Power Plant is a coal fired power generation facility located in West Olive, Michigan, on the eastern shore of Lake Michigan. It is bordered by the Pigeon River on the south, 156th Avenue on the east, and Croswell Street to the north with Lakeshore Drive bisecting the site from north to south. The power generating plant consists of three coal fired electric generating units located on the western side of the site and the CCR disposal area is on the east side of the site, east of Lakeshore Drive. Figure 1 is a site location map showing the facility and the surrounding area.

Currently, there are no remaining active CCR surface impoundments at the JHC solid waste disposal facility. The CCR disposal area had contained two primary components: a system of wet ash ponds and a dry ash disposal facility (i.e., the JHC Dry Ash Landfill). The CCR surface impoundments located within the former wet ash pond area are Pond 1-2 Bottom Ash Ponds (Ponds 1-2), Pond 3 North and Pond 3 South Bottom Ash Pond (collectively Pond 3), and Pond A. All of these impoundments have been deactivated and decommissioned. The existing Dry Ash Landfill is a double-composite geomembrane lined landfill which is licensed and permitted for CCR disposal and includes two double-lined leachate and contact water retention ponds. Site features are shown on Figure 2.

Dry, moisture-conditioned CCR from the three coal fired electric generating units continues to be managed in the licensed solid waste landfill which is regulated under Part 115 of the Natural Resources and Environmental Protection Act (NREPA), PA 451 of 1994, as amended, and monitored in adherence to the facility's EGLE-approved *Hydrogeological Monitoring Plan (HMP)*

for JH Campbell Ash Storage Facility, Consumers Power Company, Solid Waste Disposal Area, Coal Ash, Type III (September 1996).

The surface impoundments in the wet ash pond areas were decommissioned starting in 2017 and replaced with concrete bottom ash treatment tanks. In June 2017, decommissioning of Pond 3 North began with recovery of CCR from the pond for beneficial reuse prior to backfilling with clean fill. The above-grade concrete treatment tanks were constructed within the footprint of the Pond 3 North area to manage bottom ash and became operational in July 2018. In addition, hydraulic loading was ceased at Ponds 1-2 and Pond A in June 2018 and the southern portion of Pond 3 in July 2018 (when the concrete tanks were in service).

Removal of ash from Ponds 1-2 for beneficial reuse began in June 2018 and continued through September 2018. CCR removal at Pond 3 South began in September 2018 and continued through October 2018. In addition, Pond A has been decommissioned with final cover placed in summer 2019. Groundwater monitoring is being conducted at Pond A during the post-closure period under the *Pond A Hydrogeological Monitoring Plan, JH Campbell Power Plant, West Olive, Michigan* (March 2019; Revised July 2019) (approved by EGLE August 13, 2019), as well as in accordance with the RCRA CCR Rule.

Bottom ash is currently sluiced to the concrete tanks where it is dewatered. The settled and dewatered bottom ash is beneficially reused or managed at the Dry Ash Landfill. Sluice water decanted from the tanks flows through a permitted ditching system to the recirculation pond. Water in the recirculation pond is then discharged through a National Pollutant Discharge Elimination System (NPDES) permitted outfall and into Pigeon River.

The purpose of the dry ash disposal facility is to contain dry bottom and fly ash produced as a result of burning coal for power production. Dry ash from all of the generating units is stored in silos until it is placed into the facility or is sold and shipped off site. This report focuses on the JHC Ponds 1-2 CCR unit.

1.3 Geology/Hydrogeology

The upgradient/background wells are located to the north-northwest of the JHC Dry Ash Landfill. Groundwater is typically encountered around 30 to 35 feet below ground surface (ft bgs), except in the recently excavated areas of Bottom Ash Ponds 1-2 and Bottom Ash Pond 3 South where groundwater is now within 5 to 10 ft bgs due to grade changes, and generally flows to the south-southeast toward the Pigeon River. The subsurface materials encountered at the JH Campbell site generally consist of approximately 40 to 60 feet of poorly graded, fine-grained lacustrine sand. A laterally extensive clay-rich till is generally encountered within approximately 40 to 60 ft bgs across the site that according to deep drilling logs conducted at

the JH Campbell Power Plant (just west of the CCR units) is on the order of 80 feet thick and extends to the top of shale bedrock approximately 140 ft bgs.

Section 2

Groundwater Monitoring

2.1 Monitoring Well Network

In accordance with 40 CFR 257.91, Consumers Energy established a groundwater monitoring system for JHC Ponds 1-2, which currently consists of 12 monitoring wells (6 background monitoring wells and 6 downgradient monitoring wells) that are screened in the uppermost aquifer. The monitoring well locations are shown on Figure 2. Six monitoring wells located north-northwest of the Dry Ash Landfill provide data on background groundwater quality that has not been affected by the CCR unit (JHC-MW-15023 through JHC-MW-15028). Background groundwater quality data from these six background wells are additionally used for the CCR groundwater monitoring program at three other JH Campbell CCR units.

Six Background Monitoring Wells:

- JHC-MW-15023 through JHC-MW-15028

Due to the cessation of hydraulic loading and decommissioning of Ponds 1-2 and Pond 3, the groundwater flow direction changed significantly from the previous baseline and assessment monitoring events such that groundwater flow is generally toward the south at Pond 1-2s and to the south/southwest at Pond 3. As a result, several of the monitoring wells were no longer located in the downgradient direction. In response, as documented in the 2018 Annual Report, Consumers Energy installed five new downgradient wells on December 3 through December 5, 2018 and collected additional data from these new wells to reassess groundwater flow and ensure sufficient wells were appropriately located to assess groundwater quality downgradient from the Ponds 1-2 and Pond 3 CCR Units.

As a result of the post-decommissioning changes in groundwater flow direction, Ponds 1-2 monitoring wells JHC-MW-15001 (now upgradient), JHC-MW-15002 (now side gradient), and JHC 15003 (now side gradient) are no longer positioned downgradient of groundwater flow across the Ponds 1-2 area. Since these wells were historically located downgradient of Ponds 1-2, when flow was radially outward, they will continue to be sampled and evaluated as part of the assessment monitoring program to evaluate groundwater quality post-CCR removal. An updated groundwater monitoring network certification is included as Appendix A.

Monitoring wells JHC-MW-18004 through JHC-MW-18005 were installed on the southwest and south edges of former Ponds 1-2. Data collected from these wells in 2018 and 2019 confirms that the monitoring wells are appropriately positioned to assess groundwater quality downgradient from the former Ponds 1-2 CCR Unit. As such, these wells have been added to the Ponds 1-2

monitoring system and will serve as downgradient monitoring wells in the assessment monitoring program. The Ponds 1-2 monitoring wells now consist of:

Ponds 1-2 Downgradient Monitoring Wells:

- JHC-MW-15005
- JHC-MW-18004
- JHC-MW-18005

Other Ponds Assessment Monitoring Wells (currently located up- or side gradient):

- JHC-MW-15001 (upgradient)
- JHC-MW-15002 (side gradient)
- JHC-MW-15003 (side gradient)

As shown on Figure 2, monitoring wells JHC-MW-15029 and JHC-MW-15030 are used for water level measurements only. Static water level data are collected at additional wells throughout the JH Campbell CCR units and used to construct a site-wide groundwater contour map; therefore, the following discussion includes a comprehensive summary of wells replaced and added during 2019.

2.1.1 Monitoring Well Replacement

Monitoring well JHC-MW-15008, located downgradient of Pond A, was decommissioned in June 2019 due to insufficient groundwater recharge as a result of the groundwater table re-equilibrating to a lower elevation subsequent to decommissioning Pond A. JHC-MW-15008R was installed in the vicinity of the decommissioned well JRW-MW-15008 to continue to evaluate groundwater downgradient of Pond A. Well decommissioning, installation, and construction are documented in Appendix B.

2.2 November 2018 Assessment Groundwater Monitoring

As discussed in the 2018 Annual Report, the second 2018 semiannual monitoring event was conducted in November 2018, but laboratory analysis and data quality review were ongoing as of the writing of the 2018 Annual Report. A summary of the November 2018 assessment monitoring event was prepared under a separate cover and is included in Appendix C.

2.3 Semiannual Groundwater Monitoring

Per §257.95, all wells in the CCR unit monitoring program must be sampled at least semiannually. One semiannual event must include analysis for all constituents from

Appendix III and Appendix IV constituents and one semiannual event may include analysis for all constituents in Appendix III and those constituents in Appendix IV of the CCR Rule that were detected during prior sampling. In addition to the Appendix III and IV constituents, field parameters including dissolved oxygen, oxidation reduction potential, specific conductivity, temperature, and turbidity were collected at each well. Samples were collected and analyzed in accordance with the *JH Campbell Monitoring Program Sample Analysis Plan* (SAP) (ARCADIS, 2016).

2.3.1 Data Summary

The first semiannual groundwater assessment monitoring event for 2019 was performed on April 22 through April 26 and April 29, 2019 and the second semiannual groundwater assessment monitoring event for 2019 was performed on October 7 through October 11, 2019. Both events were performed by TRC personnel, and samples were analyzed by Eurofins TestAmerica Laboratories Inc. (TestAmerica) in accordance with the SAP. Static water elevation data were collected at all monitoring well locations. Groundwater samples were collected from the 6 background monitoring wells and 6 downgradient monitoring wells for the Appendix III and Appendix IV constituents and field parameters. In addition, quarterly sampling was conducted in February 28, 2019 and August 13, 2019 at JHC-MW-18004 and JHC-MW-18005 in order to assess groundwater flow conditions and groundwater quality at the new wells and establish a dataset with sufficient number of samples (minimum of 4) to statistically evaluate the data.

A summary of the groundwater data collected during both the April 2019 event and October 2019 event are provided on Table 1 (static groundwater elevation data), Table 2 (field data), Table 3 (background well analytical results), and Table 4 (Ponds 1-2 analytical results). The quarterly monitoring data collected from the new wells in February and August are also included in Table 1, Table 2, and Table 4.

2.3.2 Data Quality Review

Data from each round were evaluated for completeness, overall quality and usability, method-specified sample holding times, precision and accuracy, and potential sample contamination. The data were found to be complete and usable for the purposes of the CCR monitoring program. The data quality reviews are summarized in Appendix D.

2.3.3 Groundwater Flow Rate and Direction

Groundwater elevations measured across the Site during the April 2019 event and the October 2019 event are provided on Table 1. April 2019 and October 2019 groundwater elevations were used to construct the groundwater contour maps provided on Figure 3

and Figure 4, respectively. The average hydraulic gradient was calculated using the following well pairs: JHC-MW-15029/JHC-MW-15030, JHC-MW-15029/JHC-MW-15005, JHC-MW-15019/JHC-MW-15035 and JHC-MW-15023/JHC-MW-15037 (Figure 2). Using the mean hydraulic conductivity of 62 ft/day (ARCADIS, 2016) and an assumed effective porosity of 0.4, the estimated average seepage velocity is approximately 0.66 ft/day or 240 ft/year for the April 2019 event, and approximately 0.66 ft/day or 239 ft/year for the October 2019 event.

The general groundwater flow direction is similar to that identified in previous monitoring rounds and continues to demonstrate that the downgradient wells are appropriately positioned to detect the presence of Appendix IV constituents that could potentially migrate from Ponds 1-2.

Section 3

Statistical Evaluation

Assessment monitoring is continuing at Ponds 1-2 while corrective measures are further evaluated in accordance with §257.96 and §257.97 as outlined in the ACM. The following section summarizes the statistical approach applied to assess the 2019 groundwater data in accordance with the assessment monitoring program. The statistical evaluation details are provided in Appendix C (*November 2018 Assessment Monitoring Data Summary and Statistical Evaluation*), Appendix E (*June 2018 Statistical Evaluation of Initial Assessment Monitoring Event*), Appendix F (*April 2019 Assessment Monitoring Data Summary and Statistical Evaluation*), and Appendix G (*October 2019 Assessment Monitoring Data Summary and Statistical Evaluation*).

3.1 Establishing Groundwater Protection Standards

The Appendix IV GWPSs are used to assess whether Appendix IV constituent concentrations are present in groundwater at unacceptable levels as a result of CCR Unit operations by statistically comparing concentrations in the downgradient wells to the GWPSs for each Appendix IV constituent. The calculation of the GWPSs is documented in the *Groundwater Protection Standards* technical memorandum included in Appendix C of the 2018 Annual Report.

3.2 Data Comparison to Groundwater Protection Standards

Consistent with the *Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities, Unified Guidance* (Unified Guidance) (USEPA, 2009), the preferred method for comparisons to a fixed standard are confidence limits. An exceedance of the standard occurs when the 99 percent lower confidence level of the downgradient data exceeds the GWPS. As documented in the January 14, 2019 *Notification of Appendix IV Constituent Exceeding Groundwater Protection Standard per §257.95(g)*, arsenic was present at statistically significant levels above the GWPSs in two of the downgradient wells at Ponds 1-2 based on the statistical data comparison for the first semiannual assessment monitoring event (June 2018) (Appendix E). Therefore, Consumers Energy initiated an Assessment of Corrective Measures (ACM). Assessment monitoring is ongoing.

Overall, the statistical evaluations have confirmed that arsenic is the only Appendix IV constituent present at statistically significant levels above the GWPSs. Ponds 1-2 have been decommissioned and CCRs have been removed. Due to the changes in groundwater flow direction subsequent to pond decommissioning, monitoring wells JHC-MW-15001, JHC-MW-15002 and JHC-MW-15003 are no longer downgradient of groundwater flow across the Ponds 1-2 area. However, as discussed in Section 2.1, they will continue to be sampled and evaluated as

part of the assessment monitoring program and used to evaluate groundwater quality post-CCR removal. A summary of the confidence intervals for April 2019 and October 2019 are provided in Table 5 and Table 6, respectively.

Groundwater chemistry is currently changing as a result of closure activities performed at Ponds 1-2. As discussed in the ACM, Ponds 1-2 have been decommissioned and CCRs have been removed and groundwater flow direction has changed such that groundwater generally flows to the south-southwest and mounding is no longer observed. The cessation of hydraulic loading and recharge of the aquifer are expected to have changed groundwater conditions, and many Appendix III and Appendix IV constituents may be affected by this change. Groundwater conditions will continue to be monitored while corrective measures continue to be evaluated and a remedy is selected. There is still some uncertainty surrounding how changes in groundwater oxidation-reduction conditions may affect contaminant transport as a result of changing conditions due to CCR removal activities. Groundwater monitoring in 2020 will reduce uncertainty surrounding the potential changes in groundwater oxidation-reduction conditions and the effect on contaminant transport. These observations will be critical for the comparison of corrective measures alternatives.

Section 4

Corrective Action

Consumers Energy provided notification that arsenic was present at statistically significant levels above the federal groundwater protection standard (GWPS) established at 10 ug/L (TRC, 2019) in two out of five downgradient monitoring wells at Ponds 1-2 as follows:

- Arsenic at JHC-MW-15002 and JHC-MW-15003

The CCR Rule 40 CFR §257.96(a) requires that an owner or operator initiate an assessment of corrective measures (ACM) to prevent further release, to remediate any releases, and to restore impacted areas to original conditions if any Appendix IV constituent has been detected at a statistically significant level exceeding a GWPS. The *Assessment of Corrective Measures (ACM)* (TRC, September 2019) was initiated on April 15, 2019 and was certified and submitted to EGLE on September 11, 2019 in accordance with the schedule in §257.96.

4.1 Nature and Extent Groundwater Sampling

Per §257.95(g)(1), in the event that the facility determines, pursuant to §257.93(h), that there is a statistical exceedance of the GWPSs for one or more of the Appendix IV constituents, the facility must characterize the nature and extent of the release of CCR as well as any site conditions that may affect the remedy selected. The nature and extent data consist of Appendix III and IV constituents collected from the background and downgradient CCR monitoring well networks and from supplemental downgradient wells in the HMP monitoring well network. In addition to the existing HMP wells, TRC, on behalf of Consumers Energy, installed shallow and deep step out wells nested with existing downgradient wells MW-14, PZ-23, PZ-24, and PZ-40 (shallow well only) in April 2018 to further characterize the horizontal and vertical distribution of Appendix III and IV constituents in groundwater downgradient from the CCR units. The locations of the additional downgradient step out wells (MW-14S, MW-14D, PZ-23S, PZ-23D, PZ-24S, PZ-24D, PZ-40S) are shown on Figure 2. A summary of the nature and extent groundwater data collected from February through October 2019, including both the April 2019 and October 2019 semiannual events, are provided on Table 7 (Nature and Extent analytical). The soil boring logs and well construction diagrams for the step out monitoring wells utilized for the nature and extent groundwater sampling are included in Appendix B.

As discussed in the ACM, the nature and extent of contamination (e.g. arsenic in groundwater) relative to GWPSs has been defined per the RCRA CCR rule requirements based on the site-specific hydrogeology. The presence of nearby surface water bodies (Recirculation Pond and the Pigeon River) as well as the unimpacted background monitoring wells to the north provide the boundaries for the extent of the GWPS exceedances. In addition, the underlying clay unit

prevents the downward vertical migration of groundwater. Although Michigan Part 201 residential drinking water criteria are exceeded, there are no onsite drinking water wells downgradient from Ponds 1-2 and the closest downgradient drinking water wells are located south and east of the Pigeon River, separated hydraulically by the river. Shallow groundwater has the potential to vent to nearby surface water boundaries that are not used for drinking water. Although several Appendix III and IV constituents exceed the Michigan Part 201 generic groundwater-surface water interface (GSI) criteria in on-site wells, compliance for the GSI pathway is currently met based on data collected from the step out wells and the NPDES outfall at the Recirculation Pond.

4.2 Assessment of Corrective Measures

The ACM was completed on September 11, 2019 as a step towards developing a final remedy. The certification for a 60-day time extension to the 90-day completion period of the ACM required per §257.96(a) is included in Appendix H of this report.

Several groundwater remediation alternatives evaluated in the ACM are considered technically feasible to reduce on-site groundwater concentrations. The following corrective measures were retained for further evaluation for Ponds 1-2:

- Source Removal with Groundwater Monitoring and Institutional Controls;
- Source Removal with Post Source Control/Removal Monitoring;
- Source Removal with Groundwater Capture/Control;
- Source Removal with Impermeable Barrier;
- Source Removal with Active Geochemical Sequestration; and
- Source Removal with Passive Geochemical Sequestration.

Consumers Energy plans to utilize an adaptive management strategy for selecting the final groundwater remedy for Ponds 1-2 in coordination with the specified CCR source material management strategies discussed in the ACM. Under this remedy selection strategy, measures that remove source material, reduce infiltration, and/or minimize the potential for future migration during the closure process may be implemented to address existing conditions followed by monitoring and evaluation of the performance after closure. Adjustments will be made to the corrective measure remedy, as needed, to achieve the remedial goals (e.g. GWPS and/or risk/exposure/pathway-based criteria).

4.3 Remedy Selection

Consumers Energy has not selected a remedy pursuant to §257.97 and R 444 of Part 115. The semiannual progress report describing the progress in selecting and designing the remedy

required pursuant to §257.97(a) is included in Appendix I of this report. Consumers Energy has performed CCR removal at Ponds 1-2 as documented in the “*JH Campbell Generating Facility Bottom Ash Ponds 1-2 Closure Plan*,” (Golder, January 2018). Ponds 1-2 is undergoing closure by removal of CCR in accordance with §257.102(c). The December 2017 “*Bottom Ash Ponds 1-2 Closure Work Plan*” was submitted to and approved by EGLE. Dewatering and removal of ash from Ponds 1-2 for beneficial reuse began in June 2018 and continued through September 2018. CCR removal activities were completed in October 2018 and Consumers Energy submitted final documentation of CCR removal to EGLE in August 2019. On October 22, 2019 EGLE provided written concurrence that all bottom ash had been removed from Ponds 1-2 based on multiple lines of evidence described in the approved closure work plan. Changes in groundwater chemistry continue to be evaluated following the completion of CCR removal at Ponds 1-2. Groundwater monitoring in 2020 will reduce uncertainty surrounding potential changes in redox conditions and the effect on contaminant transport. These observations will be critical for the comparison of corrective measures alternatives.

Section 5

Conclusions and Recommendations

Assessment monitoring is ongoing at the JHC Ponds 1-2 CCR unit while corrective action continues to be assessed. Ponds 1-2 have been decommissioned and CCRs have been removed. Overall, the statistical evaluations have confirmed that arsenic is the only Appendix IV constituent present at statistically significant levels above the GWPSs.

The ACM also documents that groundwater nature and extent have been defined, as required in §257.95(g)(1). Although arsenic concentrations exceed the GWPS in on-site groundwater, an evaluation of risk demonstrates that there are currently no adverse effects on human health or the environment from either surface water or groundwater due to CCR management at Ponds 1-2.

Consumers Energy has also completed the removal of CCR from Ponds 1-2. The ACM report provided a high-level assessment of groundwater remediation technologies that could potentially address site-specific constituents of concern (i.e. arsenic) under known groundwater conditions. Changes in groundwater chemistry continue to be evaluated following the completion of CCR removal at Ponds 1-2. Groundwater monitoring in 2020 will reduce uncertainty surrounding potential changes in groundwater oxidation-reduction conditions and the effect on contaminant transport. These observations will be critical for the comparison of corrective measures alternatives.

Consumers Energy will continue to evaluate corrective measures in accordance with §257.96 and §257.97. The groundwater management remedy for the JHC Ponds 1-2 will be selected as soon as feasible to, at a minimum, meet the federal standards of §257.97(b) of the CCR Rule. Consumers Energy will continue executing the self-implementing groundwater compliance schedule in conformance with §257.90 - §257.98. The next semiannual monitoring events are scheduled for the second and fourth calendar quarters of 2020.

Section 6

References

- ARCADIS. May 13, 2016. Summary of Monitoring Well Design, Installation, and Development – Bottom Ash Pond Unit 1-2N/1-2S. JH Campbell Electric Generation Facility – West Olive, Michigan. Prepared for Consumers Energy Company.
- ARCADIS. May 18, 2016. Electric Generation Facilities RCRA CCR Detection Monitoring Program. JH Campbell Monitoring Program Sample and Analysis Plan, West Olive, Michigan. Prepared for Consumers Energy Company.
- Consumers Power Company. September 1996. Hydrogeological Monitoring Plan for JH Campbell Ash Storage Facility, Consumers Power Company, Solid Waste Disposal Area, Coal Ash, Type III.
- Golder Associates Inc. January 2018. JH Campbell Generating Facility Bottom Ash Ponds 1-2 Closure Plan, West Olive, Michigan. Prepared for Consumers Energy Company.
- TRC Environmental Corporation. October 2017. Groundwater Statistical Evaluation Plan – JH Campbell Power Plant, Units 1-2 North and 1-2 South, West Olive, Michigan. Prepared for Consumers Energy Company.
- TRC Environmental Corporation. January 2018. Annual Groundwater Monitoring Report, JH Campbell Power Plant, Unit 1-2 North and 1-2 South CCR Unit, West Olive, Michigan. Prepared for Consumers Energy Company.
- TRC Environmental Corporation. October 15, 2018. Groundwater Protection Standards, Consumers Energy, JH Campbell Site, Bottom Ash Pond Units 1-2 North and 1-2 South CCR Unit, technical memorandum prepared for Consumers Energy Company.
- TRC Environmental Corporation. January 2019. 2018 Annual Groundwater Monitoring Report, JH Campbell Power Plant, Unit 1-2 North and 1-2 South CCR Unit, West Olive, Michigan. Prepared for Consumers Energy Company.
- USEPA. 2009. Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities, Unified Guidance. Office of Conservation and Recovery. EPA 530/R-09-007.
- USEPA. April 2015. 40 CFR Parts 257 and 261. Hazardous and Solid Waste Management System: Disposal of Coal Combustion Residuals from Electric Utilities; Final Rule. 80 Federal Register 74 (April 17, 2015), pp. 21301-21501 (80 FR 21301).

USEPA. July 2018. 40 CFR Part 257. Hazardous and Solid Waste Management System: Disposal of Coal Combustion Residuals from Electric Utilities; Amendments to the National Minimum Criteria (Phase One, Part One); Final Rule. 83 Federal Register 146 (July 30, 2018), pp. 36435-36456 (83 FR 36435).

USEPA. April 2018. Barnes Johnson (Office of Resource Conservation and Recovery) to James Roewer (c/o Edison Electric Institute) and Douglas Green, Margaret Fawal (Venable LLP). Re: Coal Combustion Residuals Rule Groundwater Monitoring Requirements. April 30, 2018. United States Environmental Protection Agency, Washington, D.C. 20460. Office of Solid Waste and Emergency Response, now the Office of Land and Emergency Management.

Tables

Table 1
 Summary of Groundwater Elevation Data – February 2019 - October 2019
 JH Campbell – RCRA CCR Monitoring Program
 West Olive, Michigan

| Well Location | Ground Surface Elevation (ft) | TOC Elevation (ft) | Geologic Unit of Screen Interval | Screen Interval Elevation (ft) | February 26, 2019 | | April 22, 2019 | | August 12, 2019 | | October 7, 2019 | | |
|------------------------------|-------------------------------|--------------------|----------------------------------|--------------------------------|--------------------------|----------------------------|--------------------------|----------------------------|--------------------------|----------------------------|--------------------------|----------------------------|--|
| | | | | | Depth to Water (ft BTOC) | Groundwater Elevation (ft) | Depth to Water (ft BTOC) | Groundwater Elevation (ft) | Depth to Water (ft BTOC) | Groundwater Elevation (ft) | Depth to Water (ft BTOC) | Groundwater Elevation (ft) | |
| Background | | | | | | | | | | | | | |
| JHC-MW-15023 | 617.01 | 619.98 | Sand | 603.0 to 593.0 | -- | -- | 15.40 | 604.58 | 16.70 | 603.28 | 15.85 | 604.13 | |
| JHC-MW-15024 | 613.79 | 616.62 | Sand | 606.8 to 596.8 | -- | -- | 10.55 | 606.07 | 11.59 | 605.03 | 11.15 | 605.47 | |
| JHC-MW-15025 | 614.14 | 617.17 | Sand | 607.1 to 597.1 | -- | -- | 9.64 ⁽²⁾ | 607.53 | 10.65 | 606.52 | 10.08 | 607.09 | |
| JHC-MW-15026 | 615.09 | 618.04 | Sand | 607.1 to 597.1 | -- | -- | 11.63 | 606.41 | 12.21 | 605.83 | 11.88 | 606.16 | |
| JHC-MW-15027 | 614.77 | 617.30 | Sand | 604.8 to 594.8 | -- | -- | 12.11 | 605.19 | 12.51 | 604.79 | 12.42 | 604.88 | |
| JHC-MW-15028 | 611.02 | 613.80 | Sand | 603.0 to 593.0 | -- | -- | 12.08 | 601.72 | 12.30 | 601.50 | 12.00 | 601.80 | |
| JHC-MW-15029 | 608.08 | 610.95 | Sand | 600.1 to 590.1 | -- | -- | 9.83 | 601.12 | 10.18 | 600.77 | 9.50 | 601.45 | |
| JHC-MW-15030 | 604.05 | 607.17 | Sand | 600.1 to 590.1 | -- | -- | 8.21 | 598.96 | 8.94 | 598.23 | 7.75 | 599.42 | |
| Pond 1N, 1S, 2N, 2S | | | | | | | | | | | | | |
| JHC-MW-15001 | 607.02 | 609.53 | Sand | 603.5 to 598.5 | 11.23 | 598.30 | 11.42 | 598.11 | 11.70 | 597.83 | 11.10 | 598.43 | |
| JHC-MW-15002 | 618.18 | 621.27 | Sand | 590.2 to 580.2 | 23.70 | 597.57 | 23.77 | 597.50 | 23.74 | 597.53 | 23.49 | 597.78 | |
| JHC-MW-15003 | 623.16 | 627.20 | Sand | 595.2 to 585.2 | 32.14 | 595.06 | 32.28 | 594.92 | 32.38 | 594.82 | 32.05 | 595.15 | |
| JHC-MW-15005 | 606.22 | 609.99 | Sand | 579.2 to 569.2 | 17.78 ⁽³⁾ | 592.21 | 17.90 | 592.09 | 17.98 | 592.01 | 17.78 | 592.21 | |
| JHC-MW-18004 | 602.92 | 605.72 | Sand | 596.9 to 586.9 | 11.10 ⁽³⁾ | 594.62 | 11.34 | 594.38 | 11.65 | 594.07 | 10.98 | 594.74 | |
| JHC-MW-18005 | 600.30 | 603.16 | Sand | 595.3 to 585.3 | 9.35 ⁽³⁾ | 593.81 | 10.09 | 593.07 | 10.28 | 592.88 | 10.01 | 593.15 | |
| Pond 3N, 3S | | | | | | | | | | | | | |
| JHC-MW-15013 | 632.40 | 635.25 | Sand | 604.4 to 594.4 | 34.40 | 600.85 | 34.47 | 600.78 | 34.58 | 600.67 | 34.00 | 601.25 | |
| JHC-MW-15015 | 632.46 | 635.20 | Sand | 604.5 to 594.5 | 33.75 | 601.45 | 33.68 | 601.52 | 33.68 | 601.52 | 33.20 | 602.00 | |
| JHC-MW-15016 | 631.81 | 632.52 | Sand | 603.8 to 593.8 | 30.98 ⁽³⁾ | 601.54 | 30.90 | 601.62 | 30.97 | 601.55 | 30.54 | 601.98 | |
| JHC-MW-18001 | 609.09 | 611.98 | Sand | 603.1 to 593.1 | 11.02 ⁽³⁾ | 600.96 | 11.03 | 600.95 | 11.22 | 600.76 | 10.62 | 601.36 | |
| JHC-MW-18002 | 605.53 | 608.93 | Sand | 602.0 to 592.0 | 8.25 ⁽³⁾ | 600.68 | 8.27 | 600.66 | 8.59 | 600.34 | 7.94 | 600.99 | |
| JHC-MW-18003 | 605.36 | 608.78 | Sand | 601.9 to 591.9 | 8.18 ⁽³⁾ | 600.60 | 8.26 | 600.52 | 8.45 | 600.33 | 7.80 | 600.98 | |
| Landfill | | | | | | | | | | | | | |
| JHC-MW-15017 | 613.69 | 616.61 | Sand | 603.7 to 593.7 | -- | -- | 13.71 | 602.90 | 14.00 | 602.61 | 13.58 | 603.03 | |
| JHC-MW-15018 | 614.26 | 617.02 | Sand | 604.3 to 594.3 | -- | -- | 14.43 | 602.59 | 14.70 | 602.32 | 14.43 | 602.59 | |
| JHC-MW-15019 | 609.81 | 612.86 | Sand | 603.8 to 593.8 | -- | -- | 10.80 | 602.06 | 11.07 | 601.79 | 11.00 | 601.86 | |
| JHC-MW-15022 | 620.92 | 623.79 | Sand | 597.9 to 587.9 | -- | -- | 27.51 | 596.28 | 28.00 | 595.79 | 27.72 | 596.07 | |
| JHC-MW-15031 | 632.94 | 635.87 | Sand | 599.9 to 589.9 | -- | -- | 42.03 | 593.84 | 42.19 | 593.68 | 42.35 | 593.52 | |
| JHC-MW-15032 | 611.32 | 614.29 | Sand | 598.3 to 588.3 | -- | -- | 15.61 | 598.68 | 16.38 | 597.91 | 15.71 | 598.58 | |
| JHC-MW-15033 | 618.08 | 620.99 | Sand | 602.1 to 592.1 | -- | -- | 20.22 | 600.77 | 21.19 | 599.80 | 20.42 | 600.57 | |
| JHC-MW-15034 | 612.90 | 615.97 | Sand | 601.9 to 591.9 | -- | -- | 14.38 | 601.59 | 14.98 | 600.99 | 14.15 | 601.82 | |
| JHC-MW-15035 | 632.53 | 634.28 | Sand | 599.5 to 589.5 | -- | -- | 39.32 | 594.96 | 39.50 | 594.78 | 39.78 | 594.50 | |
| JHC-MW-15036 | 617.94 | 618.34 | Sand | 597.9 to 587.9 | -- | -- | 25.62 | 592.72 | 25.89 | 592.45 | 25.90 | 592.44 | |
| JHC-MW-15037 | 614.28 | 616.06 | Sand | 591.3 to 586.3 | -- | -- | 24.20 | 591.86 | 24.41 | 591.65 | 24.35 | 591.71 | |
| Pond A | | | | | | | | | | | | | |
| JHC-MW-15006 | 624.74 | 627.58 | Sand | 599.7 to 589.7 | 33.65 | 593.93 | 33.66 | 593.92 | 34.08 | 593.50 | 34.00 | 593.58 | |
| JHC-MW-15007 | 624.82 | 627.70 | Sand | 602.8 to 592.8 | 33.97 | 593.73 | 33.98 | 593.72 | 34.45 | 593.25 | 34.29 | 593.41 | |
| JHC-MW-15008 | 632.43 | 635.30 | Sand | 604.4 to 594.4 | Dry | | Dry | | Decommissioned | | Decommissioned | | |
| JHC-MW-15008R ⁽⁴⁾ | 632.32 | 634.67 | Sand | 597.3 to 587.3 | NA | NA | NA | NA | 42.05 | 592.62 | 41.98 | 592.69 | |
| JHC-MW-15009 | 632.33 | 635.32 | Sand | 602.3 to 592.3 | 41.72 | 593.60 | 41.60 | 593.72 | 42.10 | 593.22 | 42.28 | 593.04 | |
| JHC-MW-15010 | 632.55 | 635.57 | Sand | 602.6 to 592.6 | 41.37 | 594.20 | 41.10 | 594.47 | 41.58 | 593.99 | 41.90 | 593.67 | |
| JHC-MW-15011 | 627.71 | 630.83 | Sand | 600.7 to 590.7 | 37.81 | 593.02 | 37.85 | 592.98 | 38.07 | 592.76 | 37.85 | 592.98 | |

Notes:

Survey conducted by Nederveld, November 2015, October 2018, December 2018, and August 2019.

Elevation in feet relative to North American Vertical Datum 1988 (NAVD 88).

TOC: Top of well casing.

--: Not measured

NR: Not recorded

NA: Not Applicable

(1): The static water level for PZ-24S was taken on April 24, 2019.

(2): The static water level for JHC-MW-15025 was taken on April 23, 2019.

(3): The static water level data for JHC-MW-15005, JHC-MW-18001, JHC-MW-18002, JHC-MW-18003, JHC-MW-18004, and JHC-MW-18005 were collected on February 27, 2019;

JHC-MW-15016 was sampled on February 28, 2019.

(4): JHC-MW-15008R installed in June 2019.

Table 2
 Summary of Field Parameter Results – February 2019 - October 2019
 JH Campbell Ponds 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location | Sample Date | Dissolved Oxygen (mg/L) | Oxidation Reduction Potential (mV) | pH (SU) | Specific Conductivity (umhos/cm) | Temperature (°C) | Turbidity (NTU) |
|------------------------|-------------|----------------------------|---------------------------------------|------------|-------------------------------------|---------------------|--------------------|
| Background | | | | | | | |
| JHC-MW-15023 | 4/23/2019 | 2.21 | 79.5 | 5.9 | 106 | 8.80 | 9.95 |
| | 10/8/2019 | 0.49 | 106.0 | 6.2 | 97 | 10.40 | 4.75 |
| JHC-MW-15024 | 4/23/2019 | 1.56 | 73.7 | 7.2 | 321 | 7.30 | 3.90 |
| | 10/8/2019 | 0.61 | 25.3 | 7.4 | 261 | 11.80 | 3.00 |
| JHC-MW-15025 | 4/23/2019 | 7.47 | 70.1 | 6.7 | 140 | 6.80 | 14.55 |
| | 10/8/2019 | 2.15 | 9.8 | 8.1 | 370 | 11.70 | 2.15 |
| JHC-MW-15026 | 4/22/2019 | 5.02 | 55.8 | 6.9 | 136 | 10.00 | 7.61 |
| | 10/7/2019 | 3.70 | 110.5 | 7.3 | 140 | 11.50 | 11.60 |
| JHC-MW-15027 | 4/22/2019 | 5.99 | 61.0 | 6.5 | 79 | 9.10 | 8.87 |
| | 10/7/2019 | 4.75 | 134.6 | 6.3 | 70 | 11.40 | 3.45 |
| JHC-MW-15028 | 4/22/2019 | 7.60 | 48.0 | 7.6 | 81 | 9.60 | 4.99 |
| | 10/7/2019 | 6.37 | 84.5 | 7.2 | 87 | 14.20 | 3.85 |
| Ponds 1 & 2 | | | | | | | |
| JHC-MW-15001 | 4/25/2019 | 1.76 | 69.5 | 6.0 | 440 | 6.80 | 3.30 |
| | 10/9/2019 | 0.41 | -109.3 | 6.4 | 595 | 19.00 | 0.85 |
| JHC-MW-15002 | 4/25/2019 | 0.17 | -106.6 | 6.9 | 861 | 13.60 | 3.60 |
| | 10/9/2019 | 0.45 | -37.0 | 6.5 | 732 | 14.10 | 4.75 |
| JHC-MW-15003 | 4/29/2019 | 1.17 | 77.0 | 8.4 | 330 | 11.80 | 10.10 |
| | 10/9/2019 | 0.16 | 48.8 | 8.7 | 843 | 13.50 | 0.97 |
| JHC-MW-15005 | 4/25/2019 | 5.77 | 86.3 | 7.2 | 1087 | 7.10 | 19.95 |
| | 10/9/2019 | 0.95 | -9.5 | 7.3 | 765 | 16.00 | 3.60 |
| JHC-MW-18004 | 2/28/2019 | 5.37 | 104.0 | -- | 632 | 6.06 | -- |
| | 4/25/2019 | 6.05 | 89.8 | 7.2 | 620 | 8.00 | 6.90 |
| | 8/13/2019 | 1.85 | 63.8 | 7.5 | 805 | 16.10 | 0.45 |
| | 10/9/2019 | 1.55 | 97.0 | 7.2 | 658 | 16.50 | 0.24 |
| JHC-MW-18005 | 2/28/2019 | 1.31 | 103.1 | -- | 509 | 6.51 | -- |
| | 4/25/2019 | 2.50 | 65.5 | 9.0 | 397 | 8.50 | 2.88 |
| | 8/13/2019 | 1.40 | -8.9 | 8.9 | 437 | 15.00 | 0.90 |
| | 10/9/2019 | 1.43 | 58.6 | 8.8 | 483 | 14.00 | 0.46 |

Notes:

mg/L - Milligrams per Liter.
 mV - Millivolts.
 SU - Standard units
 umhos/cm - Micromhos per centimeter.
 °C - Degrees Celcius
 NTU - Nephelometric Turbidity Unit.
 -- - Not sampled.

Table 3
 Summary of Background Well Groundwater Sampling Results (Analytical): April 2019 - October 2019
 JH Campbell Background – RCRA CCR Monitoring Program
 West Olive, Michigan

| | | Sample Location: | | JHC-MW-15023 | | JHC-MW-15024 | | JHC-MW-15025 | | JHC-MW-15026 | | JHC-MW-15027 | | JHC-MW-15028 | | | |
|------------------------|-------|--------------------|------------------|---------------------|------------------|--------------|------------|--------------|-----------|--------------|-----------|--------------|-----------|--------------|------------|----------|---------|
| | | Sample Date: | | 4/23/2019 | 10/8/2019 | 4/23/2019 | 10/8/2019 | 4/23/2019 | 10/8/2019 | 4/22/2019 | 10/7/2019 | 4/22/2019 | 10/7/2019 | 4/22/2019 | 10/7/2019 | | |
| Constituent | Unit | EPA MCL | MI Residential* | MI Non-Residential* | MI GSI^ | Background | | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | 500 | 500 | 7,200 | 54 | < 50 | < 50 | < 50 | < 50 | < 50 | < 50 | < 50 | < 50 | < 50 | < 50 | |
| Calcium | mg/L | NC | NC | NC | 500 | 9.5 | 9.5 | 29 | 29 | 13 | 23 | 12 | 13 | 7.4 | 7.9 | 10 | 10 |
| Chloride | mg/L | 250** | 250 | 250 | 500 | 3.1 | 3.7 | 30 | 13 | 11 | 35 | 8.8 | 5.4 | 2.0 | < 2.0 | < 2.0 | < 2.0 |
| Fluoride | ug/L | 4,000 | NC | NC | NC | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250** | 250 | 250 | 500 | 12 | 12 | 7.5 | 7.5 | 8.5 | 10 | 8.6 | 8.4 | 7.5 | 12 | 5.5 | 5.5 |
| Total Dissolved Solids | mg/L | 500** | 500 | 500 | 500 | 75 | 91 | 180 | 270 | 75 | 210 | 140 | 100 | < 50 | 62 | < 50 | 76 |
| pH, Field | SU | 6.5 - 8.5** | 6.5 - 8.5 | 6.5 - 8.5 | 6.5 - 9.0 | 5.9 | 6.2 | 7.2 | 7.4 | 6.7 | 8.1 | 6.9 | 7.3 | 6.5 | 6.3 | 7.6 | 7.2 |
| Appendix IV | | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | 6.0 | 6.0 | 130 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Arsenic | ug/L | 10 | 10 | 10 | 10 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Barium | ug/L | 2,000 | 2,000 | 2,000 | 820 | 22 | 21 | 17 | 16 | 20 | 8.6 | 14 | 11 | 23 | 39 | 5.4 | 7.2 |
| Beryllium | ug/L | 4 | 4.0 | 4.0 | 18 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | 5.0 | 5.0 | 3.5 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | 100 | 100 | 11 | < 1.0 | 1.2 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | 3.6 |
| Cobalt | ug/L | NC | 40 | 100 | 100 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 |
| Fluoride | ug/L | 4,000 | NC | NC | NC | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 4.0 | 4.0 | 39 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 170 | 350 | 440 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 |
| Mercury | ug/L | 2 | 2.0 | 2.0 | 0.20# | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 73 | 210 | 3,200 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 |
| Radium-226 | pCi/L | NC | NC | NC | NC | 0.108 | < 0.147 | < 0.0821 | 0.173 | < 0.0726 | < 0.124 | < 0.0974 | 0.139 | < 0.103 | 0.249 | < 0.0933 | 0.125 |
| Radium-228 | pCi/L | NC | NC | NC | NC | < 0.355 | < 0.390 | < 0.349 | 0.379 | < 0.353 | < 0.348 | < 0.355 | < 0.387 | < 0.340 | < 0.348 | < 0.308 | < 0.349 |
| Radium-226/228 | pCi/L | 5 | NC | NC | NC | < 0.355 | < 0.390 | < 0.349 | 0.552 | < 0.353 | 0.381 | < 0.355 | < 0.387 | < 0.340 | 0.394 | < 0.308 | < 0.349 |
| Selenium | ug/L | 50 | 50 | 50 | 5.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Thallium | ug/L | 2 | 2.0 | 2.0 | 3.7 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 |

Notes:
 ug/L - micrograms per liter.
 mg/L - milligrams per liter.
 SU - standard units; pH is a field parameter.
 pCi/L - picocuries per liter.
 MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April 2012.
 NC - no criteria.
 * - Michigan Part 201 Generic Drinking Water Cleanup Criteria, December 30, 2013.
 ** - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR), April 2012.
 ^ - Michigan Part 201 Groundwater Surface Water Interface (GSI) Criteria. Hardness-dependent criteria calculated using site-specific hardness of 180 mg CaCO3/L as measured at surface water sample SW-01 collected on April 9, 2018 from the Pigeon River. Chromium GSI criterion based on hexavalent chromium per footnote {H}.
 # - If detected above 0.20 ug/L, further evaluation of low-level mercury may be necessary to evaluate the GSI pathway per Michigan Part 201 and MDEQ policy and procedure 09-014 dated June 20, 2012.
BOLD value indicates an exceedance of one or more of the listed criteria.
RED value indicates an exceedance of the MCL.
 All metals were analyzed as total unless otherwise specified.

Table 4
 Summary of Groundwater Sampling Results (Analytical): February 2019 - October 2019
 JH Campbell Ponds 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| | | Sample Location: | | | | JHC-MW-15001 | | JHC-MW-15002 | | JHC-MW-15003 | | JHC-MW-15005 | |
|------------------------|-------|--------------------|------------------|---------------------|------------------|--------------|-------------|--------------|--------------|--------------|--------------|--------------|--------------|
| | | Sample Date: | | | | 4/25/2019 | 10/9/2019 | 4/25/2019 | 10/9/2019 | 4/29/2019 | 10/9/2019 | 4/25/2019 | 10/9/2019 |
| Constituent | Unit | EPA MCL | MI Residential* | MI Non-Residential* | MI GSI^ | downgradient | | | | | | | |
| Appendix III | | | | | | | | | | | | | |
| Boron | ug/L | NC | 500 | 500 | 7,200 | 78 | 150 | 3,200 | 1,700 | 1,700 | 3,500 | 2,800 | 1,200 |
| Calcium | mg/L | NC | NC | NC | 500 | 69 | 73 | 85 | 99 | 36 | 110 | 170 | 110 |
| Chloride | mg/L | 250** | 250 | 250 | 500 | < 2.0 | < 2.0 | 17 | 20 | 18 | 47 | 28 | 30 |
| Fluoride | ug/L | 4,000 | NC | NC | NC | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250** | 250 | 250 | 500 | 39 | 21 | 190 | 280 | 75 | 210 | 240 | 130 |
| Total Dissolved Solids | mg/L | 500** | 500 | 500 | 500 | 280 | 350 | 410 | 480 | 200 | 580 | 800 | 360 |
| pH, Field | SU | 6.5 - 8.5** | 6.5 - 8.5 | 6.5 - 8.5 | 6.5 - 9.0 | 6.0 | 6.4 | 6.9 | 6.5 | 8.4 | 8.7 | 7.2 | 7.3 |
| Appendix IV | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | 6.0 | 6.0 | 130 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | 2.2 | 1.4 | 4.4 | 3.3 |
| Arsenic | ug/L | 10 | 10 | 10 | 10 | 5.8 | 6.3 | 50 | 57 | 10 | 8.4 | 1.2 | 1.4 |
| Barium | ug/L | 2,000 | 2,000 | 2,000 | 820 | 58 | 95 | 49 | 150 | 42 | 91 | 150 | 190 |
| Beryllium | ug/L | 4 | 4.0 | 4.0 | 18 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | 5.0 | 5.0 | 3.5 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | 0.41 | 2.5 | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | 100 | 100 | 11 | < 1.0 | 1.2 | < 1.0 | < 1.0 | 4.2 | 11 | 1.3 | 1.3 |
| Cobalt | ug/L | NC | 40 | 100 | 100 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | 43 | < 6.0 | < 6.0 |
| Fluoride | ug/L | 4,000 | NC | NC | NC | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 4.0 | 4.0 | 39 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | 3.2 | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 170 | 350 | 0.20# | < 10 | < 10 | 96 | 240 | < 10 | < 10 | 38 | 50 |
| Mercury | ug/L | 2 | 2.0 | 2.0 | 0.20 | < 0.20 | 0.25 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 73 | 210 | 3,200 | < 5.0 | < 5.0 | < 5.0 | 15 | 20 | 120 | 900 | 370 |
| Radium-226 | pCi/L | NC | NC | NC | NC | < 0.101 | < 0.162 | 0.233 | 0.698 | < 0.113 | 0.301 | 0.169 | 0.592 |
| Radium-228 | pCi/L | NC | NC | NC | NC | < 0.447 | < 0.516 | 0.409 | < 0.394 | < 0.530 | 0.421 | < 0.350 | 0.427 |
| Radium-226/228 | pCi/L | 5 | NC | NC | NC | < 0.447 | < 0.516 | 0.642 | 1.04 | < 0.530 | 0.722 | < 0.350 | 1.02 |
| Selenium | ug/L | 50 | 50 | 50 | 5.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | 2.9 | 18 | 140 | 66 |
| Thallium | ug/L | 2 | 2.0 | 2.0 | 3.7 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | 2.0 | 2.9 |

Notes:

ug/L - micrograms per liter.

mg/L - milligrams per liter.

SU - standard units; pH is a field parameter.

pCi/L - picocuries per liter.

MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April 2012.

NC - no criteria.

* - Michigan Part 201 Generic Drinking Water Cleanup Criteria, December 30, 2013.

** - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR), April 2012.

^ - Michigan Part 201 Groundwater Surface Water Interface (GSI) Criteria. Hardness-dependent criteria calculated using site-specific hardness of 180 mg CaCO3/L as measured at surface water sample SW-01 collected on April 9, 2018 from the Pigeon River. Chromium GSI criterion based on hexavalent chromium per footnote {H}.

- If detected above 0.20 ug/L, further evaluation of low-level mercury may be necessary to evaluate the GSI pathway per Michigan Part 201 and EGLE policy and procedure 09-014 dated June 20, 2012.

BOLD value indicates an exceedance of one or more of the listed criteria.

RED value indicates an exceedance of the MCL.

All metals were analyzed as total unless otherwise specified.

(1) - Field meter reading not usable due to malfunctioning groundwater meter. Displayed value is lab pH reading from an unpreserved bottle.

Table 4
 Summary of Groundwater Sampling Results (Analytical): February 2019 - October 2019
 JH Campbell Ponds 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-18004 | | | | JHC-MW-18005 | | | |
|------------------------|-------|--------------------|------------------|---------------------|---------------------|--------------------|------------|--------------|------------|--------------------|------------|------------|------------|
| Sample Date: | | | | | | 2/28/2019 | 4/25/2019 | 8/13/2019 | 10/9/2019 | 2/28/2019 | 4/25/2019 | 8/13/2019 | 10/9/2019 |
| Constituent | Unit | EPA MCL | MI Residential* | MI Non-Residential* | MI GSI [^] | downgradient | | | | | | | |
| Appendix III | | | | | | | | | | | | | |
| Boron | ug/L | NC | 500 | 500 | 7,200 | 900 | 920 | 1,200 | 620 | 660 | 650 | 750 | 660 |
| Calcium | mg/L | NC | NC | NC | 500 | 55 | 72 | 97 | 73 | 43 | 41 | 43 | 55 |
| Chloride | mg/L | 250** | 250 | 250 | 500 | 50 | 34 | 35 | 40 | 27 | 25 | 27 | 18 |
| Fluoride | ug/L | 4,000 | NC | NC | NC | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250** | 250 | 250 | 500 | 69 | 100 | 110 | 120 | 89 | 66 | 95 | 110 |
| Total Dissolved Solids | mg/L | 500** | 500 | 500 | 500 | 330 | 380 | 490 | 310 | 280 | 250 | 270 | 330 |
| pH, Field | SU | 6.5 - 8.5** | 6.5 - 8.5 | 6.5 - 8.5 | 6.5 - 9.0 | 7.6 ⁽¹⁾ | 7.2 | 7.5 | 7.2 | 8.6 ⁽¹⁾ | 9.0 | 8.9 | 8.8 |
| Appendix IV | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | 6.0 | 6.0 | 130 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Arsenic | ug/L | 10 | 10 | 10 | 10 | < 1.0 | 1.1 | 1.2 | 1.1 | 10 | 8.8 | 7.4 | 7.1 |
| Barium | ug/L | 2,000 | 2,000 | 2,000 | 820 | 170 | 220 | 680 | 270 | 72 | 73 | 120 | 150 |
| Beryllium | ug/L | 4 | 4.0 | 4.0 | 18 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | 5.0 | 5.0 | 3.5 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | 100 | 100 | 11 | 1.2 | 2.0 | 1.8 | 1.3 | 4.0 | 2.8 | 2.3 | 1.9 |
| Cobalt | ug/L | NC | 40 | 100 | 100 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 |
| Fluoride | ug/L | 4,000 | NC | NC | NC | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 4.0 | 4.0 | 39 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 170 | 350 | 0.20# | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 |
| Mercury | ug/L | 2 | 2.0 | 2.0 | 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 73 | 210 | 3,200 | 7.4 | 8.2 | 9.0 | 10 | 14 | 14 | 15 | 66 |
| Radium-226 | pCi/L | NC | NC | NC | NC | < 0.0742 | 0.110 | 0.352 | 0.179 | < 0.0795 | < 0.0785 | < 0.145 | 0.497 |
| Radium-228 | pCi/L | NC | NC | NC | NC | 0.589 | < 0.430 | 0.469 | 0.672 | < 0.386 | < 0.357 | < 0.400 | 0.456 |
| Radium-226/228 | pCi/L | 5 | NC | NC | NC | 0.654 | < 0.430 | 0.822 | 0.851 | < 0.386 | < 0.357 | < 0.400 | 0.953 |
| Selenium | ug/L | 50 | 50 | 50 | 5.0 | 12 | 12 | 39 | 33 | 35 | 16 | 11 | 140 |
| Thallium | ug/L | 2 | 2.0 | 2.0 | 3.7 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 |

Notes:

ug/L - micrograms per liter.

mg/L - milligrams per liter.

SU - standard units; pH is a field parameter.

pCi/L - picocuries per liter.

MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April 2012.

NC - no criteria.

* - Michigan Part 201 Generic Drinking Water Cleanup Criteria, December 30, 2013.

** - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR), April 2012.

[^] - Michigan Part 201 Groundwater Surface Water Interface (GSI) Criteria. Hardness-dependent criteria calculated using site-specific hardness of 180 mg CaCO₃/L as measured at surface water sample SW-01 collected on April 9, 2018 from the Pigeon River. Chromium GSI criterion based on hexavalent chromium per footnote {H}.

- If detected above 0.20 ug/L, further evaluation of low-level mercury may be necessary to evaluate the GSI pathway per Michigan Part 201 and EGLE policy and procedure 09-014 dated June 20, 2012.

BOLD value indicates an exceedance of one or more of the listed criteria.

RED value indicates an exceedance of the MCL.

All metals were analyzed as total unless otherwise specified.

(1) - Field meter reading not usable due to malfunctioning groundwater meter. Displayed value is lab pH reading from an unpreserved bottle.

Table 5
 Summary of Groundwater Protection Standard Exceedances – April 2019
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Constituent | Units | GWPS | JHC-MW-15001 | | JHC-MW-15002 | | JHC-MW-15003 | | JHC-MW-15005 | |
|-------------|-------|------|--------------|-----|--------------|-----|--------------|-----|--------------|-----|
| | | | LCL | UCL | LCL | UCL | LCL | UCL | LCL | UCL |
| Arsenic | ug/L | 10 | 0.82 | 7.5 | 33 | 130 | 8.8 | 29 | -- | -- |
| Cobalt | ug/L | 15 | -- | -- | -- | -- | 6 | 24 | -- | -- |
| Lithium | ug/L | 40 | -- | -- | 5.0 | 96 | -- | -- | 30 | 51 |
| Molybdenum | ug/L | 100 | -- | -- | -- | -- | -- | -- | 10 | 885 |
| Selenium | ug/L | 50 | -- | -- | -- | -- | -- | -- | 10 | 368 |
| Thallium | ug/L | 2 | -- | -- | -- | -- | -- | -- | 2 | 5.8 |
| | | | | | | | | | | |

Notes:

ug/L - micrograms per Liter.

-- - Not Applicable; well/parameter pair did not directly exceed the GWPS and was not included in further analysis.

GWPS - Groundwater Protection Standard as established in TRC's Technical Memorandum dated October 15, 2018.

UCL - Upper Confidence Limit ($\alpha = 0.01$) of the downgradient data set.

LCL - Lower Confidence Limit ($\alpha = 0.01$) of the downgradient data set.

Indicates a statistically significant exceedance of the GWPS. An exceedance occurs when the LCL is greater than the GWPS.

Table 6
 Summary of Groundwater Protection Standard Exceedances – October 2019
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Constituent | Units | GWPS | JHC-MW-15001 | | JHC-MW-15002 | | JHC-MW-15003 | | JHC-MW-15005 | | JHC-MW-18005 | |
|-------------|-------|------|--------------|-----|--------------|-----|--------------|-----|--------------|-----|--------------|-----|
| | | | LCL | UCL | LCL | UCL | LCL | UCL | LCL | UCL | LCL | UCL |
| Arsenic | ug/L | 10 | 0.87 | 8.1 | 37 | 100 | 6.4 | 27 | -- | -- | 6.2 | 11 |
| Cobalt | ug/L | 15 | -- | -- | -- | -- | 6 | 42 | -- | -- | -- | -- |
| Lithium | ug/L | 40 | -- | -- | 2.8 | 130 | -- | -- | 31 | 53 | -- | -- |
| Molybdenum | ug/L | 100 | -- | -- | -- | -- | 17 | 71 | 10 | 890 | -- | -- |
| Selenium | ug/L | 50 | -- | -- | -- | -- | -- | -- | 13 | 240 | 0.42 | 140 |
| Thallium | ug/L | 2 | -- | -- | -- | -- | -- | -- | 1.2 | 4 | -- | -- |

Notes:

ug/L - micrograms per Liter.

-- - Not Applicable; well/parameter pair did not directly exceed the GWPS and was not included in further analysis.

GWPS - Groundwater Protection Standard as established in TRC's Technical Memorandum dated October 15, 2018.

UCL - Upper Confidence Limit ($\alpha = 0.01$) of the downgradient data set.

LCL - Lower Confidence Limit ($\alpha = 0.01$) of the downgradient data set.

Indicates a statistically significant exceedance of the GWPS. An exceedance occurs when the LCL is greater than the GWPS.

Table 7
 Summary of Groundwater Sampling Results (Analytical): February 2019 - October 2019
 JH Campbell Nature and Extent Wells – RCRA CCR Monitoring Program
 West Olive, Michigan

| | | | | | | Sample Location: | MW-13 | MW-14 | MW-14D | | MW-14S | | | | |
|------------------------|-------|-------------|-----------------|---------------------|---------------------|------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|------------|
| | | | | | | Sample Date: | 4/24/2019 | 4/23/2019 | 4/23/2019 | 10/9/2019 | 2/15/2019 | 4/18/2019 | 4/23/2019 | 8/12/2019 | 10/10/2019 |
| Constituent | Unit | EPA MCL | MI Residential* | MI Non-Residential* | MI GSI [^] | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | 500 | 500 | 7,200 | < 50 | 66 | 180 | 170 | 27 | < 20 | < 50 | 20 | < 50 | |
| Calcium | mg/L | NC | NC | NC | 500 | 8.5 | 21 | 40 | 39 | -- | -- | 2.0 | -- | 2.1 | |
| Chloride | mg/L | 250** | 250 | 250 | 500 | < 2.0 | 9.5 | 20 | 21 | -- | -- | 2.3 | -- | < 2.0 | |
| Fluoride | ug/L | 4,000 | NC | NC | NC | < 1,000 | < 1,000 | < 1,000 | < 1,000 | -- | -- | < 1,000 | -- | < 1,000 | |
| Sulfate | mg/L | 250** | 250 | 250 | 500 | 5.3 | 17 | 28 | 32 | -- | -- | 4.0 | -- | 3.6 | |
| Total Dissolved Solids | mg/L | 500** | 500 | 500 | 500 | < 50 | 130 | 200 | 220 | -- | -- | < 50 | -- | 61 | |
| pH, Field | SU | 6.5 - 8.5** | 6.5 - 8.5 | 6.5 - 8.5 | 6.5 - 9.0 | 6.7 | 6.8 | 7.9 | 8.1 | 5.8 | 6.1 | 5.5 | 5.6 | 5.7 | |
| Appendix IV | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | 6.0 | 6.0 | 130 | 1.1 | < 1.0 | < 1.0 | < 1.0 | < 1 | < 1 | < 1.0 | < 1 | < 1.0 | |
| Arsenic | ug/L | 10 | 10 | 10 | 10 | < 1.0 | < 1.0 | 1.6 | 1.3 | < 1 | < 1 | < 1.0 | < 1 | < 1.0 | |
| Barium | ug/L | 2,000 | 2,000 | 2,000 | 820 | 8.7 | 16 | 46 | 50 | -- | -- | 8.3 | -- | 9.5 | |
| Beryllium | ug/L | 4 | 4.0 | 4.0 | 18 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | -- | -- | < 1.0 | -- | < 1.0 | |
| Cadmium | ug/L | 5 | 5.0 | 5.0 | 3.5 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | -- | -- | < 0.20 | -- | < 0.20 | |
| Chromium | ug/L | 100 | 100 | 100 | 11 | 2.3 | < 1.0 | < 1.0 | < 1.0 | < 1 | < 1 | < 1.0 | < 1 | < 1.0 | |
| Cobalt | ug/L | NC | 40 | 100 | 100 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | -- | -- | < 6.0 | -- | < 6.0 | |
| Fluoride | ug/L | 4,000 | NC | NC | NC | < 1,000 | < 1,000 | < 1,000 | < 1,000 | -- | -- | < 1,000 | -- | < 1,000 | |
| Lead | ug/L | NC | 4.0 | 4.0 | 39 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | -- | -- | < 1.0 | -- | < 1.0 | |
| Lithium | ug/L | NC | 170 | 350 | 440 | 12 | < 10 | 20 | 18 | < 10 | < 10 | < 10 | < 10 | < 10 | |
| Mercury | ug/L | 2 | 2.0 | 2.0 | 0.20# | < 0.20 | < 0.20 | < 0.20 | < 0.20 | -- | -- | < 0.20 | -- | < 0.20 | |
| Molybdenum | ug/L | NC | 73 | 210 | 3,200 | < 5.0 | < 5.0 | 20 | 21 | < 5 | < 5 | < 5.0 | < 5 | < 5.0 | |
| Radium-226 | pCi/L | NC | NC | NC | NC | < 0.0808 | < 0.0845 | < 0.110 | 0.193 | -- | -- | < 0.0790 | -- | < 0.145 | |
| Radium-228 | pCi/L | NC | NC | NC | NC | < 0.373 | < 0.352 | < 0.347 | < 0.713 | -- | -- | < 0.332 | -- | < 0.445 | |
| Radium-226/228 | pCi/L | 5 | NC | NC | NC | < 0.373 | < 0.352 | < 0.347 | 0.749 | -- | -- | < 0.332 | -- | 0.501 | |
| Selenium | ug/L | 50 | 50 | 50 | 5.0 | 2.6 | < 1.0 | < 1.0 | < 1.0 | < 1 | < 1 | < 1.0 | < 1 | < 1.0 | |
| Thallium | ug/L | 2 | 2.0 | 2.0 | 3.7 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | -- | -- | < 2.0 | -- | < 2.0 | |

Notes:

ug/L - micrograms per liter.

mg/L - milligrams per liter.

SU - standard units; pH is a field parameter.

pCi/L - picocuries per liter.

MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April 2012.

NC - no criteria.

-- - not analyzed.

* - Michigan Part 201 Generic Drinking Water Cleanup Criteria, December 30, 2013.

** - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR), April 2012.

[^] - Michigan Part 201 Groundwater Surface Water Interface (GSI) Criteria. Hardness-dependent criteria calculated using site-specific hardness of 180 mg CaCO₃/L as measured at surface water sample SW-01 collected on April 9, 2018 from the Pigeon River. Chromium GSI criterion based on hexavalent chromium per footnote {H}.

- If detected above 0.20 ug/L, further evaluation of low-level mercury may be necessary to evaluate the GSI pathway per Michigan Part 201 and EGLE policy and procedure 09-014 dated June 20, 2012.

BOLD value indicates an exceedance of one or more of the listed criteria.

RED value indicates an exceedance of the MCL.

All metals were analyzed as total unless otherwise specified.

Table 7
 Summary of Groundwater Sampling Results (Analytical): February 2019 - October 2019
 JH Campbell Nature and Extent Wells – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | PZ-23 | PZ-23D | | | PZ-23S | | | PZ-24 | | |
|------------------------|-------|-------------|-----------------|---------------------|---------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| Sample Date: | | | | | | 4/23/2019 | 4/23/2019 | 10/9/2019 | 2/15/2019 | 4/17/2019 | 4/23/2019 | 8/12/2019 | 10/9/2019 | 4/24/2019 | 10/9/2019 |
| Constituent | Unit | EPA MCL | MI Residential* | MI Non-Residential* | MI GSI [^] | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | 500 | 500 | 7,200 | 220 | 820 | 800 | 37 | 34 | < 50 | 23 | < 50 | 170 | 200 |
| Calcium | mg/L | NC | NC | NC | 500 | 39 | 24 | 28 | -- | -- | 8.6 | -- | 6.4 | 27 | 35 |
| Chloride | mg/L | 250** | 250 | 250 | 500 | 13 | 22 | 23 | -- | -- | < 2.0 | -- | < 2.0 | 18 | 14 |
| Fluoride | ug/L | 4,000 | NC | NC | NC | < 1,000 | < 1,000 | < 1,000 | -- | -- | < 1,000 | -- | < 1,000 | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250** | 250 | 250 | 500 | 49 | 52 | 52 | -- | -- | 5.4 | -- | 3.4 | < 2.0 | 48 |
| Total Dissolved Solids | mg/L | 500** | 500 | 500 | 500 | 200 | 130 | 150 | -- | -- | < 50 | -- | 480 | 170 | 250 |
| pH, Field | SU | 6.5 - 8.5** | 6.5 - 8.5 | 6.5 - 8.5 | 6.5 - 9.0 | 7.4 | 8.6 | 8.7 | 7.0 | 7.1 | 6.9 | 6.7 | 6.6 | 6.7 | 7.0 |
| Appendix IV | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | 6.0 | 6.0 | 130 | < 1.0 | < 1.0 | < 1.0 | < 1 | < 1 | < 1.0 | < 1 | < 1.0 | < 1.0 | < 1.0 |
| Arsenic | ug/L | 10 | 10 | 10 | 10 | < 1.0 | < 1.0 | < 1.0 | < 1 | < 1 | < 1.0 | < 1 | < 1.0 | < 1.0 | < 1.0 |
| Barium | ug/L | 2,000 | 2,000 | 2,000 | 820 | 14 | 25 | 27 | -- | -- | < 5.0 | -- | < 5.0 | 20 | 27 |
| Beryllium | ug/L | 4 | 4.0 | 4.0 | 18 | < 1.0 | < 1.0 | < 1.0 | -- | -- | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | 5.0 | 5.0 | 3.5 | < 0.20 | < 0.20 | < 0.20 | -- | -- | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | 100 | 100 | 11 | < 1.0 | < 1.0 | < 1.0 | < 1 | < 1 | < 1.0 | < 1 | < 1.0 | < 1.0 | 1.2 |
| Cobalt | ug/L | NC | 40 | 100 | 100 | < 6.0 | < 6.0 | < 6.0 | -- | -- | < 6.0 | -- | < 6.0 | < 6.0 | < 6.0 |
| Fluoride | ug/L | 4,000 | NC | NC | NC | < 1,000 | < 1,000 | < 1,000 | -- | -- | < 1,000 | -- | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 4.0 | 4.0 | 39 | < 1.0 | < 1.0 | < 1.0 | -- | -- | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 170 | 350 | 440 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 |
| Mercury | ug/L | 2 | 2.0 | 2.0 | 0.20# | < 0.20 | < 0.20 | < 0.20 | -- | -- | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 73 | 210 | 3,200 | 10 | 12 | 12 | 8 | 7 | 6.5 | 11 | 6.0 | 13 | 11 |
| Radium-226 | pCi/L | NC | NC | NC | NC | < 0.102 | < 0.110 | < 0.116 | -- | -- | 0.119 | -- | 0.136 | < 0.0841 | 0.260 |
| Radium-228 | pCi/L | NC | NC | NC | NC | < 0.373 | < 0.392 | < 0.743 | -- | -- | 0.383 | -- | < 0.637 | 0.483 | < 0.679 |
| Radium-226/228 | pCi/L | 5 | NC | NC | NC | < 0.373 | < 0.392 | < 0.743 | -- | -- | 0.502 | -- | < 0.637 | 0.494 | < 0.679 |
| Selenium | ug/L | 50 | 50 | 50 | 5.0 | 3.6 | < 1.0 | < 1.0 | 1 | < 1 | < 1.0 | < 1 | < 1.0 | < 1.0 | < 1.0 |
| Thallium | ug/L | 2 | 2.0 | 2.0 | 3.7 | < 2.0 | < 2.0 | < 2.0 | -- | -- | < 2.0 | -- | < 2.0 | < 2.0 | < 2.0 |

Notes:
 ug/L - micrograms per liter.
 mg/L - milligrams per liter.
 SU - standard units; pH is a field parameter.
 pCi/L - picocuries per liter.
 MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April 2012.
 NC - no criteria.
 -- - not analyzed.
 * - Michigan Part 201 Generic Drinking Water Cleanup Criteria, December 30, 2013.
 ** - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR), April 2012.
[^] - Michigan Part 201 Groundwater Surface Water Interface (GSI) Criteria. Hardness-dependent criteria calculated using site-specific hardness of 180 mg CaCO3/L as measured at surface water sample SW-01 collected on April 9, 2018 from the Pigeon River. Chromium GSI criterion based on hexavalent chromium per footnote {H}.
 # - If detected above 0.20 ug/L, further evaluation of low-level mercury may be necessary to evaluate the GSI pathway per Michigan Part 201 and EGLE policy and procedure 09-014 dated June 20, 2012.
BOLD value indicates an exceedance of one or more of the listed criteria.
RED value indicates an exceedance of the MCL.
 All metals were analyzed as total unless otherwise specified.

Table 7
 Summary of Groundwater Sampling Results (Analytical): February 2019 - October 2019
 JH Campbell Nature and Extent Wells – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | PZ-24D | | PZ-24S | | | | PZ-40 | | |
|------------------------|-------|-------------|-----------------|---------------------|---------------------|-----------|-------------|-----------|-----------|-----------|-----------|------------|-----------|-----------|
| Sample Date: | | | | | | 4/24/2019 | 10/9/2019 | 2/15/2019 | 4/18/2019 | 4/24/2019 | 8/12/2019 | 10/10/2019 | 4/24/2019 | 10/9/2019 |
| Constituent | Unit | EPA MCL | MI Residential* | MI Non-Residential* | MI GSI [^] | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | |
| Boron | ug/L | NC | 500 | 500 | 7,200 | 250 | 240 | 45 | 31 | < 50 | 32 | < 50 | 170 | 190 |
| Calcium | mg/L | NC | NC | NC | 500 | 40 | 40 | -- | -- | 4.0 | -- | 2.9 | 16 | 15 |
| Chloride | mg/L | 250** | 250 | 250 | 500 | 18 | 18 | -- | -- | < 2.0 | -- | < 2.0 | 9.3 | 8.4 |
| Fluoride | ug/L | 4,000 | NC | NC | NC | < 1,000 | < 1,000 | -- | -- | < 1,000 | -- | < 1,000 | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250** | 250 | 250 | 500 | 25 | 24 | -- | -- | 4.5 | -- | 4.0 | 19 | 21 |
| Total Dissolved Solids | mg/L | 500** | 500 | 500 | 500 | 200 | 180 | -- | -- | < 50 | -- | < 50 | 93 | 86 |
| pH, Field | SU | 6.5 - 8.5** | 6.5 - 8.5 | 6.5 - 8.5 | 6.5 - 9.0 | 7.7 | 7.5 | 5.5 | 5.9 | 5.5 | 5.6 | 5.5 | 6.4 | 6.5 |
| Appendix IV | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | 6.0 | 6.0 | 130 | < 1.0 | < 1.0 | < 1 | < 1 | < 1.0 | < 1 | < 1.0 | < 1.0 | < 1.0 |
| Arsenic | ug/L | 10 | 10 | 10 | 10 | 8.7 | 5.4 | < 1 | < 1 | < 1.0 | 1 | 1.1 | < 1.0 | < 1.0 |
| Barium | ug/L | 2,000 | 2,000 | 2,000 | 820 | 61 | 63 | -- | -- | 23 | -- | 34 | 17 | 18 |
| Beryllium | ug/L | 4 | 4.0 | 4.0 | 18 | < 1.0 | < 1.0 | -- | -- | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | 5.0 | 5.0 | 3.5 | < 0.20 | < 0.20 | -- | -- | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | 100 | 100 | 11 | < 1.0 | < 1.0 | 1 | 1 | 1.5 | 2 | 1.6 | < 1.0 | 1.3 |
| Cobalt | ug/L | NC | 40 | 100 | 100 | < 6.0 | < 6.0 | -- | -- | < 6.0 | -- | < 6.0 | < 6.0 | < 6.0 |
| Fluoride | ug/L | 4,000 | NC | NC | NC | < 1,000 | < 1,000 | -- | -- | < 1,000 | -- | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 4.0 | 4.0 | 39 | < 1.0 | < 1.0 | -- | -- | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 170 | 350 | 440 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 |
| Mercury | ug/L | 2 | 2.0 | 2.0 | 0.20# | < 0.20 | 0.21 | -- | -- | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 73 | 210 | 3,200 | 27 | 22 | < 5 | < 5 | < 5.0 | < 5 | < 5.0 | 11 | 6.4 |
| Radium-226 | pCi/L | NC | NC | NC | NC | < 0.0842 | 0.144 | -- | -- | < 0.0852 | -- | 0.248 | < 0.0984 | 0.222 |
| Radium-228 | pCi/L | NC | NC | NC | NC | < 0.359 | < 0.668 | -- | -- | < 0.357 | -- | 0.511 | < 0.410 | < 0.587 |
| Radium-226/228 | pCi/L | 5 | NC | NC | NC | < 0.359 | < 0.668 | -- | -- | < 0.357 | -- | 0.759 | < 0.410 | < 0.587 |
| Selenium | ug/L | 50 | 50 | 50 | 5.0 | < 1.0 | < 1.0 | < 1 | < 1 | < 1.0 | < 1 | < 1.0 | < 1.0 | < 1.0 |
| Thallium | ug/L | 2 | 2.0 | 2.0 | 3.7 | < 2.0 | < 2.0 | -- | -- | < 2.0 | -- | < 2.0 | < 2.0 | < 2.0 |

Notes:

ug/L - micrograms per liter.

mg/L - milligrams per liter.

SU - standard units; pH is a field parameter.

pCi/L - picocuries per liter.

MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April 2012.

NC - no criteria.

-- - not analyzed.

* - Michigan Part 201 Generic Drinking Water Cleanup Criteria, December 30, 2013.

** - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR), April 2012.

[^] - Michigan Part 201 Groundwater Surface Water Interface (GSI) Criteria. Hardness-dependent criteria calculated using site-specific hardness of 180 mg CaCO₃/L as measured at surface water sample SW-01 collected on April 9, 2018 from the Pigeon River. Chromium GSI criterion based on hexavalent chromium per footnote {H}.

- If detected above 0.20 ug/L, further evaluation of low-level mercury may be necessary to evaluate the GSI pathway per Michigan Part 201 and EGLE policy and procedure 09-014 dated June 20, 2012.

BOLD value indicates an exceedance of one or more of the listed criteria.

RED value indicates an exceedance of the MCL.

All metals were analyzed as total unless otherwise specified.

Table 7
 Summary of Groundwater Sampling Results (Analytical): February 2019 - October 2019
 JH Campbell Nature and Extent Wells – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | PZ-40S | | | | |
|------------------------|-------|--------------------|------------------|---------------------|------------------|---------------|------------|------------|------------|------------|
| Sample Date: | | | | | | 2/15/2019 | 4/18/2019 | 4/24/2019 | 8/12/2019 | 10/10/2019 |
| Constituent | Unit | EPA MCL | MI Residential* | MI Non-Residential* | MI GSI^ | | | | | |
| Appendix III | | | | | | | | | | |
| Boron | ug/L | NC | 500 | 500 | 7,200 | < 20 | < 20 | < 50 | < 20 | < 50 |
| Calcium | mg/L | NC | NC | NC | 500 | -- | -- | 2.1 | -- | 1.5 |
| Chloride | mg/L | 250** | 250 | 250 | 500 | -- | -- | < 2.0 | -- | < 2.0 |
| Fluoride | ug/L | 4,000 | NC | NC | NC | -- | -- | < 1,000 | -- | < 1,000 |
| Sulfate | mg/L | 250** | 250 | 250 | 500 | -- | -- | 4.4 | -- | 3.4 |
| Total Dissolved Solids | mg/L | 500** | 500 | 500 | 500 | -- | -- | < 50 | -- | < 50 |
| pH, Field | SU | 6.5 - 8.5** | 6.5 - 8.5 | 6.5 - 8.5 | 6.5 - 9.0 | 5.1 | 5.2 | 4.9 | 5.0 | 5.1 |
| Appendix IV | | | | | | | | | | |
| Antimony | ug/L | 6 | 6.0 | 6.0 | 130 | < 1 | < 1 | < 1.0 | < 1 | < 1.0 |
| Arsenic | ug/L | 10 | 10 | 10 | 10 | < 1 | < 1 | < 1.0 | < 1 | < 1.0 |
| Barium | ug/L | 2,000 | 2,000 | 2,000 | 820 | -- | -- | 23 | -- | 23 |
| Beryllium | ug/L | 4 | 4.0 | 4.0 | 18 | -- | -- | < 1.0 | -- | < 1.0 |
| Cadmium | ug/L | 5 | 5.0 | 5.0 | 3.5 | -- | -- | < 0.20 | -- | < 0.20 |
| Chromium | ug/L | 100 | 100 | 100 | 11 | 2 | 1 | 1.7 | < 1 | 1.3 |
| Cobalt | ug/L | NC | 40 | 100 | 100 | -- | -- | < 6.0 | -- | < 6.0 |
| Fluoride | ug/L | 4,000 | NC | NC | NC | -- | -- | < 1,000 | -- | < 1,000 |
| Lead | ug/L | NC | 4.0 | 4.0 | 39 | -- | -- | < 1.0 | -- | < 1.0 |
| Lithium | ug/L | NC | 170 | 350 | 440 | < 10 | < 10 | < 10 | < 10 | < 10 |
| Mercury | ug/L | 2 | 2.0 | 2.0 | 0.20# | -- | -- | < 0.20 | -- | < 0.20 |
| Molybdenum | ug/L | NC | 73 | 210 | 3,200 | < 5 | < 5 | < 5.0 | < 5 | < 5.0 |
| Radium-226 | pCi/L | NC | NC | NC | NC | -- | -- | < 0.100 | -- | 0.178 |
| Radium-228 | pCi/L | NC | NC | NC | NC | -- | -- | < 0.409 | -- | < 0.473 |
| Radium-226/228 | pCi/L | 5 | NC | NC | NC | -- | -- | < 0.409 | -- | < 0.473 |
| Selenium | ug/L | 50 | 50 | 50 | 5.0 | < 1 | < 1 | < 1.0 | < 1 | < 1.0 |
| Thallium | ug/L | 2 | 2.0 | 2.0 | 3.7 | -- | -- | < 2.0 | -- | < 2.0 |

Notes:

ug/L - micrograms per liter.

mg/L - milligrams per liter.

SU - standard units; pH is a field parameter.

pCi/L - picocuries per liter.

MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April 2012.

NC - no criteria.

-- not analyzed.

* - Michigan Part 201 Generic Drinking Water Cleanup Criteria, December 30, 2013.

** - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR), April 2012.

^ - Michigan Part 201 Groundwater Surface Water Interface (GSI) Criteria. Hardness-dependent criteria calculated using site-specific hardness of 180 mg CaCO3/L as measured at surface water sample SW-01 collected on April 9, 2018 from the Pigeon River. Chromium GSI criterion based on hexavalent chromium per footnote {H}.


- If detected above 0.20 ug/L, further evaluation of low-level mercury may be necessary to evaluate the GSI pathway per Michigan Part 201 and EGLE policy and procedure 09-014 dated June 20, 2012.

BOLD value indicates an exceedance of one or more of the listed criteria.

RED value indicates an exceedance of the MCL.

All metals were analyzed as total unless otherwise specified.

Figures



BASE MAP FROM USGS 7.5 MINUTE TOPOGRAPHIC QUADRANGLE SERIES.



1540 Eisenhower Place
Ann Arbor, MI 48108-3284
Phone: 734.971.7080
www.trccompanies.com

PROJECT:


**CONSUMERS ENERGY COMPANY
JH CAMPBELL POWER PLANT
WEST OLIVE, MICHIGAN**

TITLE:

SITE LOCATION MAP

| | |
|--------------|--------------------|
| DRAWN BY: | S. MAJOR |
| CHECKED BY: | B. YELEN |
| APPROVED BY: | S. HOLMSTROM |
| DATE: | JANUARY 2020 |
| PROJ. NO.: | 322174 |
| FILE: | 322174-001-022.mxd |

FIGURE 1



LEGEND

- BACKGROUND MONITORING WELL
- DOWNGRADIENT BOTTOM ASH POND 1/2 N/S MONITORING WELL
- DOWNGRADIENT BOTTOM ASH POND 3 N/S MONITORING WELL
- DOWNGRADIENT LANDFILL MONITORING WELL
- DOWNGRADIENT POND A MONITORING WELL
- MONITORING WELL (STATIC WATER LEVEL ONLY)
- DECOMMISSIONED MONITORING WELL
- NEW DOWNGRADIENT BOTTOM ASH POND 1/2 N/S MONITORING WELL (2018)
- NEW DOWNGRADIENT BOTTOM ASH POND 3 N/S MONITORING WELL (2018)
- NATURE AND EXTENT WELL

- NOTES**
1. BASE MAP IMAGERY FROM GOOGLE EARTH PRO, 2018.
 2. WELL LOCATIONS BASED ON SURVEY DATA THROUGH 12/07/2018.
 3. MONITORING WELL DECOMMISSIONED NOVEMBER 13, 2017.
 4. MONITORING WELL DECOMMISSIONED JUNE 14, 2018.
 5. MONITORING WELL DECOMMISSIONED OCTOBER 10, 2018.
 6. JHC-MW-1800X MONITORING WELLS INSTALLED IN DECEMBER 2018.
 7. MONITORING WELL DECOMMISSIONED JUNE 24, 2019.
 8. JHC-MW-15008R AND TW-19-XX MONITORING WELLS INSTALLED IN JUNE 2019.

0 700 1,400
Feet

1" = 700'
1:8,400

PROJECT: **CONSUMERS ENERGY COMPANY
JH CAMPBELL POWER PLANT
WEST OLIVE, MICHIGAN**

TITLE: **SITE PLAN
WITH CCR MONITORING WELL LOCATIONS**


DRAWN BY: S. MAJOR PROJ NO.: 322174-001
CHECKED BY: B. YELEN
APPROVED BY: S. HOLMSTROM
DATE: JANUARY 2020

FIGURE 2

TRC

1540 Eisenhower Place
Ann Arbor, MI 48108-3284
Phone: 734.971.7080
www.trccompanies.com

FILE NO.: 322174-001-030.mxd




LEGEND


- BACKGROUND MONITORING WELL
- DECOMMISSIONED MONITORING WELL
- DOWNGRADEMENT BOTTOM ASH POND 1/2 N/S MONITORING WELL
- DOWNGRADEMENT BOTTOM ASH POND 3 N/S MONITORING WELL
- DOWNGRADEMENT LANDFILL MONITORING WELL
- MONITORING WELL (STATIC WATER LEVEL ONLY)
- POND A MONITORING WELL
- NEW DOWNGRADEMENT BOTTOM ASH POND 1/2 N/S MONITORING WELL (2018)
- NEW DOWNGRADEMENT BOTTOM ASH POND 3 N/S MONITORING WELL (2018)
- NATURE AND EXTENT WELLS
- GROUNDWATER ELEVATION CONTOUR (2' INTERVAL, DASHED WHERE INFERRED)
- (600.97) GROUNDWATER ELEVATION (FEET)

NOTES

1. BASE MAP IMAGERY FROM GOOGLE EARTH PRO, 2018.
2. WELL LOCATIONS BASED ON SURVEY DATA THROUGH 12/07/2018.
3. MONITORING WELL DECOMMISSIONED NOVEMBER 13, 2017.
4. MONITORING WELL DECOMMISSIONED JUNE 14, 2018.
5. MONITORING WELL DECOMMISSIONED OCTOBER 10, 2018.
6. JHC-MW-1800X MONITORING WELLS INSTALLED IN DECEMBER 2018.
7. GROUNDWATER ELEVATIONS DISPLAYED IN FEET RELATIVE TO THE NORTH AMERICAN VERTICAL DATUM OF 1988.




| | | | |
|--------------|--------------|--|------------|
| PROJECT: | | CONSUMERS ENERGY COMPANY JH CAMPBELL POWER PLANT WEST OLIVE, MICHIGAN | |
| TITLE: | | GROUNDWATER CONTOUR MAP APRIL 2019 | |
| DRAWN BY: | S. MAJOR | PROJ NO.: | 322174-001 |
| CHECKED BY: | B. YELEN | FIGURE 3 | |
| APPROVED BY: | S. HOLMSTROM | | |
| DATE: | JANUARY 2020 | | |
| | | 1540 Eisenhower Place Ann Arbor, MI 48108-3284 Phone: 734.971.7080 www.trccompanies.com | |
| FILE NO.: | | 322174-001-024.mxd | |



LEGEND

- BACKGROUND MONITORING WELL
- DOWNGRAIDENT BOTTOM ASH POND 1/2 N/S MONITORING WELL
- DOWNGRAIDENT BOTTOM ASH POND 3 N/S MONITORING WELL
- DOWNGRAIDENT LANDFILL MONITORING WELL
- DOWNGRAIDENT POND A MONITORING WELL
- MONITORING WELL (STATIC WATER LEVEL ONLY)
- DECOMMISSIONED MONITORING WELL
- NEW DOWNGRAIDENT BOTTOM ASH POND 1/2 N/S MONITORING WELL (2018)
- NEW DOWNGRAIDENT BOTTOM ASH POND 3 N/S MONITORING WELL (2018)
- NATURE AND EXTENT WELL
- GROUNDWATER ELEVATION CONTOUR (2' INTERVAL, DASHED WHERE INFERRED)
- (600.97) GROUNDWATER ELEVATION (FEET) SHALLOW WELLS

- ### NOTES
1. BASE MAP IMAGERY FROM GOOGLE EARTH PRO, 2018.
 2. WELL LOCATIONS BASED ON SURVEY DATA THROUGH 12/07/2018.
 3. MONITORING WELL DECOMMISSIONED NOVEMBER 13, 2017.
 4. MONITORING WELL DECOMMISSIONED JUNE 14, 2018.
 5. MONITORING WELL DECOMMISSIONED OCTOBER 10, 2018.
 6. JHC-MW-1800X MONITORING WELLS INSTALLED IN DECEMBER 2018.
 7. MONITORING WELL DECOMMISSIONED JUNE 24, 2019.
 8. JHC-MW-15008R AND TW-19-XX MONITORING WELLS INSTALLED IN JUNE 2019.



| | | | |
|--------------|--------------|--|------------|
| PROJECT: | | CONSUMERS ENERGY COMPANY JH CAMPBELL POWER PLANT WEST OLIVE, MICHIGAN | |
| TITLE: | | GROUNDWATER CONTOUR MAP OCTOBER 2019 | |
| DRAWN BY: | M. VAPHIADIS | PROJ NO.: | 322174-001 |
| CHECKED BY: | B. YELEN | FIGURE 4 | |
| APPROVED BY: | S. HOLMSTROM | | |
| DATE: | JANUARY 2020 | | |
| FILE NO.: | | 322174-001-029.mxd | |


Appendix A

Groundwater Monitoring System Certification

A CMS Energy Company

Date: July 12, 2019

To: Operating Record


From: Harold D. Register, Jr., P.E. 

RE: Demonstration for 60-Day Extension for Assessment of Corrective Measures
Professional Engineer Certification
JH Campbell Unit 1&2 Bottom Ash Pond and JH Campbell Pond A

Professional Engineer Certification Statement [§257.96(a)]

Consumers Energy has determined that the analysis of the effectiveness of potential corrective measures in meeting all of the requirements and objectives of a selected remedy described in §257.97 cannot be achieved within the 90-day timeline to complete the Assessment of Corrective Measures for JH Campbell Unit 1&2 Bottom Ash Pond and JH Campbell Pond A due to site-specific conditions that are changing based on initiating closure activities. Notification was made September 7, 2018 and September 17, 2018 for JH Campbell Unit 1&2 Bottom Ash Pond and JH Campbell Pond A, respectively, that closure activities had been initiated. Groundwater monitoring data collected to date indicates changing conditions that can influence factors that must be considered in the assessment, including source evaluation, plume delineation, groundwater assessment, and source control. The final published rule allows for a single 60 day extension based on site-specific conditions or circumstances.

I hereby attest that, having reviewed the detection and assessment monitoring documentation and being familiar with the provisions of Title 40 of the Code of Federal Regulations §257.96, that the demonstration justifying a 60-day time extension to the 90-day completion period of the Assessment of Corrective Measures is accurate for JH Campbell Unit 1&2 Bottom Ash Pond and JH Campbell Pond A in accordance with the requirements of §257.96(a). This will now set the deadline for completing the Assessment of Corrective Measures for September 11, 2019.



Signature

July 12, 2019

Date of Certification

Harold D. Register, Jr., P.E.

Name

6201056266

Professional Engineer Certification Number



07/12/2019

Appendix B

Monitoring Well Installation & Decommissioning Logs



WELL CONSTRUCTION LOG

WELL NO. JHC MW-15008R

| | | | | |
|--|--|--|---|--|
| Facility/Project Name: Consumers Energy Company: JH Campbell | | Date Drilling Started: 6/24/19 | Date Drilling Completed: 6/25/19 | Project Number: 322174.0002 |
| Drilling Firm: Stearns Drilling | Drilling Method: Direct Push/HSA | Surface Elev. (ft) 632.3 | TOC Elevation (ft) 634.67 | Total Depth (ft bgs) 45.0 |
| Boring Location: Southeast of Pond A. N: 517558.9 E: 12636031.7 | | Personnel Logged By - Paula Lancaster Driller - Roger Christiansen | | Drilling Equipment: Geoprobe 7822 DT |
| Civil Town/City/or Village: West Olive | County: Ottawa | State: MI | Water Level Observations: While Drilling: Date/Time <u>6/24/19 14:50</u> ▾ Depth (ft bgs) <u>38.8</u> After Drilling: Date/Time <u>6/25/19 08:45</u> ▾ Depth (ft bgs) <u>38.8</u> | |

| SAMPLE | NUMBER AND TYPE | RECOVERY (%) | BLOW COUNTS | DEPTH IN FEET | LITHOLOGIC DESCRIPTION | USCS | GRAPHIC LOG | WELL DIAGRAM | COMMENTS |
|--------|-----------------|--------------|-------------|---------------|--|------|-------------|--------------|--|
| | | | | | | | | | |
| | 1 | GP | 66 | | FILL mostly ash and gravel. SAND mostly fine sand, light yellowish brown (10YR 6/4), dry, loose. | | | | Soil boring reamed to a depth of 47 feet below ground surface using 4.25 inch hollow stem augers prior to well installation. |
| | 2 | GP | 80 | 5 | Changes to some gravel at 3.5 feet below ground surface. Changes to no gravel at 3.7 feet below ground surface. Changes to yellowish brown (10YR 5/4), moist at 3.8 feet below ground surface. | | | | |
| | 3 | GP | 100 | 10 | Changes to few to little gravel, brown (10YR 5/3) at 7.5 feet below ground surface. | | | | |
| | 4 | GP | 100 | 15 | Changes to no gravel, yellowish brown (10YR 5/6) at 10.0 feet below ground surface. | SP | | | |
| | 5 | GP | 70 | 20 | | | | | |

SOIL BORING-WELL CONSTRUCTION LOG 322174.0002.0000.GPJ TRC_CORP_INCHES.GDT 10/11/19

Signature: Firm: TRC 1540 Eisenhower Place Ann Arbor, Michigan 734-971-7080 Fax 734-971-9022

Checked By: Jennifer Reed



WELL CONSTRUCTION LOG

WELL NO. JHC MW-15008R


SOIL BORING WELL CONSTRUCTION LOG 322174.0002.0000.GPJ TRC CORP. INCHES.GDT 10/11/19

| SAMPLE | | BLOW COUNTS | DEPTH IN FEET | LITHOLOGIC DESCRIPTION | USCS | GRAPHIC LOG | WELL DIAGRAM | COMMENTS |
|-----------------|--------------|-------------|---------------|--|------|-------------|--------------|----------|
| NUMBER AND TYPE | RECOVERY (%) | | | | | | | |
| 6 | 73 | | | Changes to fine to medium sand, dark yellowish brown (10YR 6/6) at 27.0 feet below ground surface. Changes to brown (10YR 4/3) with staining at 28.25 feet below ground surface. Changes to medium sand, few coarse sand, dark yellowish brown (10YR 4/6) at 28.6 feet below ground surface. | SP | | | |
| 7 | 73 | | 30 | SAND mostly medium sand, little coarse sand, few fine sand, little fine gravel, dark yellowish brown (10YR 4/6), dry, loose. | | | | |
| | | | 32.5 | Changes to mostly medium sand, few fine sand, few coarse sand, trace fine gravel at 32.5 feet below ground surface. | | | | |
| | | | 34.0 | Changes to mostly fine sand, trace medium to coarse sand, light yellowish brown (10YR 6/4) at 34.0 feet below ground surface. | | | | |
| 8 | 65 | | | | | | | |
| | | | 39.25 | Changes to mostly medium sand, trace to few coarse sand, trace fine gravel, wet at 39.25 feet below ground surface. | | | | |
| | | | 39.5 | Changes to mostly fine to medium sand at 39.5 feet below ground surface. | | | | |
| 9 | 65 | | | Changes to mostly medium sand, trace coarse sand, trace fine sand, dark brown (10YR 4/6), loose at 40.0 feet below ground surface. | SW | | | |
| 10 | 0 | | 45 | Soil boring blind drilled from 45.0 to 47.0 feet below ground surface using hollow stem augers. | | | | |
| | | | 47.0 | End of boring at 47.0 feet below ground surface. | | | | |
| | | | 50 | | | | | |
| | | | 55 | | | | | |



WELL CONSTRUCTION DIAGRAM

| | |
|--|---|
| PROJ. NAME: CEC JHC RAP Area 2019 Work | WELL ID: JHC MW-15008R |
| PROJ. NO: 322174.0002 | DATE INSTALLED: 6/25/2019 INSTALLED BY: Stearns/P. Lancaster CHECKED BY: B. Yelen |



| CASING AND SCREEN DETAILS | |
|---------------------------|---|
| TYPE OF RISER: | <u>2-INCH PVC</u> |
| PIPE SCHEDULE: | <u>40</u> |
| PIPE JOINTS: | <u>THREADED O-RINGS</u> |
| SCREEN TYPE: | <u>2-INCH PVC</u> |
| SCR. SLOT SIZE: | <u>0.01-INCH</u> |
| BOREHOLE DIAMETER: | <u>8</u> IN. FROM <u>0</u> TO <u>47</u> FT. <u> </u> IN. FROM <u> </u> TO <u> </u> FT. |
| SURF. CASING DIAMETER: | <u>4</u> IN. FROM <u>0</u> TO <u>2.5</u> FT. <u> </u> IN. FROM <u> </u> TO <u> </u> FT. |

| WELL DEVELOPMENT | |
|--|------------------------|
| DEVELOPMENT METHOD: | <u>SURGE AND PUMP</u> |
| TIME DEVELOPING: | <u>1</u> HOURS |
| WATER REMOVED: | <u>100</u> GALLONS |
| WATER ADDED: | <u>5</u> GALLONS |
| WATER CLARITY BEFORE / AFTER DEVELOPMENT | |
| CLARITY BEFORE: | <u>Turbid</u> |
| COLOR BEFORE: | <u>yellowish brown</u> |
| CLARITY AFTER: | <u>None</u> |
| COLOR AFTER: | <u>None</u> |
| ODOR (IF PRESENT): | <u>None</u> |

| WATER LEVEL SUMMARY | | | | |
|------------------------|-------|-------|-----------|------|
| MEASUREMENT (FEET) | | | DATE | TIME |
| DTB BEFORE DEVELOPING: | 45.00 | T/PVC | 6/25/2019 | 8:45 |
| DTB AFTER DEVELOPING: | 45.00 | T/PVC | 6/26/2019 | 9:35 |
| SWL BEFORE DEVELOPING: | 38.80 | T/PVC | 6/25/2019 | 8:45 |
| SWL AFTER DEVELOPING: | 38.70 | T/PVC | 6/26/2019 | 9:35 |
| OTHER SWL: | | T/PVC | | |
| OTHER SWL: | | T/PVC | | |

NOTES:

| PROTECTIVE CASING DETAILS | |
|--------------------------------------|---|
| PERMANENT, LEGIBLE WELL LABEL ADDED? | <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO |
| PROTECTIVE COVER AND LOCK INSTALLED? | <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO |
| LOCK KEY NUMBER: | |



MONITORING WELL DECOMMISSIONING LOG

| | | | |
|---|---|--------------------------------|-----------------------|
| PROJECT NAME: Consumers Energy Company: JH Campbell | MONITORING WELL ID: JHC-MW-15008 | | |
| PROJECT NUMBER: 322174.0002 | DATE: 06/24/2019 | LOCATION: Southeast of Pond A. | LOCATION COORDINATES: |
| OBSERVED BY: Paula Lancaster | | | N: 517560.39 |
| DRILLING CONTRACTOR: STEARNS DRILLING | | | E: 12636031.25 |
| CREW CHIEF: Roger Christiansen | TOP OF CASING ELEV.: 635.30 | SURFACE ELEV.: 632.43 | |

| | | | | | | |
|----------------------------|--|---|------------------------------------|---|--|--------------------------------------|
| PROTECTIVE COVER TYPE: | <input checked="" type="checkbox"/> STICK-UP | <input type="checkbox"/> FLUSH MOUNT | <input type="checkbox"/> TRAF. BOX | <input type="checkbox"/> OTHER _____ | | |
| PROTECTIVE COVER DIAMETER: | <input checked="" type="checkbox"/> 4" | <input type="checkbox"/> 8" | <input type="checkbox"/> 9" | <input type="checkbox"/> 10" | <input type="checkbox"/> 12" | <input type="checkbox"/> OTHER _____ |
| WELL MATERIAL: | <input checked="" type="checkbox"/> PVC | <input type="checkbox"/> SS | <input type="checkbox"/> IRON | <input type="checkbox"/> GALVANIZED STEEL | <input type="checkbox"/> OTHER _____ | |
| WELL CASING DIAMETER: | <input type="checkbox"/> 1" | <input checked="" type="checkbox"/> 2" | <input type="checkbox"/> 4" | <input type="checkbox"/> 6" | <input type="checkbox"/> 8" | <input type="checkbox"/> OTHER _____ |
| WELL SCREEN MATERIAL: | <input checked="" type="checkbox"/> PVC | <input type="checkbox"/> SS | <input type="checkbox"/> IRON | <input type="checkbox"/> GALVANIZED STEEL | <input type="checkbox"/> OTHER _____ | |
| WELL SCREEN LENGTH: | <input type="checkbox"/> 5-FT | <input checked="" type="checkbox"/> 10-FT | <input type="checkbox"/> UNKNOWN | <input type="checkbox"/> OTHER _____ | DTW: <u>Not measured</u> T/ PVC | |
| WELL SCREEN SLOT SIZE: | <input checked="" type="checkbox"/> 0.01" | <input type="checkbox"/> 0.02" | <input type="checkbox"/> UNKNOWN | <input type="checkbox"/> OTHER _____ | DTB: <u>Not measured</u> T/ PVC | |

| DECOMMISSIONING PROCEDURE | |
|---|--|
| NOTES: Well casing filled with medium bentonite pellets then hydrated. Pro-cover and concrete pad removed. Well casing cut off at 2 feet below grade. Remaining hole backfilled and brought to grade with the surrounding surface sand. | |

| GROUTING PROCEDURE: | NOTES: |
|--------------------------------------|--------|
| GROUT TYPE: NA | |
| GROUT MIX: | |
| GROUT INTERVAL: FT-BGS TO FT-BGS | |
| BENTONITE SEAL: MEDIUM CHIPS | |
| SEAL INTERVAL: 2 FT-BGS TO 38 FT-BGS | |

| |
|--|
| ADDITIONAL COMMENTS: |
| |

SIGNED

CHECKED



WELL CONSTRUCTION LOG

WELL NO. MW-14D

| | | | | |
|--|--|--|---|--|
| Facility/Project Name: Consumers Energy Company: JH Campbell | | Date Drilling Started: 4/10/18 | Date Drilling Completed: 4/10/18 | Project Number: 290806.0000.0000 |
| Drilling Firm: Stearns Drilling | Drilling Method: Direct Push | Surface Elev. (ft) 587.4 | TOC Elevation (ft) 590.35 | Total Depth (ft bgs) 35.0 |
| Boring Location: Approximately 17 feet SW of MW-14. N: 516842.4 E: 12636804.0 | | Personnel Logged By - T. Hess Driller - Tom Ulrich | | Drilling Equipment: Geoprobe 7822 DT |
| Civil Town/City/or Village: West Olive | County: Ottawa | State: MI | Water Level Observations: While Drilling: Date/Time 4/10/18 15:15 Depth (ft bgs) <u>6.5</u> After Drilling: Date/Time 4/11/18 08:13 Depth (ft bgs) <u>6.5</u> | |

| SAMPLE | NUMBER AND TYPE | RECOVERY (%) | BLOW COUNTS | DEPTH IN FEET | LITHOLOGIC DESCRIPTION | USCS | GRAPHIC LOG | WELL DIAGRAM | COMMENTS |
|--------|-----------------|--------------|-------------|---------------|--|-------|-------------|--------------|----------|
| | 1 | 100 | | 0 | TOPSOIL sandy, very dark gray (10YR 3/1). | | | | |
| | 2 | 75 | | 5 | SAND mostly fine to medium sand, yellowish brown (10YR 5/8), dry, loose. Change to light yellowish brown (10YR 6/4) at 2.5 feet. | | | | |
| | 3 | 75 | | 10 | Change to yellowish brown (10YR 5/8) at 5.0 feet. | | | | |
| | 4 | 90 | | 15 | Change to trace coarse sand, brown (10YR 5/3), saturated at 6.5 feet. | | | | |
| | 5 | 95 | | 20 | Change to trace gravel at 11.5 feet. | | | | |
| | 6 | 100 | | 25 | Change to no gravel at 13.5 feet. Change to reddish brown (5YR 4/4) at 14.0 feet. Change to mostly medium to coarse sand, brown (10YR 5/3) at 15.0 feet. | SP | | | |
| | 7 | 100 | | 30 | Change to mostly fine to medum sand at 18.0 feet. | | | | |
| | | | | 35 | SANDY SILT mostly silt, some fine to medium sand, brown (10YR 5/3), saturated, soft. | ML | | | |
| | | | | | SAND mostly fine to medium sand, brown (10YR5/3), saturated, loose. | | | | |
| | | | | | Change to mostly fine to medium sand, some medium to coarse sand at 31.5 feet. Change to trace to few coarse gravel at 33.0 feet. | SP | | | |
| | | | | | SILTY CLAY mostly clay, some silt, low plasticity, dark gray (10YR 4/1), dry, hard. | CL-ML | | | |
| | | | | | End of boring at 35.0 feet below ground surface. | | | | |

SOIL BORING WELL CONSTRUCTION LOG 290806.0000.GPJ TRC CORP. INCHES.GDT 7/16/18


Signature: Firm: TRC Environmental Corporation (734) 971-7080
1540 Eisenhower Place Ann Arbor, MI 48108 Fax (734) 971-9022

Checked By: C. Scieszka



WELL CONSTRUCTION DIAGRAM

| | |
|---|---------------------------|
| PROJ. NAME: Consumers Energy Company: JH Campbell | WELL ID: MW-14D |
| PROJ. NO: 290806.0000 | DATE INSTALLED: 4/11/2018 |
| INSTALLED BY: Tanner Hess | CHECKED BY: C. Scieszka |



| CASING AND SCREEN DETAILS | |
|---------------------------|---|
| TYPE OF RISER: | <u>2-INCH PVC</u> |
| PIPE SCHEDULE: | <u>40</u> |
| PIPE JOINTS: | <u>THREADED O-RINGS</u> |
| SOLVENT USED? | <u>NO</u> |
| SCREEN TYPE: | <u>2-INCH PVC, PRE-PACKED</u> |
| SCR. SLOT SIZE: | <u>0.01-INCH</u> |
| BOREHOLE DIAMETER: | <u>3.75</u> IN. FROM <u>0</u> TO <u>34.5</u> FT. |
| | <u>2</u> IN. FROM <u>34.5</u> TO <u>35</u> FT. |
| SURF. CASING DIAMETER: | <u> </u> IN. FROM <u> </u> TO <u> </u> FT. |
| | <u> </u> IN. FROM <u> </u> TO <u> </u> FT. |

| WELL DEVELOPMENT | |
|--|-----------------------|
| DEVELOPMENT METHOD: | <u>SURGE AND PUMP</u> |
| TIME DEVELOPING: | <u>0.58</u> HOURS |
| WATER REMOVED: | <u>75</u> GALLONS |
| WATER ADDED: | <u>5</u> GALLONS |
| WATER CLARITY BEFORE / AFTER DEVELOPMENT | |
| CLARITY BEFORE: | <u>CLOUDY</u> |
| COLOR BEFORE: | <u>BROWN</u> |
| CLARITY AFTER: | <u>CLEAR</u> |
| COLOR AFTER: | <u>CLEAR</u> |
| ODOR (IF PRESENT): | <u>NONE</u> |

| WATER LEVEL SUMMARY | | | | |
|------------------------|--------------------|-------|-----------|------|
| | MEASUREMENT (FEET) | | DATE | TIME |
| DTB BEFORE DEVELOPING: | 37.56 | T/PVC | 4/12/2018 | 0846 |
| DTB AFTER DEVELOPING: | 37.40 | T/PVC | 4/12/2018 | 0929 |
| SWE BEFORE DEVELOPING: | 9.43 | T/PVC | 4/12/2018 | 0846 |
| SWE AFTER DEVELOPING: | 9.44 | T/PVC | 4/12/2018 | 0929 |
| OTHER SWE: | | T/PVC | | |
| OTHER SWE: | | T/PVC | | |

NOTES:

| PROTECTIVE CASING DETAILS | |
|--------------------------------------|---|
| PERMANENT, LEGIBLE WELL LABEL ADDED? | <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO |
| PROTECTIVE COVER AND LOCK INSTALLED? | <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO |
| LOCK KEY NUMBER: | <u>Consumers</u> |



WELL CONSTRUCTION LOG

WELL NO. MW-14S

| | | | | | |
|---|--|--|---|--|-------------------------------------|
| Facility/Project Name: Consumers Energy Company: JH Campbell | | Date Drilling Started: 4/11/18 | Date Drilling Completed: 4/11/18 | Project Number: 290806.0000.0000 | |
| Drilling Firm: Stearns Drilling | Drilling Method: Direct Push | Surface Elev. (ft) 587.4 | TOC Elevation (ft) 590.98 | Total Depth (ft bgs) 9.5 | Borehole Dia. (in) 2/3.75 |
| Boring Location: Approximately 8 feet SW of MW-14. N: 516850.8 E: 12636808.0 | | Personnel Logged By - T. Hess Driller - Tom Ulrich | | Drilling Equipment: Geoprobe 7822 DT | |
| Civil Town/City/or Village: West Olive | County: Ottawa | State: MI | Water Level Observations: While Drilling: Date/Time 4/10/18 15:15 ▾ Depth (ft bgs) <u>6.5</u> After Drilling: Date/Time 4/11/18 09:13 ▾ Depth (ft bgs) <u>6.5</u> | | |

| SAMPLE | NUMBER AND TYPE | RECOVERY (%) | BLOW COUNTS | DEPTH IN FEET | LITHOLOGIC DESCRIPTION | USCS | GRAPHIC LOG | WELL DIAGRAM | COMMENTS |
|--------|-----------------|--------------|-------------|---------------|---|------|-------------|--------------|---|
| | | | | | | | | | |
| | | | | 0 | TOPSOIL sandy, very dark gray (10YR 3/1). | | | | Blind drill from 0-9.5 feet, lithology from 0-9.5 feet taken from MW-14D. |
| | | | | 1 | SAND mostly fine to medium sand, yellowish brown (10YR 5/8), dry, loose. | | | | |
| | | | | 2 | | | | | |
| | | | | 2.5 | Change to light yellowish brown (10YR 6/4) at 2.5 feet. | | | | |
| | | | | 3 | | | | | |
| | | | | 4 | | | | | |
| | | | | 5 | Change to yellowish brown (10YR 5/8) at 5.0 feet. | SP | | | |
| | | | | 6.5 | ▼ Change to trace coarse sand, brown (10YR 5/3), saturated at 6.5 feet. | | | | |
| | | | | 7 | | | | | |
| | | | | 9.5 | End of boring at 9.5 feet below ground surface. | | | | |

SOIL BORING WELL CONSTRUCTION LOG 290806.0000.GPJ TRC_CORP_INCHES.GDT 7/16/18 GP


Signature: Firm: TRC Environmental Corporation (734) 971-7080
1540 Eisenhower Place Ann Arbor, MI 48108 Fax (734) 971-9022

Checked By: C. Scieszka



WELL CONSTRUCTION DIAGRAM

| | |
|---|---------------------------|
| PROJ. NAME: Consumers Energy Company: JH Campbell | WELL ID: MW-14S |
| PROJ. NO: 290806.0000 | DATE INSTALLED: 4/11/2018 |
| INSTALLED BY: Tanner Hess | CHECKED BY: C. Scieszka |



| CASING AND SCREEN DETAILS | |
|---------------------------|---|
| TYPE OF RISER: | <u>2-INCH PVC</u> |
| PIPE SCHEDULE: | <u>40</u> |
| PIPE JOINTS: | <u>THREADED O-RINGS</u> |
| SOLVENT USED? | <u>NO</u> |
| SCREEN TYPE: | <u>2-INCH PVC, PRE-PACKED</u> |
| SCR. SLOT SIZE: | <u>0.01-INCH</u> |
| BOREHOLE DIAMETER: | <u>3.75</u> IN. FROM <u>0</u> TO <u>9.5</u> FT. |
| | <u> </u> IN. FROM <u> </u> TO <u> </u> FT. |
| SURF. CASING DIAMETER: | <u> </u> IN. FROM <u> </u> TO <u> </u> FT. |
| | <u> </u> IN. FROM <u> </u> TO <u> </u> FT. |

| WELL DEVELOPMENT | |
|--|-----------------------|
| DEVELOPMENT METHOD: | <u>SURGE AND PUMP</u> |
| TIME DEVELOPING: | <u>0.25</u> HOURS |
| WATER REMOVED: | <u>25</u> GALLONS |
| WATER ADDED: | <u>5</u> GALLONS |
| WATER CLARITY BEFORE / AFTER DEVELOPMENT | |
| CLARITY BEFORE: | <u>CLOUDY</u> |
| COLOR BEFORE: | <u>BROWN</u> |
| CLARITY AFTER: | <u>CLEAR</u> |
| COLOR AFTER: | <u>CLEAR</u> |
| ODOR (IF PRESENT): | <u>NONE</u> |

| WATER LEVEL SUMMARY | | | | |
|------------------------|-------|-------|-----------|------|
| MEASUREMENT (FEET) | | | DATE | TIME |
| DTB BEFORE DEVELOPING: | 13.03 | T/PVC | 4/12/2018 | 0926 |
| DTB AFTER DEVELOPING: | 13.19 | T/PVC | 4/12/2018 | 0949 |
| SWE BEFORE DEVELOPING: | 10.19 | T/PVC | 4/12/2018 | 0926 |
| SWE AFTER DEVELOPING: | 10.30 | T/PVC | 4/12/2018 | 0949 |
| OTHER SWE: | | T/PVC | | |
| OTHER SWE: | | T/PVC | | |

NOTES:

| PROTECTIVE CASING DETAILS | |
|--------------------------------------|---|
| PERMANENT, LEGIBLE WELL LABEL ADDED? | <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO |
| PROTECTIVE COVER AND LOCK INSTALLED? | <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO |
| LOCK KEY NUMBER: | <u>Consumers</u> |



WELL CONSTRUCTION LOG

WELL NO. PZ-23D

Page 1 of 1

| | | | | |
|---|--|--|---|--|
| Facility/Project Name: Consumers Energy Company: JH Campbell | | Date Drilling Started: 4/9/18 | Date Drilling Completed: 4/9/18 | Project Number: 290806.0000.0000 |
| Drilling Firm: Stearns Drilling | Drilling Method: Direct Push | Surface Elev. (ft) 603.1 | TOC Elevation (ft) 606.17 | Total Depth (ft bgs) 40.0 |
| Boring Location: Approximately 17 feet ESE of PZ-23. N: 517279.8 E: 12633475.1 | | Personnel Logged By - T. Hess Driller - Tom Ulrich | | Drilling Equipment: Geoprobe 7822 DT |
| Civil Town/City/or Village: West Olive | County: Ottawa | State: MI | Water Level Observations: While Drilling: Date/Time <u>4/9/18 10:55</u> Depth (ft bgs) <u>12.3</u> After Drilling: Date/Time <u>4/9/18 14:55</u> Depth (ft bgs) <u>12.8</u> | |

| SAMPLE | NUMBER AND TYPE | RECOVERY (%) | BLOW COUNTS | DEPTH IN FEET | LITHOLOGIC DESCRIPTION | USCS | GRAPHIC LOG | WELL DIAGRAM | COMMENTS |
|--------|-----------------|--------------|-------------|---------------|--|-------|-------------|--------------|----------|
| | 1 | HA | 100 | 0 | TOPSOIL black (10YR 2/1), organic material present. | | | | |
| | 2 | GP | 85 | 5 | SAND mostly fine to medium sand, light yellowish brown (10YR 6/4), loose, dry. | | | | |
| | 3 | GP | 60 | 12.5 | Change to pale brown (10YR 6/3), mostly fine, wet at 12.5 feet. | | | | |
| | 4 | GP | 80 | 15 | Change to brown (10 YR 5/3) at 15.0 feet. | | | | |
| | 5 | GP | 90 | 18 | Change to fine to medium sand at 18.0 feet. | SP | | | |
| | 6 | GP | 95 | 23 | Change to medium to coarse sand at 23.0 feet. | | | | |
| | 7 | GP | 100 | 25 | Change to fine to medium sand at 25.0 feet. | | | | |
| | 8 | GP | 60 | 29 | 2-inch seam of medium to coarse sand at 29.0 feet. | | | | |
| | | | | 30 | Change to gray (10YR 5/1) at 30.0 feet. | | | | |
| | 8 | GP | 60 | 35 | SILTY CLAY mostly clay, some silt, no to low plasticity, dark gray (10YR 4/1), dry, hard. | CL-ML | | | |
| | | | | 40 | End of boring at 40.0 feet below ground surface. | | | | |

SOIL BORING WELL CONSTRUCTION LOG 290806.0000.GPJ TRC_CORP_INCHES.GDT 7/16/18


| | | |
|------------|--|--------------------------------------|
| Signature: | Firm: TRC Environmental Corporation 1540 Eisenhower Place Ann Arbor, MI 48108 | (734) 971-7080 Fax (734) 971-9022 |
|------------|--|--------------------------------------|

Checked By: C. Scieszka



WELL CONSTRUCTION DIAGRAM

| | |
|---|--------------------------|
| PROJ. NAME: Consumers Energy Company: JH Campbell | WELL ID: PZ-23D |
| PROJ. NO: 290806.0000 | DATE INSTALLED: 4/9/2018 |
| INSTALLED BY: Tanner Hess | CHECKED BY: C. Scieszka |



| CASING AND SCREEN DETAILS | |
|---------------------------|---|
| TYPE OF RISER: | <u>2-INCH PVC</u> |
| PIPE SCHEDULE: | <u>40</u> |
| PIPE JOINTS: | <u>THREADED O-RINGS</u> |
| SOLVENT USED? | <u>NO</u> |
| SCREEN TYPE: | <u>2-INCH PVC, PRE-PACKED</u> |
| SCR. SLOT SIZE: | <u>0.01-INCH</u> |
| BOREHOLE DIAMETER: | <u>3.75</u> IN. FROM <u>0</u> TO <u>35</u> FT. |
| | <u>2</u> IN. FROM <u>35</u> TO <u>40</u> FT. |
| SURF. CASING DIAMETER: | <u> </u> IN. FROM <u> </u> TO <u> </u> FT. |
| | <u> </u> IN. FROM <u> </u> TO <u> </u> FT. |

| WELL DEVELOPMENT | |
|--|-----------------------|
| DEVELOPMENT METHOD: | <u>SURGE AND PUMP</u> |
| TIME DEVELOPING: | <u>0.25</u> HOURS |
| WATER REMOVED: | <u>50</u> GALLONS |
| WATER ADDED: | <u>4</u> GALLONS |
| WATER CLARITY BEFORE / AFTER DEVELOPMENT | |
| CLARITY BEFORE: | <u>CLOUDY</u> |
| COLOR BEFORE: | <u>BROWN</u> |
| CLARITY AFTER: | <u>CLEAR</u> |
| COLOR AFTER: | <u>CLEAR</u> |
| ODOR (IF PRESENT): | <u>NONE</u> |

| WATER LEVEL SUMMARY | | | | |
|------------------------|-------|-------|-----------|------|
| MEASUREMENT (FEET) | | | DATE | TIME |
| DTB BEFORE DEVELOPING: | 37.83 | T/PVC | 4/11/2018 | 1410 |
| DTB AFTER DEVELOPING: | 37.36 | T/PVC | 4/11/2018 | 1442 |
| SWE BEFORE DEVELOPING: | 15.99 | T/PVC | 4/11/2018 | 1409 |
| SWE AFTER DEVELOPING: | 15.99 | T/PVC | 4/11/2018 | 1441 |
| OTHER SWE: | | T/PVC | | |
| OTHER SWE: | | T/PVC | | |

NOTES:

| PROTECTIVE CASING DETAILS | |
|--------------------------------------|---|
| PERMANENT, LEGIBLE WELL LABEL ADDED? | <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO |
| PROTECTIVE COVER AND LOCK INSTALLED? | <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO |
| LOCK KEY NUMBER: | <u>Consumers</u> |



WELL CONSTRUCTION LOG

WELL NO. PZ-23S

Page 1 of 1

| | | | | |
|--|--|--|---|--|
| Facility/Project Name: Consumers Energy Company: JH Campbell | | Date Drilling Started: 4/9/18 | Date Drilling Completed: 4/9/18 | Project Number: 290806.0000.0000 |
| Drilling Firm: Stearns Drilling | Drilling Method: Direct Push | Surface Elev. (ft) 602.8 | TOC Elevation (ft) 604.97 | Total Depth (ft bgs) 16.0 |
| Boring Location: Approximately 8.5 feet ESE of PZ-23. N: 517281.6 E: 12633466.4 | | Personnel Logged By - T. Hess Driller - Tom Ulrich | | Drilling Equipment: Geoprobe 7822 DT |
| Civil Town/City/or Village: West Olive | County: Ottawa | State: MI | Water Level Observations: While Drilling: Date/Time <u>4/9/18 15:10</u> Depth (ft bgs) <u>12.5</u> After Drilling: Date/Time <u>4/9/18 15:32</u> Depth (ft bgs) <u>12.2</u> | |

| SAMPLE | | BLOW COUNTS | DEPTH IN FEET | LITHOLOGIC DESCRIPTION | USCS | GRAPHIC LOG | WELL DIAGRAM | COMMENTS |
|-----------------|--------------|-------------|---------------|---|------|-------------|--------------|---|
| NUMBER AND TYPE | RECOVERY (%) | | | | | | | |
| | | | | TOPSOIL black (10YR 2/1), organic material present. | | | | Blind drill from 0-10 feet and 15-16 feet, lithology from 0-10 feet and 15-16 feet taken from PZ-23D. |
| | | | 2 | SAND mostly fine to medium sand, light yellowish brown (10YR 6/4), loose, dry. | | | | |
| | | | 4 | | | | | |
| | | | 6 | | | | | |
| | | | 8 | | | | | |
| | | | 10 | | SP | | | |
| | | | 12 | Change to pale brown (10YR 6/3), mostly fine, saturated at 12.5 feet. | | | | |
| | | 50 | 14 | Change to brown (10 YR 5/3) at 15.0 feet. | | | | |
| | | | 16 | End of boring at 16.0 feet below ground surface. | | | | |

SOIL BORING WELL CONSTRUCTION LOG 290806.0000.0000.GPJ TRC_CORP_INCHES.GDT 7/16/18


Signature: Firm: TRC Environmental Corporation (734) 971-7080
 1540 Eisenhower Place Ann Arbor, MI 48108 Fax (734) 971-9022

Checked By: C. Scieszka



WELL CONSTRUCTION DIAGRAM

| | |
|---|--|
| PROJ. NAME: Consumers Energy Company: JH Campbell | WELL ID: PZ-23S |
| PROJ. NO: 290806.0000 | DATE INSTALLED: 4/9/2018 INSTALLED BY: Tanner Hess CHECKED BY: C. Scieszka |



| CASING AND SCREEN DETAILS | |
|---------------------------|---|
| TYPE OF RISER: | <u>2-INCH PVC</u> |
| PIPE SCHEDULE: | <u>40</u> |
| PIPE JOINTS: | <u>THREADED O-RINGS</u> |
| SOLVENT USED? | <u>NO</u> |
| SCREEN TYPE: | <u>2-INCH PVC, PRE-PACKED</u> |
| SCR. SLOT SIZE: | <u>0.01-INCH</u> |
| BOREHOLE DIAMETER: | <u>3.75</u> IN. FROM <u>0</u> TO <u>16</u> FT. |
| | <u> </u> IN. FROM <u> </u> TO <u> </u> FT. |
| SURF. CASING DIAMETER: | <u> </u> IN. FROM <u> </u> TO <u> </u> FT. |
| | <u> </u> IN. FROM <u> </u> TO <u> </u> FT. |

| WELL DEVELOPMENT | |
|--|-----------------------|
| DEVELOPMENT METHOD: | <u>SURGE AND PUMP</u> |
| TIME DEVELOPING: | <u>0.5</u> HOURS |
| WATER REMOVED: | <u>30</u> GALLONS |
| WATER ADDED: | <u>5</u> GALLONS |
| WATER CLARITY BEFORE / AFTER DEVELOPMENT | |
| CLARITY BEFORE: | <u>CLOUDY</u> |
| COLOR BEFORE: | <u>BROWN</u> |
| CLARITY AFTER: | <u>CLEAR</u> |
| COLOR AFTER: | <u>CLEAR</u> |
| ODOR (IF PRESENT): | <u>NONE</u> |

| WATER LEVEL SUMMARY | | | | |
|------------------------|-------|-------|-----------|------|
| MEASUREMENT (FEET) | | DATE | TIME | |
| DTB BEFORE DEVELOPING: | 18.35 | T/PVC | 4/11/2018 | 1442 |
| DTB AFTER DEVELOPING: | 18.25 | T/PVC | 4/11/2018 | 1515 |
| SWE BEFORE DEVELOPING: | 14.69 | T/PVC | 4/11/2018 | 1442 |
| SWE AFTER DEVELOPING: | 14.71 | T/PVC | 4/11/2018 | 1515 |
| OTHER SWE: | | T/PVC | | |
| OTHER SWE: | | T/PVC | | |

NOTES:

| PROTECTIVE CASING DETAILS | |
|--------------------------------------|---|
| PERMANENT, LEGIBLE WELL LABEL ADDED? | <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO |
| PROTECTIVE COVER AND LOCK INSTALLED? | <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO |
| LOCK KEY NUMBER: | <u>Consumers</u> |



WELL CONSTRUCTION LOG

WELL NO. PZ-24D

Page 1 of 1

| | | | | |
|--|--|--|---|--|
| Facility/Project Name: Consumers Energy Company: JH Campbell | | Date Drilling Started: 4/10/18 | Date Drilling Completed: 4/10/18 | Project Number: 290806.0000.0000 |
| Drilling Firm: Stearns Drilling | Drilling Method: Direct Push | Surface Elev. (ft) 586.6 | TOC Elevation (ft) 590.06 | Total Depth (ft bgs) 35.0 |
| Boring Location: Approximately 14 feet E of PZ-24. | | Personnel Logged By - T. Hess Driller - Tom Ulrich | | Drilling Equipment: Geoprobe 7822 DT |
| N: 516444.3 E: 12636155.3 | | | | |
| Civil Town/City/or Village: West Olive | County: Ottawa | State: MI | Water Level Observations: While Drilling: Date/Time 4/10/18 12:30 ▾ Depth (ft bgs) <u>3.5</u> After Drilling: Date/Time 4/10/18 14:20 ▾ Depth (ft bgs) <u>3.0</u> | |

| SAMPLE | NUMBER AND TYPE | RECOVERY (%) | BLOW COUNTS | DEPTH IN FEET | LITHOLOGIC DESCRIPTION | USCS | GRAPHIC LOG | WELL DIAGRAM | COMMENTS |
|--------|-----------------|--------------|-------------|---------------|--|-----------------|-------------|--------------|----------|
| | 1 | HA | 100 | 0 | SAND mostly fine to medium sand, strong brown (7.5 YR 4/6), loose, dry. Change to light yellowish brown (10YR 6/4) at 1.0 feet. | | | | |
| | 2 | GP | 100 | 5 | Change to mostly medium to coarse sand, pale brown (10YR 6/3), saturated at 3.5 feet. Change to mostly fine to medium sand at 4.0 feet. | | | | |
| | 3 | GP | 90 | 10 | Change to mostly medium to coarse sand, brown (10YR 5/3) at 10.0 feet. | | | | |
| | 4 | GP | 85 | 15 | Change to mostly fine to medium sand at 15.0 feet. | SP | | | |
| | 5 | GP | 100 | 20 | | | | | |
| | 6 | GP | 90 | 25 | Change to pale brown (10YR 6/3) at 25.0 feet. | | | | |
| | 7 | GP | 100 | 30 | Change to light brownish gray (10YR 6/2) at 30.0 feet. SILTY SAND mostly fine to medium sand, some silt, light brownish gray (10YR 6/2), saturated, loose. | SM | | | |
| | | | | 35 | SANDY SILT mostly fine silt, little fine to medium sand, light brownish gray (10YR 6/2), saturated, soft. SILTY CLAY mostly clay, some silt, no to low plasticity, dark gray (10YR 4/1), dry, hard. End of boring at 35.0 feet below ground surface. | ML CL- ML | | | |

SOIL BORING WELL CONSTRUCTION LOG 290806.0000.GPJ TRC_CORP_INCHES.GDT 7/16/18


Signature: Firm: **TRC Environmental Corporation** (734) 971-7080
1540 Eisenhower Place Ann Arbor, MI 48108 Fax (734) 971-9022

Checked By: C. Scieszka



WELL CONSTRUCTION DIAGRAM

| | |
|---|---------------------------|
| PROJ. NAME: Consumers Energy Company: JH Campbell | WELL ID: PZ-24D |
| PROJ. NO: 290806.0000 | DATE INSTALLED: 4/10/2018 |
| INSTALLED BY: Tanner Hess | CHECKED BY: C. Scieszka |



| CASING AND SCREEN DETAILS | |
|---------------------------|---------------------------|
| TYPE OF RISER: | 2-INCH PVC |
| PIPE SCHEDULE: | 40 |
| PIPE JOINTS: | THREADED O-RINGS |
| SOLVENT USED? | NO |
| SCREEN TYPE: | 2-INCH PVC, PRE-PACKED |
| SCR. SLOT SIZE: | 0.01-INCH |
| BOREHOLE DIAMETER: | 3.75 IN. FROM 0 TO 35 FT. |
| | IN. FROM TO FT. |
| SURF. CASING DIAMETER: | IN. FROM TO FT. |
| | IN. FROM TO FT. |

| WELL DEVELOPMENT | |
|--|----------------|
| DEVELOPMENT METHOD: | SURGE AND PUMP |
| TIME DEVELOPING: | 0.42 HOURS |
| WATER REMOVED: | 75 GALLONS |
| WATER ADDED: | 5 GALLONS |
| WATER CLARITY BEFORE / AFTER DEVELOPMENT | |
| CLARITY BEFORE: | CLOUDY |
| COLOR BEFORE: | BROWN |
| CLARITY AFTER: | CLEAR |
| COLOR AFTER: | CLEAR |
| ODOR (IF PRESENT): | NONE |

| WATER LEVEL SUMMARY | | | | |
|------------------------|-------|-------|-----------|------|
| MEASUREMENT (FEET) | | | DATE | TIME |
| DTB BEFORE DEVELOPING: | 38.50 | T/PVC | 4/12/2018 | 0750 |
| DTB AFTER DEVELOPING: | 38.50 | T/PVC | 4/12/2018 | 0824 |
| SWE BEFORE DEVELOPING: | 6.63 | T/PVC | 4/12/2018 | 0750 |
| SWE AFTER DEVELOPING: | 6.61 | T/PVC | 4/12/2018 | 0824 |
| OTHER SWE: | | T/PVC | | |
| OTHER SWE: | | T/PVC | | |

NOTES:

| PROTECTIVE CASING DETAILS | |
|--------------------------------------|---|
| PERMANENT, LEGIBLE WELL LABEL ADDED? | <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO |
| PROTECTIVE COVER AND LOCK INSTALLED? | <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO |
| LOCK KEY NUMBER: | Consumers |



WELL CONSTRUCTION LOG

WELL NO. PZ-24S

| | | | | |
|--|--|--|---|--|
| Facility/Project Name: Consumers Energy Company: JH Campbell | | Date Drilling Started: 4/10/18 | Date Drilling Completed: 4/10/18 | Project Number: 290806.0000.0000 |
| Drilling Firm: Stearns Drilling | Drilling Method: Direct Push | Surface Elev. (ft) 586.6 | TOC Elevation (ft) 590.15 | Total Depth (ft bgs) 7.0 |
| Boring Location: Approximately 7 feet E of PZ-24. N: 516441.6 E: 12636148.7 | | Personnel Logged By - T. Hess Driller - Tom Ulrich | | Drilling Equipment: Geoprobe 7822 DT |
| Civil Town/City/or Village: West Olive | County: Ottawa | State: MI | Water Level Observations: While Drilling: Date/Time 4/10/18 12:30 ▾ Depth (ft bgs) <u>3.5</u> After Drilling: Date/Time 4/10/18 14:45 ▾ Depth (ft bgs) <u>3.0</u> | |

| SAMPLE | | BLOW COUNTS | DEPTH IN FEET | LITHOLOGIC DESCRIPTION | USCS | GRAPHIC LOG | WELL DIAGRAM | COMMENTS |
|-----------------|--------------|-------------|---------------|---|------|-------------|--------------|---|
| NUMBER AND TYPE | RECOVERY (%) | | | | | | | |
| | | | 0 | SAND mostly fine to medium sand, strong brown (7.5 YR 4/6), loose, dry. | | | | Blind drill from 0-7 feet, lithology from 0-7 feet taken from PZ-24D. |
| | | | 1 | Change to light yellowish brown (10YR 6/4) at 1.0 feet. | | | | |
| | | | 2 | | | | | |
| | | | 3 | ▼ | | | | |
| | | | 3.5 | ▽ | | | | |
| | | | 4 | Change to mostly medium to coarse sand, pale brown (10YR 6/3), saturated at 3.5 feet. | SP | | | |
| | | | 4 | Change to mostly fine to medium sand at 4.0 feet. | | | | |
| | | | 5 | | | | | |
| | | | 6 | | | | | |
| | | | 7 | End of boring at 7.0 feet below ground surface. | | | | |

SOIL BORING WELL CONSTRUCTION LOG 290806.0000.GPJ TRC_CORP_INCHES.GDT 7/16/18


Signature:  Firm: TRC Environmental Corporation (734) 971-7080
1540 Eisenhower Place Ann Arbor, MI 48108 Fax (734) 971-9022

Checked By: C. Scieszka



WELL CONSTRUCTION DIAGRAM

| | |
|---|---------------------------|
| PROJ. NAME: Consumers Energy Company: JH Campbell | WELL ID: PZ-24S |
| PROJ. NO: 290806.0000 | DATE INSTALLED: 4/10/2018 |
| INSTALLED BY: Tanner Hess | CHECKED BY: C. Scieszka |



| CASING AND SCREEN DETAILS | |
|---------------------------|---|
| TYPE OF RISER: | <u>2-INCH PVC</u> |
| PIPE SCHEDULE: | <u>40</u> |
| PIPE JOINTS: | <u>THREADED O-RINGS</u> |
| SOLVENT USED? | <u>NO</u> |
| SCREEN TYPE: | <u>2-INCH PVC, PRE-PACKED</u> |
| SCR. SLOT SIZE: | <u>0.01-INCH</u> |
| BOREHOLE DIAMETER: | <u>3.75</u> IN. FROM <u>0</u> TO <u>7</u> FT. |
| | <u> </u> IN. FROM <u> </u> TO <u> </u> FT. |
| SURF. CASING DIAMETER: | <u> </u> IN. FROM <u> </u> TO <u> </u> FT. |
| | <u> </u> IN. FROM <u> </u> TO <u> </u> FT. |

| WELL DEVELOPMENT | |
|--|-----------------------|
| DEVELOPMENT METHOD: | <u>SURGE AND PUMP</u> |
| TIME DEVELOPING: | <u>0.17</u> HOURS |
| WATER REMOVED: | <u>25</u> GALLONS |
| WATER ADDED: | <u>5</u> GALLONS |
| WATER CLARITY BEFORE / AFTER DEVELOPMENT | |
| CLARITY BEFORE: | <u>CLOUDY</u> |
| COLOR BEFORE: | <u>BROWN</u> |
| CLARITY AFTER: | <u>CLEAR</u> |
| COLOR AFTER: | <u>CLEAR</u> |
| ODOR (IF PRESENT): | <u>NONE</u> |

| WATER LEVEL SUMMARY | | | | |
|------------------------|-------|-------|-----------|------|
| MEASUREMENT (FEET) | | | DATE | TIME |
| DTB BEFORE DEVELOPING: | 11.10 | T/PVC | 4/12/2018 | 0822 |
| DTB AFTER DEVELOPING: | 11.02 | T/PVC | 4/12/2018 | 0838 |
| SWE BEFORE DEVELOPING: | 6.74 | T/PVC | 4/12/2018 | 0822 |
| SWE AFTER DEVELOPING: | 6.80 | T/PVC | 4/12/2018 | 0838 |
| OTHER SWE: | | T/PVC | | |
| OTHER SWE: | | T/PVC | | |

NOTES:

| PROTECTIVE CASING DETAILS | |
|--------------------------------------|---|
| PERMANENT, LEGIBLE WELL LABEL ADDED? | <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO |
| PROTECTIVE COVER AND LOCK INSTALLED? | <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO |
| LOCK KEY NUMBER: | <u>Consumers</u> |



WELL CONSTRUCTION LOG

WELL NO. PZ-40S

Page 1 of 1

| | | | | |
|--|--|--|--|--|
| Facility/Project Name: Consumers Energy Company: JH Campbell | | Date Drilling Started: 4/10/18 | Date Drilling Completed: 4/10/18 | Project Number: 290806.0000.0000 |
| Drilling Firm: Stearns Drilling | Drilling Method: Direct Push | Surface Elev. (ft) 589.5 | TOC Elevation (ft) 593.25 | Total Depth (ft bgs) 15.0 |
| Boring Location: Approximately 8 feet W of PZ-40. N: 516097.9 E: 12634760.3 | | Personnel Logged By - T. Hess Driller - Tom Ulrich | | Drilling Equipment: Geoprobe 7822 DT |
| Civil Town/City/or Village: West Olive | County: Ottawa | State: MI | Water Level Observations: While Drilling: Date/Time 4/10/18 10:20 Depth (ft bgs) <u>7.25</u> After Drilling: Date/Time 4/10/18 10:50 Depth (ft bgs) <u>7.0</u> | |

| SAMPLE | RECOVERY (%) | BLOW COUNTS | DEPTH IN FEET | LITHOLOGIC DESCRIPTION | USCS | GRAPHIC LOG | WELL DIAGRAM | COMMENTS |
|---------|--------------|-------------|---------------|---|------|-------------|--------------|----------|
| 1 HA | 100 | | 2 | SAND mostly fine to medium sand, yellowish brown (10YR 5/8), loose, dry. Change to light yellowish brown (10YR 6/4) at 2.0 feet. | | | | |
| 2 GP | 80 | | 7.25 | Change to saturated at 7.25 feet. Change to mostly medium to coarse sand, yellowish brown (10YR 5/4) at 7.5 feet. Change to light yellowish brown (10YR 6/4) at 8.5 feet. | SP | | | |
| 3 GP | 75 | | 10.0 | Change to mostly medium to coarse sand, brown (10YR 5/3) at 10.0 feet. | | | | |
| | | | 15.0 | End of boring at 15.0 feet below ground surface. | | | | |

SOIL BORING WELL CONSTRUCTION LOG 290806.0000.GPJ TRC_CORP_INCHES.GDT 7/16/18


| | | |
|------------|--|--------------------------------------|
| Signature: | Firm: TRC Environmental Corporation 1540 Eisenhower Place Ann Arbor, MI 48108 | (734) 971-7080 Fax (734) 971-9022 |
|------------|--|--------------------------------------|

Checked By: C. Scieszka



WELL CONSTRUCTION DIAGRAM

| | |
|---|---------------------------|
| PROJ. NAME: Consumers Energy Company: JH Campbell | WELL ID: PZ-40S |
| PROJ. NO: 290806.0000 | DATE INSTALLED: 4/10/2018 |
| INSTALLED BY: Tanner Hess | CHECKED BY: C. Scieszka |



| CASING AND SCREEN DETAILS | |
|---------------------------|---|
| TYPE OF RISER: | <u>2-INCH PVC</u> |
| PIPE SCHEDULE: | <u>40</u> |
| PIPE JOINTS: | <u>THREADED O-RINGS</u> |
| SOLVENT USED? | <u>NO</u> |
| SCREEN TYPE: | <u>2-INCH PVC, PRE-PACKED</u> |
| SCR. SLOT SIZE: | <u>0.01-INCH</u> |
| BOREHOLE DIAMETER: | <u>3.75</u> IN. FROM <u>0</u> TO <u>14</u> FT. |
| | <u>2</u> IN. FROM <u>14</u> TO <u>15</u> FT. |
| SURF. CASING DIAMETER: | <u> </u> IN. FROM <u> </u> TO <u> </u> FT. |
| | <u> </u> IN. FROM <u> </u> TO <u> </u> FT. |

| WELL DEVELOPMENT | |
|--|-----------------------|
| DEVELOPMENT METHOD: | <u>SURGE AND PUMP</u> |
| TIME DEVELOPING: | <u>0.25</u> HOURS |
| WATER REMOVED: | <u>50</u> GALLONS |
| WATER ADDED: | <u>5</u> GALLONS |
| WATER CLARITY BEFORE / AFTER DEVELOPMENT | |
| CLARITY BEFORE: | <u>CLOUDY</u> |
| COLOR BEFORE: | <u>BROWN</u> |
| CLARITY AFTER: | <u>CLEAR</u> |
| COLOR AFTER: | <u>CLEAR</u> |
| ODOR (IF PRESENT): | <u>NONE</u> |

| WATER LEVEL SUMMARY | | | | |
|------------------------|-------|-------|-----------|------|
| MEASUREMENT (FEET) | | | DATE | TIME |
| DTB BEFORE DEVELOPING: | 17.71 | T/PVC | 4/11/2018 | 1554 |
| DTB AFTER DEVELOPING: | 17.92 | T/PVC | 4/11/2018 | 1620 |
| SWE BEFORE DEVELOPING: | 10.75 | T/PVC | 4/11/2018 | 1553 |
| SWE AFTER DEVELOPING: | 10.75 | T/PVC | 4/11/2018 | 1620 |
| OTHER SWE: | | T/PVC | | |
| OTHER SWE: | | T/PVC | | |

NOTES:

| PROTECTIVE CASING DETAILS | |
|--------------------------------------|---|
| PERMANENT, LEGIBLE WELL LABEL ADDED? | <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO |
| PROTECTIVE COVER AND LOCK INSTALLED? | <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO |
| LOCK KEY NUMBER: | <u>Consumers</u> |

DRILLING AND SAMPLING LOG

HOLE NO. Pz-23

ELEV. 602.9

PROJECT J. H. Campbell Plant, Consumers Power Co. DEPTH 18.6 ft.

FEATURE Groundwater Study DEPTH TO WATER 9.7 ft. 8/5/76

JOB NO. 64-0047-954 DRILLER Balzer Cook LOGGED BY P. D. Lidel

LOCATION Great Lakes Soiltest

DRILLING CO. Services DRILL RIG. Mobil B-40

Completion Date 8/5/76

Drilling Method: Eight-inch hollow stem auger, Standard Penetration Resistance Test and split spoon samples taken every five feet:

| DEPTH (ELEV) | CLASS | FIELD DESCRIPTION | SAMPLE NUMBER | RECOVERY | SPT | REMARKS |
|--------------|-------|--|---------------|----------|-----|---|
| 0 | | | | | | |
| 602.9 | | 0.0 - 16.0 Sand, brown, very fine grained, loose and dry at surface becoming more damp toward water table (SP) | 1 | 66 | X | 1/0/0 |
| 5 | SP | 0.0 - 0.5 Sand is dark brown due to the presence of organic matter. | 2 | 100 | X | 2/2/4 Bag sample #1 taken between 7. and 9.0 ft. |
| 10 | | | 3 | 100 | X | 2/3/3 |
| 15 | | | 4 | 33 | X | 1/1/1 |
| 584.3 | | Bottom of Boring - 16.0 ft. | | | | |
| 20 | | Drove 2 in. dia. well screen to 18.6 ft. with 1.0 ft. of casing above ground. Hole sealed with 1/2 bag of bentonite. | | | | |
| 25 | | | | | | |
| 30 | | | | | | |

DRILLING AND SAMPLING LOG

PZ-24

HOLE NO. _____

ELEV. 587.0

PROJECT J. H. Campbell Plant, Consumers Power Co. DEPTH 13.2 ft.

FEATURE Groundwater Study DEPTH TO WATER 4.0 ft. 8/6/76

JOB NO. 64-0047-954 DRILLER Balzer Cook LOGGED BY P. D. Lidel

LOCATION Great Lakes Soiltest

DRILLING CO. Services DRILL RIG. Mobil B-40

Completion Date 8/6/76

Drilling Method: Eight-inch hollow stem auger, Standard Penetration Resistance Test and split spoon samples taken every five feet.

| DEPTH (ELEV) | CLASS | FIELD DESCRIPTION | SAMPLE NUMBER | RECOVERY | SPT | REMARKS |
|--------------|-------|---|---------------|----------|-----|---------|
| 0 | | | | | | |
| 587.0 | SP | 0.0 - 10.0 Sand, brown, very fine grained, loose, damp above water table, contains some organic matter in upper 0.5 ft. (SP) | 1 | 100 | X | 1/1/1 |
| 5 | | | 2 | 100 | X | 1/2/2 |
| 10 | | | 3 | 33 | X | 1/1/1 |
| 577.0 | | Bottom of Boring - 10.0 ft. Drove 2 in. dia. well screen to 13.2 ft. with 1.0 ft. of casing above ground. Hole sealed with 1/2 bag of bentonite. | | | | |
| 15 | | | | | | |
| 20 | | | | | | |
| 25 | | | | | | |
| 30 | | | | | | |

Consumers Power Company
 J. H. Campbell Plant
 Groundwater Study
 W. O. 64-0047-954

BORING PZ-40

SURFACE ELEVATION 590.1
COORDINATE


| ELEV. IN FEET | OTHER TESTS | STRENGTH TEST (PSF) | ATTERBERG LIMITS | | FIELD MOISTURE CONTENT (%) | DRY DENSITY (PCF) | PERCENT RECOVERY (%) | ROD | DEEP IN FEET | BLOW COUNT | SYMBOLS | DESCRIPTION |
|---------------|-------------|---------------------|------------------|------------------|----------------------------|-------------------|----------------------|-----|--------------|------------|---------|--|
| | | | LIQUID LIMIT | PLASTICITY INDEX | | | | | | | | |
| 590 | | | | | | | | | 5 | 4 | | LIGHT BROWN SAND: fine to medium-grained, trace of coarse sand and fine gravel, very loose to medium dense, 0'-25'. Completed boring at 25' on 9/7/79 Installed PVC standpipe piezometer with bottom of screen at elev. 568.3. |
| | | | | | | | | | 10 | 6 | | |
| 580 | | | | | | | | | 15 | 5 | SP | |
| | | | | | | | | | 20 | 14 | | |
| 570 | | | | | | | | | 25 | 8 | O | |

LOG OF BORING

 **Gilbert/Commonwealth**
ENGINEERS/GEOTECHNICAL CONSULTANTS Reading, PA / Ardmore, PA

PLATE

STS Field Well Installation Diagram



- 1) TYPE OF PIPE
PVC, GALVANIZED STAINLESS, OTHER _____
- 2) TYPE OF PIPE JOINTS
BELLED, COUPLINGS THREADED, OTHER _____
- 3) TYPE OF WELL SCREEN
PVC, GALVANIZED, STAINLESS OTHER _____
- 4) SCREEN SIZE _____ 5'
- 5) INSTALLED PROTECTOR PIPE W/LOCK? YES OR NO
- 6) WAS SOLVENT USED? YES OR NO
- 7) WAS DRILLING MUD USED?
SOLID AUGER, HOLLOW STEM AUGER WATER REVERT, BENTONITE
- 8) DID STANDPIPE COME UP WHEN CASING WAS PULLED?
YES OR NO
- 9) HOW WAS WELL DEVELOPED?
BAILING PUMPING, SURGING, COMPRESSED AIR
- 10) TIME SPENT FOR WELL DEVELOPMENT
5 MIN., 15 MIN., 30 MIN OTHER _____
- 11) APPROXIMATE WATER VOLUME REMOVED OR ADDED?
5 GAL, 10 GAL, 15 GAL, OTHER _____
- 12) WATER CLARITY BEFORE DEVELOPMENT
CLEAR TURBID, OPAQUE
- 13) WATER CLARITY AFTER DEVELOPMENT
CLEAR TURBID, OPAQUE
- 14) DID THE WATER SMELL? YES OR NO
- 15) WATER LEVEL SUMMARY
 - 1) DEPTH FROM T. STANDPIPE AFTER DEVELOPMENT?
_____ FT OR DRY
 - 2) OTHER MEASUREMENTS:
 DATE _____, _____ FT FROM T. ST. PIPE
 DATE _____, _____ FT FROM T. ST. PIPE
 DATE _____, _____ FT FROM T. ST. PIPE
 DATE _____, _____ FT FROM T. ST. PIPE

WELL NO. MW 13-96 DATE INSTALLED 1/9/96 DRILL RIG HURRICAN

DRILLER TOM KALINOWSKI DRILL CREW CHRIS POWELL & GREG FOX

JOB/CLIENT CONSUMERS POWER STS PROJECT NO. 72583

(VERSION 1: 05/90 - M11DRAW)



STS Consultants Ltd.

CLIENT
CONSUMERS POWER
 PROJECT NAME
J.H. CAMPBELL

LOG OF BORING NUMBER **MW-13-96**
 ARCHITECT-ENGINEER


SITE LOCATION
WEST OLIVE, MI

| DEPTH (FT) ELEVATION (FT) | SAMPLE NO. | SAMPLE TYPE | SAMPLE DISTANCE RECOVERY | DESCRIPTION OF MATERIAL | UNCONFINED COMPRESSIVE STRENGTH TONS/FT. ² | | | | |
|------------------------------|------------|-------------|-----------------------------|---|--|-----------------|----------------|----|----|
| | | | | | 1 | 2 | 3 | 4 | 5 |
| | | | | | PLASTIC LIMIT x | WATER CONTENT x | LIQUID LIMIT x | | |
| | | | | | ⊗ | ● | △ | | |
| SURFACE ELEVATION | | | | | 10 | 20 | 30 | 40 | 50 |
| | | | | | STANDARD PENETRATION BLOWS/FT. | | | | |
| | | | | | 10 | 20 | 30 | 40 | 50 |
| | 1 | CS | | Organic topsoil, little fine to medium sand - brown - moist. (Pt) | | | | | |
| 2.5 | 1A | CS | | Clayey silt, little fine to medium sand - brown - soft - moist to wet. (ML) | | | | | |
| 5.0 | 2 | CS | | | | | | | |
| 7.5 | 2A | CS | | Clayey silt, trace fine sand - gray - very stiff - moist. (ML) | | | | | |
| 10.0 | 3 | CS | | | | | | | |
| 12.0 | | | | END OF BORING Boring advanced with hydraulic push techniques. Monitoring Well installed. Screen set from 5.5' to 8.0'. CS = Continuous Sampler | | | | | |

The stratification lines represent the approximate boundary lines between soil types: in-situ, the transition may be gradual.

| | | | | | | |
|----|------------------|----------|------------------|--------------|------------|-------------------|
| WL | 6.5 ft | WS OR WS | BORING STARTED | 01/09/96 | STS OFFICE | Lansing-07 |
| WL | BCR | ACR | BORING COMPLETED | 01/09/96 | ENTERED BY | SHEET NO. 1 OF 1 |
| WL | 6.5 ft @ 1 hr AB | | RIG/FOREMAN | GEOPROBE/GHF | APP'D BY | STS JOB NO. 72583 |
| | | | | | DAP | |
| | | | | | JSM | |

STS Field Well Installation Diagram



- 1) TYPE OF PIPE
PVC, GALVANIZED, STAINLESS, OTHER _____
- 2) TYPE OF PIPE JOINTS
BELLED, COUPLINGS, THREADED, OTHER _____
- 3) TYPE OF WELL SCREEN
PVC, GALVANIZED, STAINLESS, OTHER _____
- 4) SCREEN SIZE 5'
- 5) INSTALLED PROTECTOR PIPE W/LOCK? YES OR NO
- 6) WAS SOLVENT USED? YES OR NO
- 7) WAS DRILLING MUD USED?
SOLID AUGER, HOLLOW STEM AUGER, WATER REVERT, BENTONITE
- 8) DID STANDPIPE COME UP WHEN CASING WAS PULLED?
YES OR NO
- 9) HOW WAS WELL DEVELOPED?
BAILING, PUMPING, SURGING, COMPRESSED AIR
- 10) TIME SPENT FOR WELL DEVELOPMENT
5 MIN., 15 MIN., 30 MIN, OTHER _____
- 11) APPROXIMATE WATER VOLUME REMOVED OR ADDED?
5 GAL, 10 GAL, 15 GAL, OTHER _____
- 12) WATER CLARITY BEFORE DEVELOPMENT
CLEAR, TURBID, OPAQUE
- 13) WATER CLARITY AFTER DEVELOPMENT
CLEAR, TURBID, OPAQUE
- 14) DID THE WATER SMELL? YES OR NO
- 15) WATER LEVEL SUMMARY
 - 1) DEPTH FROM T. STANDPIPE AFTER DEVELOPMENT?
_____ FT OR DRY
 - 2) OTHER MEASUREMENTS:
DATE _____, _____ FT FROM T. ST. PIPE
DATE _____, _____ FT FROM T. ST. PIPE
DATE _____, _____ FT FROM T. ST. PIPE
DATE _____, _____ FT FROM T. ST. PIPE

WELL NO. MW 14-96 DATE INSTALLED 1-9-96 DRILL RIG HURRICANE

DRILLER TOM KALINOWSKI DRILL CREW CHRIS POWELL & GREG FOX

JOB/CLIENT CONSUMERS POWER CO. STS PROJECT NO. 72583



Consultants Ltd.

CLIENT
CONSUMERS POWER
PROJECT NAME
J.H. CAMPBELL

LOG OF BORING NUMBER MW-14-96
ARCHITECT-ENGINEER

SITE LOCATION
WEST OLIVE, MI

| DEPTH (FT) ELEVATION (FT) | SAMPLE NO. | SAMPLE TYPE | SAMPLE DISTANCE RECOVERY | DESCRIPTION OF MATERIAL | UNCONFINED COMPRESSIVE STRENGTH TONS/FT. ² | | | | |
|------------------------------|------------|-------------|-----------------------------|---|--|-------------------------|-------------------|-----------|----|
| | | | | | 1 | 2 | 3 | 4 | 5 |
| SURFACE ELEVATION | | | | | PLASTIC LIMIT x | WATER CONTENT x | LIQUID LIMIT x | | |
| | | | | | x | ● | △ | | |
| | | | | | 10 | 20 | 30 | 40 | 50 |
| | | | | | ⊗ | STANDARD PENETRATION | | BLOWS/FT. | |
| | | | | | 10 | 20 | 30 | 40 | 50 |
| | 1 | CS | | Organic topsoil, little fine to medium sand - brown - loose - moist. (Pt) | | | | | |
| 2.5 | 1A | CS | | Fine to medium sand - brown - medium dense - moist. (SP) | | | | | |
| 3.0 | | | | | | | | | |
| | 2 | CS | | | | | | | |
| 7.5 | | | | | | | | | |
| | 3 | CS | | | | | | | |
| 10.0 | | | | END OF BORING Boring advanced using hydraulic push techniques. Monitoring Well installed. Screen set from 6.4' to 8.9'. CS = Continuous Sampler | | | | | |

→ The stratification lines represent the approximate boundary lines between soil types: in-situ, the transition may be gradual.

| | | | | | | |
|----|------------------|----------|------------------|--------------|------------|-------------------|
| WL | 7.2 ft | WS OR WS | BORING STARTED | 01/09/96 | STS OFFICE | Lansing-07 |
| WL | BCR | ACR | BORING COMPLETED | 01/09/96 | ENTERED BY | SHEET NO. 1 OF 1 |
| WL | 7.2 ft @ 1 hr AB | | RIG/FOREMAN | GEOPROBE/GHF | APP'D BY | STS JOB NO. 72583 |
| | | | | | JSM | |

Appendix C November 2018 Assessment Monitoring Data Summary



1540 Eisenhower Place
Ann Arbor, MI 48108

734.971.7080 PHONE
734.971.9022 FAX

www.trcsolutions.com

March 14, 2019

Bethany Swanberg
Environmental Services – Landfill Operations Compliance
Consumers Energy Company
1945 W. Parnall Road
Jackson, MI 49201

Subject: November 2018 Assessment Monitoring Data Summary and Statistical Evaluation, Consumers Energy, JH Campbell Site, Bottom Ash Pond Units 1-2 North and 1-2 South CCR Unit

Dear Ms. Swanberg:

Consumers Energy Company (CEC) is continuing semiannual assessment monitoring in accordance with §257.95 of the CCR Rule¹ for the JH Campbell Power Plant (JHC) Bottom Ash Pond Unit 1-2 North and 1-2 South (collectively Unit 1-2) located in West Olive, Michigan. During the statistical evaluation of the initial assessment monitoring event, arsenic was present in one or more downgradient monitoring wells at statistically significant levels exceeding the Groundwater Protection Standard (GWPS). Therefore, CEC will initiate an Assessment of Corrective Measures (ACM) within 90 days from when the Appendix IV exceedance was determined (no later than April 14, 2019). As discussed in the *2018 Annual Groundwater Monitoring Report (2018 Annual Report)* (TRC, January 2019), prepared by TRC on behalf of CEC, the second semiannual assessment monitoring event was conducted in November 2018, but laboratory analysis and data quality review were ongoing as of the writing of the 2018 Annual Report. Therefore, the summary of the November 2018 groundwater data would be prepared under separate cover after laboratory analysis is complete and results have been reviewed for usability. This letter report has been prepared to provide the summary of the November 2018 assessment groundwater monitoring results, data quality review, and statistical data evaluation, in addition to December 2018 groundwater monitoring results from several newly installed monitoring wells.

Assessment Monitoring Sampling Summary

TRC conducted the second semiannual assessment monitoring event at Unit 1-2 in accordance with the *JH Campbell Monitoring Program Sample Analysis Plan (SAP)* (ARCADIS, 2016). The second semiannual

¹ USEPA final rule for the regulation and management of Coal Combustion Residuals (CCR) under the Resource Conservation and Recovery Act (RCRA) published April 17, 2015, as amended per Phase One, Part One of the CCR Rule (83 FR 36435).

assessment monitoring event was performed on November 12 through November 16, 2018. Monitoring wells JHC-MW-15001 through JHC-MW-15005 and background monitoring wells JHC-MW-15023 through JHC-MW-15028 were sampled during this monitoring event. The locations of the monitoring wells are depicted on Figure 1. As discussed in the 2018 Annual Report, downgradient monitoring well JHC-MW-15004 had been decommissioned during CCR removal activities on June 14, 2018, and was not sampled in November 2018. Given that groundwater flow changes have occurred such that JHC-MW-15001 is located hydraulically upgradient of Unit 1-2, JHC-MW-15002 and JHC-MW-15003 are predominately side gradient, and JHC-MW-15004 has been removed, additional downgradient monitoring wells have been installed at Unit 1-2 and are being used to reassess the monitoring well network, as discussed below.

TRC personnel collected static water level measurements from the JHC Unit 1-2 CCR Unit well network. Static water elevation data are summarized in Table 1 and groundwater elevation data are shown on Figure 2. Monitoring wells were purged with peristaltic pumps or submersible pumps utilizing low-flow sampling methodology. Field parameters were stabilized at each monitoring well prior to collecting groundwater samples. Field parameters for each monitoring well are summarized in Table 2.

The groundwater samples were analyzed by Pace Analytical Services, LLC (Pace) for Appendix III and IV constituents during the event in accordance with the SAP. The analytical results from background monitoring wells are summarized in Table 3, and the analytical results for the downgradient monitoring wells are summarized in Table 4.

Due to the cessation of hydraulic loading to Unit 1-2 and Bottom Ash Ponds 3 North and 3 South (collectively Unit 3), the groundwater flow direction changed significantly from the previous baseline and assessment monitoring events. In response, as documented in the 2018 Annual Report, CEC installed five new downgradient wells on December 3 through December 5, 2018 to reassess groundwater flow and ensure sufficient wells were appropriately located to assess groundwater quality downgradient from the Unit 1-2 and Unit 3. JHC-MW-18001 through JHC-MW-18003 were installed on the west and southwest edges of former Unit 3 and JHC-MW-18004 and JHC-MW-18005 were installed on the south and southwest edges of the former Unit 1-2 (as shown on Figure 1). The 2018 wells were sampled for Appendix III and Appendix IV constituents on December 7 through December 12, 2018. The summary of data collected at the newly installed monitoring wells is included in Attachment A. After groundwater flow patterns in the immediate vicinity of the CCR unit have equilibrated and have been confirmed, data collected from the new monitoring wells will be used to determine which monitoring wells are appropriately positioned to assess groundwater quality downgradient from the Unit 1-2 CCR Unit.



Groundwater Flow Rate and Direction

Groundwater elevation data collected during the semiannual assessment monitoring event were generally similar to data collected previously in the background, detection monitoring events, and previous assessment monitoring events. The data showed that groundwater within the uppermost aquifer generally flows to the south-southeast across the Site, with a southwesterly groundwater flow component on the western edge of the Site. The groundwater mounding previously observed in the immediate vicinity of Unit 1-2 and Unit 3 is no longer apparent subsequent to completing decommissioning activities at both units in September and October 2018, respectively. Slight mounding is still observed in the vicinity of Pond A as groundwater continues to equilibrate in response to permanent discontinuation of hydraulic loading in June 2018. Groundwater elevations measured across the Site during the November 2018 sampling event are provided on Table 1 and were used to construct the groundwater contour map provided on Figure 2.

The figure shows that current site-wide groundwater flow is generally consistent with previous monitoring events since the background sampling events commenced in December 2015. Groundwater flow in the immediate vicinity of Unit 1-2 is predominately toward the south, consistent with the April and June 2018 assessment monitoring events. The average hydraulic gradient throughout the Site during the November 2018 event is estimated at 0.0039 ft/ft. The gradient was calculated using the following well pairs: JHC-MW-15029/JHC-MW-15030, JHC-MW-15029/JHC-MW-15005, JHC-MW-15019/JHC-MW-15035 and JHC-MW-15023/JHC-MW-15037 (Figure 1). Using the mean hydraulic conductivity of 62 ft/day (ARCADIS, 2016) and an assumed effective porosity of 0.4, the estimated average seepage velocity is approximately 0.61 ft/day or 220 ft/year for the November 2018 event.

While the general overall groundwater flow direction measured across the JHC site during these assessment monitoring events is similar to that identified in previous monitoring rounds, groundwater flow changes have occurred in the immediate vicinity of Unit 1-2 as a result of permanent discontinued hydraulic loading and completion of pond deconstruction activities (including CCR removal) at Unit 1-2. Since hydraulic loading has been discontinued, the groundwater flow is predominantly toward the south instead of radially outward. The initial data collected from the newly installed wells indicates that they are in the downgradient direction, while JHC-MW-15001 is upgradient and JHC-MW-15002 and JHC-MW-15003 are predominately side gradient of groundwater flow from Unit 1-2 (Attachment A Figure A1). As such, the Unit 1-2 groundwater monitoring system is in the process of being re-evaluated and groundwater flow conditions are being confirmed using the data from the new wells, and will be re-established, as appropriate, to assess groundwater quality downgradient from the Unit 1-2 CCR Unit.

Data Quality

Analytical data were found to be usable for assessment monitoring and were generally consistent with previous sampling events. The Data Quality Reviews are included as Attachment B.

Assessment Monitoring Statistical Evaluation

Following the second semiannual assessment monitoring event sampling event, the compliance well groundwater concentrations for Appendix IV constituents were compared to the GWPSs to determine if a statistically significant exceedance had occurred in accordance with §257.95. Consistent with the *Unified Guidance*², the preferred method for comparisons to a fixed standard are confidence limits. An exceedance of the standard occurs when the 99 percent lower confidence level of the downgradient data exceeds the GWPS. GWPSs were established in accordance with §257.95(h), as detailed in the October 15, 2018 *Groundwater Protection Standards* technical memorandum, which was also included in 2018 Annual Report (TRC, January 2019).

Confidence intervals were established per the statistical methods detailed in the *Statistical Evaluation of November 2018 Assessment Monitoring Sampling Event* technical memorandum provided in Attachment C. For each Appendix IV constituent, the concentrations were first compared directly to the GWPSs. Constituent-well combinations that included a direct exceedance of the GWPSs were retained for further statistical analysis using confidence limits.

The statistical evaluation of the second semiannual assessment monitoring event data indicates that the following constituent is present at statistically significant levels exceeding the GWPS in downgradient monitoring wells at the JHC Unit 1-2 CCR unit:

| <u>Constituent</u> | <u>GWPS</u> | <u># Downgradient Wells Observed</u> |
|--------------------|-------------|--------------------------------------|
| Arsenic | 10 ug/L | 2 of 4 |

In addition, the December 2018 concentrations of Appendix III and Appendix IV constituents at the new downgradient wells are below the GWPSs (using direct comparison), with several Appendix III and Appendix IV concentrations above the background UTLs, as shown in Attachment A Table A3. These results are consistent with the results of the initial assessment monitoring data statistical evaluation and CEC will continue to initiate an assessment of corrective measures by April 14, 2019, per §257.95(g). CEC will continue executing the self-implementing groundwater compliance schedule in conformance with §257.90 - §257.98.


² USEPA. 2009. *Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities, Unified Guidance*. Office of Conservation and Recovery. EPA 530/R-09-007.

Ms. Swanberg
Consumers Energy Company
March 14, 2019
Page 5

Sincerely,

TRC


Graham Crockford
Program Manager


Sarah B. Holmstrom
Hydrogeologist/Project Manager

Attachments

Table 1. Summary of Groundwater Elevation Data
Table 2. Summary of Field Parameter Results
Table 3. Summary of Background Wells Groundwater Sampling Results (Analytical)
Table 4. Summary of Groundwater Sampling Results (Analytical)
Table 5. Summary of Groundwater Protection Standard Exceedances – November 2018

Figure 1. Monitoring Well Network and Site Plan
Figure 2. Groundwater Contour Map – November 2018

Attachment A Unit 1-2 December 2018 Groundwater Data Summary
Attachment B Data Quality Reviews
Attachment C Statistical Evaluation of November 2018 Assessment Monitoring Sampling Event

cc: Brad Runkel, Consumers Energy
Harold D. Register, Jr., Consumers Energy
Central Files

Tables

Table 1
Summary of Groundwater Elevation Data – November 2018
JH Campbell – RCRA CCR Monitoring Program
West Olive, Michigan

| Well Location | Ground Surface Elevation (ft) | TOC Elevation (ft) | Geologic Unit of Screen Interval | Screen Interval Elevation (ft) | November 12, 2018 | | |
|-----------------------------|-------------------------------|--------------------|----------------------------------|--------------------------------|--------------------------|----------------------------|--|
| | | | | | Depth to Water (ft BTOC) | Groundwater Elevation (ft) | |
| Background | | | | | | | |
| JHC-MW-15023 | 617.01 | 619.98 | Sand | 603.0 to 593.0 | 16.28 | 603.70 | |
| JHC-MW-15024 | 613.79 | 616.62 | Sand | 606.8 to 596.8 | 11.42 | 605.20 | |
| JHC-MW-15025 | 614.14 | 617.17 | Sand | 607.1 to 597.1 | 10.60 | 606.57 | |
| JHC-MW-15026 | 615.09 | 618.04 | Sand | 607.1 to 597.1 | 12.35 | 605.69 | |
| JHC-MW-15027 | 614.77 | 617.30 | Sand | 604.8 to 594.8 | 12.76 | 604.54 | |
| JHC-MW-15028 | 611.02 | 613.80 | Sand | 603.0 to 593.0 | 12.48 | 601.32 | |
| JHC-MW-15029 | 608.08 | 610.95 | Sand | 600.1 to 590.1 | 9.78 | 601.17 | |
| JHC-MW-15030 | 604.05 | 607.17 | Sand | 600.1 to 590.1 | 8.25 ⁽¹⁾ | 598.92 | |
| Unit 1N, 1S, 2N, 2S | | | | | | | |
| JHC-MW-15001 | 607.02 | 609.53 | Sand | 603.5 to 598.5 | 10.90 | 598.63 | |
| JHC-MW-15002 ⁽²⁾ | 618.18 | 621.27 | Sand | 590.2 to 580.2 | 23.18 | 598.09 | |
| JHC-MW-15003 ⁽²⁾ | 623.16 | 627.20 | Sand | 595.2 to 585.2 | 31.78 | 595.42 | |
| JHC-MW-15005 ⁽²⁾ | 606.22 | 609.99 | Sand | 579.2 to 569.2 | 17.75 | 592.24 | |
| Unit 3N, 3S | | | | | | | |
| JHC-MW-15013 | 632.40 | 635.25 | Sand | 604.4 to 594.4 | 33.90 | 601.35 | |
| JHC-MW-15015 | 632.46 | 635.20 | Sand | 604.5 to 594.5 | 33.20 | 602.00 | |
| JHC-MW-15016 | 631.81 | 632.52 | Sand | 603.8 to 593.8 | 30.56 ⁽¹⁾ | 601.96 | |
| Landfill | | | | | | | |
| JHC-MW-15017 | 613.69 | 616.61 | Sand | 603.7 to 593.7 | 13.85 | 602.76 | |
| JHC-MW-15018 | 614.26 | 617.02 | Sand | 604.3 to 594.3 | 14.61 | 602.41 | |
| JHC-MW-15019 | 609.81 | 612.86 | Sand | 603.8 to 593.8 | 11.04 | 601.82 | |
| JHC-MW-15022 | 620.92 | 623.79 | Sand | 597.9 to 587.9 | 27.89 | 595.90 | |
| JHC-MW-15031 | 632.94 | 635.87 | Sand | 599.9 to 589.9 | 42.32 | 593.55 | |
| JHC-MW-15032 | 611.32 | 614.29 | Sand | 598.3 to 588.3 | 16.06 | 598.23 | |
| JHC-MW-15033 | 618.08 | 620.99 | Sand | 602.1 to 592.1 | 20.79 | 600.20 | |
| JHC-MW-15034 | 612.90 | 615.97 | Sand | 601.9 to 591.9 | 14.57 | 601.40 | |
| JHC-MW-15035 | 632.53 | 634.28 | Sand | 599.5 to 589.5 | 39.60 | 594.68 | |
| JHC-MW-15036 | 617.94 | 618.34 | Sand | 597.9 to 587.9 | 25.92 | 592.42 | |
| JHC-MW-15037 | 614.28 | 616.06 | Sand | 591.3 to 586.3 | 24.45 | 591.61 | |
| Pond A | | | | | | | |
| JHC-MW-15006 | 624.74 | 627.58 | Sand | 599.7 to 589.7 | 33.36 | 594.22 | |
| JHC-MW-15007 | 624.82 | 627.70 | Sand | 602.8 to 592.8 | 33.75 | 593.95 | |
| JHC-MW-15008 | 632.43 | 635.30 | Sand | 604.4 to 594.4 | 40.37 | 594.93 | |
| JHC-MW-15009 | 632.33 | 635.32 | Sand | 602.3 to 592.3 | 41.55 | 593.77 | |
| JHC-MW-15010 | 632.55 | 635.57 | Sand | 602.6 to 592.6 | 41.00 | 594.57 | |
| JHC-MW-15011 | 627.71 | 630.83 | Sand | 600.7 to 590.7 | 37.70 | 593.13 | |

Notes:

Survey conducted by Nederveld, November 2015, October 2018, and December 2018.

Elevation in feet relative to North American Vertical Datum 1988 (NAVD 88).

TOC: Top of well casing.

ft BTOC: Feet below top of well casing.

(1) - The static water levels for JHC-MW-15016 and JHC-MW-15030 were collected on November 15, 2018.

(2) - Surface elevation and TOC resurveyed December 2018 post construction activities.

Table 2
 Summary of Field Parameter Results – November 2018
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location | Sample Date | Dissolved Oxygen (mg/L) | Oxidation Reduction Potential (mV) | pH (SU) | Specific Conductivity (umhos/cm) | Temperature (°C) | Turbidity (NTU) |
|-------------------|-------------|----------------------------|---------------------------------------|------------|-------------------------------------|---------------------|--------------------|
| Background | | | | | | | |
| JHC-MW-15023 | 11/13/2018 | 0.86 | 30.3 | 6.1 | 75 | 9.8 | 6.9 |
| JHC-MW-15024 | 11/13/2018 | 0.97 | 18.7 | 7.1 | 135 | 9.8 | 6.0 |
| JHC-MW-15025 | 11/13/2018 | 2.60 | 30.7 | 7.9 | 145 | 9.7 | 5.9 |
| JHC-MW-15026 | 11/13/2018 | 6.50 | 129.8 | 6.8 | 86 | 9.6 | 3.8 |
| JHC-MW-15027 | 11/13/2018 | 5.90 | 148.8 | 6.4 | 79 | 9.2 | 12.4 |
| JHC-MW-15028 | 11/13/2018 | 5.81 | 17.5 | 7.8 | 82 | 11.9 | 7.0 |
| Unit 1/2 | | | | | | | |
| JHC-MW-15001 | 11/13/2018 | 0.80 | -23.2 | 6.3 | 464 | 14.8 | 3.7 |
| JHC-MW-15002 | 11/15/2018 | 9.80 | 89.8 | 8.0 | 361 | 8.8 | 5.8 |
| JHC-MW-15003 | 11/15/2018 | 0.50 | -106.1 | 8.7 | 948 | 14.6 | 3.9 |
| JHC-MW-15005 | 11/15/2018 | 2.33 | 41.2 | 7.5 | 645 | 17.8 | 2.3 |

Notes:

mg/L - Milligrams per Liter.

mV - Millivolts.

SU - Standard units

umhos/cm - Micromhos per centimeter.

°C - Degrees Celsius.

NTU - Nephelometric Turbidity Unit.

Table 3
 Summary of Background Well Groundwater Sampling Results (Analytical): November 2018
 JH Campbell Background – RCRA CCR Monitoring Program
 West Olive, Michigan

| | | | | | | Sample Location: | JHC-MW-15023 | JHC-MW-15024 | JHC-MW-15025 | JHC-MW-15026 | JHC-MW-15027 | JHC-MW-15028 |
|------------------------|-------|--------------------|------------------|---------------------|---------------------|------------------|--------------|--------------|--------------|--------------|--------------|--------------|
| | | | | | | Sample Date: | 11/13/2018 | 11/13/2018 | 11/13/2018 | 11/13/2018 | 11/13/2018 | 11/13/2018 |
| Constituent | Unit | EPA MCL | MI Residential* | MI Non-Residential* | MI GSI [^] | Background | | | | | | |
| Appendix III | | | | | | | | | | | | |
| Boron | ug/L | NC | 500 | 500 | 7,200 | 46.9 | < 20.0 | 23.9 | < 20.0 | < 20.0 | < 20.0 | < 20.0 |
| Calcium | mg/L | NC | NC | NC | 500 | 15.6 | 28.0 | 16.7 | 9.2 | 9.6 | 11.4 | 11.4 |
| Chloride | mg/L | 250** | 250 | 250 | 500 | 10.7 | 17.7 | 12.8 | 7.0 | 5.2 | 4.0 | 4.0 |
| Fluoride | ug/L | 4,000 | NC | NC | NC | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250** | 250 | 250 | 500 | 12.2 | 7.0 | 8.6 | 8.0 | 9.0 | 4.9 | 4.9 |
| Total Dissolved Solids | mg/L | 500** | 500 | 500 | 500 | 80 | 180 | 94 | < 50.0 | 54 | 50 | 50 |
| pH, Field | SU | 6.5 - 8.5** | 6.5 - 8.5 | 6.5 - 8.5 | 6.5 - 9.0 | 6.1 | 7.1 | 7.9 | 6.8 | 6.4 | 7.8 | 7.8 |
| Appendix IV | | | | | | | | | | | | |
| Antimony | ug/L | 6 | 6.0 | 6.0 | 130 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Arsenic | ug/L | 10 | 10 | 10 | 10 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Barium | ug/L | 2,000 | 2,000 | 2,000 | 820 | 21.7 | 16.2 | 14.1 | 10.5 | 30.6 | 5.5 | 5.5 |
| Beryllium | ug/L | 4 | 4.0 | 4.0 | 18 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | 5.0 | 5.0 | 3.5 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | 100 | 100 | 11 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Cobalt | ug/L | NC | 40 | 100 | 100 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 |
| Fluoride | ug/L | 4,000 | NC | NC | NC | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 4.0 | 4.0 | 39 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 170 | 350 | 440 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 |
| Mercury | ug/L | 2 | 2.0 | 2.0 | 0.20# | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 73 | 210 | 3,200 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 |
| Radium-226 | pCi/L | NC | NC | NC | NC | < 0.531 | 1.21 | < 0.677 | 0.615 | < 0.695 | < 0.688 | < 0.688 |
| Radium-228 | pCi/L | NC | NC | NC | NC | < 0.894 | < 1.03 | < 0.862 | < 1.08 | 0.961 | < 1.05 | < 1.05 |
| Radium-226/228 | pCi/L | 5 | NC | NC | NC | < 1.43 | 1.76 | < 1.54 | < 1.25 | 1.61 | < 1.74 | < 1.74 |
| Selenium | ug/L | 50 | 50 | 50 | 5 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Thallium | ug/L | 2 | 2.0 | 2.0 | 3.7 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 |

Notes:

ug/L - micrograms per liter.

mg/L - milligrams per liter.

SU - standard units; pH is a field parameter.

pCi/L - picocuries per liter.

MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April 2012.

NC - no criteria.

* - Michigan Part 201 Generic Drinking Water Cleanup Criteria, December 30, 2013.

** - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April 2012.

[^] - Michigan Part 201 Groundwater Surface Water Interface (GSI) Criteria. Hardness-dependent criteria calculated using site-specific hardness of 180 mg CaCO₃/L as measured at surface water sample SW-01 collected on April 9, 2018 from the Pigeon River. Chromium GSI criterion based on hexavalent chromium per footnote {H}.

- If detected above 0.20 ug/L, further evaluation of low-level mercury may be necessary to evaluate the GSI pathway per Michigan Part 201 and MDEQ policy and procedure 09-014 dated June 20, 2012.

BOLD value indicates an exceedance of one or more of the listed criteria.

RED value indicates an exceedance of the MCL.

All metals were analyzed as total unless otherwise specified.

Table 4
 Summary of Groundwater Sampling Results (Analytical): November 2018
 JH Campbell 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| | | | | | | Sample Location: | JHC-MW-15001 | JHC-MW-15002 | JHC-MW-15003 | JHC-MW-15005 |
|------------------------|-------|--------------------|------------------|---------------------|---------------------|------------------|--------------|--------------|--------------|--------------|
| | | | | | | Sample Date: | 11/13/2018 | 11/15/2018 | 11/15/2018 | 11/15/2018 |
| Constituent | Unit | EPA MCL | MI Residential* | MI Non-Residential* | MI GSI [^] | downgradient | | | | |
| Appendix III | | | | | | | | | | |
| Boron | ug/L | NC | 500 | 500 | 7,200 | 146 | 1,470 | 1,120 | 1,450 | |
| Calcium | mg/L | NC | NC | NC | 500 | 72.1 | 41.9 | 115 | 61.9 | |
| Chloride | mg/L | 250** | 250 | 250 | 500 | 2.7 | 19.3 | 16.3 | 30.6 | |
| Fluoride | ug/L | 4,000 | NC | NC | NC | < 1,000 | < 1,000 | < 1,000 | < 1,000 | |
| Sulfate | mg/L | 250** | 250 | 250 | 500 | 59.1 | 95.2 | 294 | 133 | |
| Total Dissolved Solids | mg/L | 500** | 500 | 500 | 500 | 310 | 222 | 644 | 334 | |
| pH, Field | SU | 6.5 - 8.5** | 6.5 - 8.5 | 6.5 - 8.5 | 6.5 - 9.0 | 6.3 | 8.0 | 8.7 | 7.5 | |
| Appendix IV | | | | | | | | | | |
| Antimony | ug/L | 6 | 6.0 | 6.0 | 130 | < 1.0 | < 1.0 | 2.0 | 5.1 | |
| Arsenic | ug/L | 10 | 10 | 10 | 10 | 12.7 | 60.5 | 8.1 | 1.2 | |
| Barium | ug/L | 2,000 | 2,000 | 2,000 | 820 | 84.9 | 18.4 | 113 | 149 | |
| Beryllium | ug/L | 4 | 4.0 | 4.0 | 18 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | |
| Cadmium | ug/L | 5 | 5.0 | 5.0 | 3.5 | < 0.20 | < 0.20 | 1.7 | < 0.20 | |
| Chromium | ug/L | 100 | 100 | 100 | 11 | < 1.0 | < 1.0 | 13.6 | < 1.0 | |
| Cobalt | ug/L | NC | 40 | 100 | 100 | < 6.0 | < 6.0 | 23.6 | < 6.0 | |
| Fluoride | ug/L | 4,000 | NC | NC | NC | < 1,000 | < 1,000 | < 1,000 | < 1,000 | |
| Lead | ug/L | NC | 4.0 | 4.0 | 39 | < 1.0 | < 1.0 | 3.3 | < 1.0 | |
| Lithium | ug/L | NC | 170 | 350 | 440 | < 10 | 68 | < 10 | 28 | |
| Mercury | ug/L | 2 | 2.0 | 2.0 | 0.20# | < 0.20 | < 0.20 | < 0.20 | < 0.20 | |
| Molybdenum | ug/L | NC | 73 | 210 | 3,200 | 13.3 | 9.2 | 65.3 | 222 | |
| Radium-226 | pCi/L | NC | NC | NC | NC | < 0.755 | < 1.09 | < 0.579 | < 0.461 | |
| Radium-228 | pCi/L | NC | NC | NC | NC | < 0.879 | 1.04 | < 0.657 | 0.967 | |
| Radium-226/228 | pCi/L | 5 | NC | NC | NC | < 1.63 | < 1.70 | < 1.24 | 1.41 | |
| Selenium | ug/L | 50 | 50 | 50 | 5 | < 1.0 | 2.5 | 28.6 | 158 | |
| Thallium | ug/L | 2 | 2.0 | 2.0 | 3.7 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | |

Notes:

ug/L - micrograms per liter.

mg/L - milligrams per liter.

SU - standard units; pH is a field parameter.

pCi/L - picocuries per liter.

MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April 2012.

NC - no criteria.

* - Michigan Part 201 Generic Drinking Water Cleanup Criteria, December 30, 2013.

** - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April 2012.

[^] - Michigan Part 201 Groundwater Surface Water Interface (GSI) Criteria. Hardness-dependent criteria calculated using

site-specific hardness of 180 mg CaCO₃/L as measured at surface water sample SW-01 collected on April 9, 2018

from the Pigeon River. Chromium GSI criterion based on hexavalent chromium per footnote {H}.

- If detected above 0.20 ug/L, further evaluation of low-level mercury may be necessary to evaluate the GSI pathway

per Michigan Part 201 and MDEQ policy and procedure 09-014 dated June 20, 2012.

BOLD value indicates an exceedance of one or more of the listed criteria.

RED value indicates an exceedance of the MCL.

All metals were analyzed as total unless otherwise specified.

Table 5
 Summary of Groundwater Protection Standard Exceedances – November 2018
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Constituent | Units | GWPS | JHC-MW-15001 | | JHC-MW-15002 | | JHC-MW-15003 | | JHC-MW-15005 | |
|-------------|-------|------|--------------|-----|--------------|-----|--------------|-----|--------------|-----|
| | | | LCL | UCL | LCL | UCL | LCL | UCL | LCL | UCL |
| Arsenic | ug/L | 10 | 0.78 | 7.1 | 33 | 130 | 11 | 31 | NA | NA |
| Lithium | ug/L | 40 | NA | NA | 3.8 | 35 | NA | NA | 28 | 51 |
| Molybdenum | ug/L | 100 | NA | NA | NA | NA | NA | NA | 10 | 222 |
| Selenium | ug/L | 50 | NA | NA | NA | NA | NA | NA | 10 | 370 |
| Thallium | ug/L | 2 | NA | NA | NA | NA | NA | NA | 2 | 5.8 |

Notes:

ug/L - micrograms per Liter.

NA - Not Applicable; well/parameter pair did not directly exceed the GWPS and was not included in further analysis.

GWPS - Groundwater Protection Standard as established in TRC's Technical Memorandum dated October 15, 2018.

UCL - Upper Confidence Limit ($\alpha = 0.01$) of the downgradient data set.

LCL - Lower Confidence Limit ($\alpha = 0.01$) of the downgradient data set.

Indicates a statistically significant exceedance of the GWPS. An exceedance occurs when the LCL is greater than the GWPS.

Figures



LEGEND

- BACKGROUND MONITORING WELL
- DOWNGRADIANT BOTTOM ASH POND 1/2 N/S MONITORING WELL
- DOWNGRADIANT BOTTOM ASH POND 3 N/S MONITORING WELL
- DOWNGRADIANT LANDFILL MONITORING WELL
- DOWNGRADIANT POND A MONITORING WELL
- MONITORING WELL (STATIC WATER LEVEL ONLY)
- DECOMMISSIONED MONITORING WELL
- NEW DOWNGRADIANT BOTTOM ASH POND 1/2 N/S MONITORING WELL (2018)
- NEW DOWNGRADIANT BOTTOM ASH POND 3 N/S MONITORING WELL (2018)

- NOTES**
1. BASE MAP IMAGERY FROM USDA – NATIONAL AGRICULTURE IMAGERY PROGRAM, 7/20/2016.
 2. WELL LOCATIONS SURVEYED BY NEDERVELD ON 11/25/2015.
 3. MONITORING WELL DECOMMISSIONED NOVEMBER 13, 2017.
 4. MONITORING WELL DECOMMISSIONED JUNE 14, 2018.
 5. MONITORING WELL DECOMMISSIONED OCTOBER 10, 2018.
 6. JHC-MW-1800X MONITORING WELLS INSTALLED IN DECEMBER 2018.

0 600 1,200
Feet

1" = 600'
1:7,200

PROJECT: CONSUMERS ENERGY COMPANY
JH CAMPBELL POWER PLANT
WEST OLIVE, MICHIGAN


TITLE: **SITE PLAN
WITH CCR MONITORING WELL LOCATIONS**

DRAWN BY: J. PAPEZ PROJ NO.: 290806-001
CHECKED BY: S. HOLMSTROM
APPROVED BY: G. CROCKFORD
DATE: MARCH 2019

FIGURE 1

1540 Eisenhower Place
Ann Arbor, MI 48108-3284
Phone: 734.971.7080
www.trcsolutions.com

FILE NO.: 290806-001-015.mxd





LEGEND

- BACKGROUND MONITORING WELL
- DECOMMISSIONED MONITORING WELL
- DOWNGRADIENT BOTTOM ASH POND 1/2 N/S MONITORING WELL
- DOWNGRADIENT BOTTOM ASH POND 3 N/S MONITORING WELL
- DOWNGRADIENT LANDFILL MONITORING WELL
- MONITORING WELL (STATIC WATER LEVEL ONLY)
- POND A MONITORING WELL
- GROUNDWATER ELEVATION CONTOUR (2' INTERVAL, DASHED WHERE INFERRED)
- (600.97) GROUNDWATER ELEVATION (FEET)

NOTES

1. BASE MAP IMAGERY FROM USDAL-NATIONAL AGRICULTURE IMAGERY PROGRAM, 7/20/2016.
2. WELL LOCATIONS SURVEYED BY NEDERVELD ON 11/25/2015.
3. GROUNDWATER ELEVATIONS DISPLAYED IN FEET RELATIVE TO THE NORTH AMERICAN VERTICAL DATUM OF 1988.
4. MONITORING WELL DECOMMISSIONED NOVEMBER 13, 2017.
5. MONITORING WELL DECOMMISSIONED JUNE 14, 2018.
6. MONITORING WELL DECOMMISSIONED OCTOBER 10, 2018.



| | | | |
|--------------|--------------------|--|------------|
| PROJECT: | | CONSUMERS ENERGY COMPANY JH CAMPBELL POWER PLANT WEST OLIVE, MICHIGAN | |
| TITLE: | | GROUNDWATER CONTOUR MAP NOVEMBER 2018 | |
| DRAWN BY: | S. MAJOR | PROJ NO.: | 322174-001 |
| CHECKED BY: | K. LOWERY | FIGURE 2 | |
| APPROVED BY: | S. HOLMSTROM | | |
| DATE: | MARCH 2019 | | |
| | | 1540 Eisenhower Place Ann Arbor, MI 48108-3284 Phone: 734.971.7080 www.trcsolutions.com | |
| FILE NO.: | 290806-001-019.mxd | | |

Attachment A
Unit 1-2 December 2018 Groundwater Data Summary

Technical Memorandum

Date: March 14, 2019

To: Bethany Swanberg, CEC

cc: Brad Runkel, CEC
JR Register, CEC
Michelle Marion, CEC
Graham Crockford, TRC

From: Sarah Holmstrom, TRC

Project No.: 290806.0000.0000

Subject: CEC: JH Campbell Bottom Ash Pond Unit 1-2 December 2018 Groundwater Data Summary

Project Number: 290806.0000.0000 Ph 1, Task 3

In June 2017, decommissioning of the Unit 3 North at the Consumers Energy Company (CEC) JH Campbell (JHC) Power Plant Site began with recovery of CCR from the pond for beneficial reuse prior to backfilling with clean fill. The above-grade concrete treatment tanks were constructed within the footprint of the Unit 3 North pond area to manage bottom ash and became operational in July 2018. Removal of ash from Unit 1-2 for beneficial reuse began in June 2018 and continued through September 2018. CCR removal at Unit 3 South began in September 2018 and continued through October 2018. In addition, hydraulic loading was ceased at Unit 1-2 and Pond A in June 2018 and the southern portion of Unit 3 in July 2018 (when the concrete tanks were in service). Due to this cessation of hydraulic loading, groundwater flow characteristics in the vicinity of the Units 3 North and 3 South (collectively Unit 3) and Units 1-2 North and 1-2 South (Unit 1-2) bottom ash ponds changed significantly between the initiation of monitoring in accordance with the CCR Rule (December 2015) and the initiation of semiannual assessment monitoring (June 2018).

One of the downgradient monitoring wells (JHC-MW-15004) had been decommissioned on June 14, 2018, to accommodate the CCR removal activities. Following the completion of the CCR removal activities, three additional monitoring wells were installed along the west and southwest edges of JHC Unit 3 and two additional monitoring wells were installed along the south and southwest edges of JHC Unit 1-2 during the week of December 3, 2018 in order to replace the decommissioned well and reassess groundwater flow in the vicinity of JHC Unit 3 and JHC Unit 1-2. As such, the JHC Unit

Technical Memorandum

1-2 groundwater monitoring system is being re-evaluated subsequent to the completion of the CCR removal activities and permanent discontinuation of hydraulic loading. After groundwater flow patterns in the immediate vicinity of the CCR unit have equilibrated post-deconstruction, data collected from the new monitoring wells will be used to determine which monitoring wells are appropriately positioned to assess groundwater quality downgradient from the Unit 1-2 CCR Unit.

This technical memorandum provides a summary of the initial groundwater data collected from the new monitoring wells installed in the vicinity of Unit 1-2 during December 2018.

Groundwater Sampling Summary

TRC collected groundwater samples from the newly installed monitoring wells JHC-MW-18004 and JHC-MW-18006 on December 3 through December 7, 2018 in accordance with the *JH Campbell Monitoring Program Sample Analysis Plan (SAP)* (ARCADIS, 2016).

TRC personnel collected static water level measurements from the three newly installed wells near Unit 3, the two newly installed wells near Unit 1-2, and a subset of preexisting monitoring wells located near Unit 1-2 and Unit 3. Static water elevation data are summarized in Table A1 and groundwater potentiometric elevation data are shown on Figure A1. Monitoring wells were purged with peristaltic pumps or submersible pumps utilizing low-flow sampling methodology. Field parameters were stabilized at each monitoring well prior to collecting groundwater samples. Field parameters for each monitoring well are summarized in Table A2.

The groundwater samples were analyzed for Appendix III and Appendix IV constituents by Pace Analytical Services, LLC (Pace) in accordance with the SAP. The analytical results are summarized in Table A3.

Groundwater Flow Direction

Groundwater elevation data collected during the December 2018 sampling event were generally similar to data collected in November 2018. Groundwater elevations measured across the area of Unit 1-2 and Unit 3 during the December 2018 sampling event are provided in Table A1 and were used to construct a groundwater contour map (Figure A1). The groundwater flow in this area of the site is predominantly toward the west-southwest instead of radially outward from Unit 3, and predominantly toward the south, with a slight southwesterly flow component, in the vicinity of Unit 1-2.

The general flow direction is similar to that identified in April, June and November 2018. JHC-MW-18004 and JHC-MW-18005, located on the southwest and south perimeters of the former Unit 1-2 CCR Unit, are positioned downgradient of the south flow component across Unit 1-2. The initial data collected from the newly installed wells indicates that they are in the downgradient direction, while JHC-MW-15001 is upgradient and JHC-MW-15002 and JHC-MW-15003 are predominately side gradient of groundwater flow from Unit 1-2 (Figure A1). As such, the Unit 1-2 groundwater

Technical Memorandum

monitoring system is in the process of being re-evaluated and groundwater flow conditions are being confirmed using the data from the new wells, and will be re-established, as appropriate, to assess groundwater quality downgradient from the Unit 1-2 CCR Unit.

Data Quality

Analytical data were found to be usable for assessment monitoring. The Data Quality Review for this event is included as Attachment A1.

Analytical Results Summary

Although the groundwater monitoring system is being reassessed while groundwater flow conditions are confirmed, prior to incorporating the new wells into the assessment monitoring well network, the concentrations of the Appendix III and IV constituents in each of the new wells were compared to the potentially relevant criteria in Table A3. Since these wells were just installed in December 2018, adequate background has not been established at these locations to perform statistical evaluation of the data. However, in order to evaluate groundwater quality at the new downgradient monitoring wells in the context of the assessment monitoring program, the results were also compared against the Appendix III upper tolerance limits (UTLs) and Appendix IV groundwater protection standards (GWPSs) previously established for the site. The results from the new wells show several Appendix III and Appendix IV concentrations exceed the background UTLs, but are below the GWPSs (using a direct comparison to the standards).

Once groundwater flow is confirmed, the groundwater monitoring system will be re-established using the new wells in 2019, as appropriate, to assess groundwater quality downgradient from the Unit 1-2 CCR Unit moving forward.

Attachments

| | |
|---------------|--|
| Table A1. | Summary of Groundwater Elevation Data – December 2018 |
| Table A2. | Summary of Field Parameter Results – December 2018 |
| Table A3. | Summary of Groundwater Sampling Results (Analytical) – December 2018 |
| Figure A1. | Groundwater Contour Map – December 2018 |
| Attachment A1 | Data Quality Review |

Technical Memorandum

Tables

Table A1
 Summary of Groundwater Elevation Data – December 2018
 JH Campbell – RCRA CCR Monitoring Program
 West Olive, Michigan

| Well Location | Ground Surface Elevation (ft) | TOC Elevation (ft) | Geologic Unit of Screen Interval | Screen Interval Depth (ft BGS) | | Screen Interval Elevation (ft) | | Borehole Terminus Depth (ft BGS) | Borehole Terminus Elevation (ft) | December 7, 2018 | | | |
|-----------------------------|-------------------------------|-----------------------|----------------------------------|--------------------------------|----|--------------------------------|-------|----------------------------------|----------------------------------|--------------------------|----------------------------|----------------------|--------|
| | | | | | | | | | | Depth to Water (ft BTOC) | Groundwater Elevation (ft) | | |
| Unit 1N, 1S, 2N, 2S | | | | | | | | | | | | | |
| JHC-MW-15002 ⁽¹⁾ | 618.18 | 621.27 ⁽¹⁾ | Sand | 28.0 | to | 38.0 | 590.2 | to | 580.2 | 38.0 | 580.18 | 23.30 | 597.97 |
| JHC-MW-15003 ⁽¹⁾ | 623.16 | 627.20 ⁽¹⁾ | Sand | 28.0 | to | 38.0 | 595.2 | to | 585.2 | 38.0 | 585.16 | 31.89 | 595.31 |
| JHC-MW-15005 ⁽¹⁾ | 606.22 | 609.99 ⁽¹⁾ | Sand | 27.0 | to | 37.0 | 579.2 | to | 569.2 | 40.0 | 566.22 | 17.69 | 592.30 |
| JHC-MW-18004 ⁽²⁾ | 602.92 | 605.72 | Sand | 6.0 | to | 16.0 | 596.9 | to | 586.9 | 16.0 | 586.92 | 11.02 | 594.70 |
| JHC-MW-18005 ⁽²⁾ | 600.30 | 603.16 | Sand | 5.0 | to | 15.0 | 595.3 | to | 585.3 | 15.0 | 585.30 | 9.77 | 593.39 |
| Unit 3N, 3S | | | | | | | | | | | | | |
| JHC-MW-15013 | 632.40 | 635.25 | Sand | 28.0 | to | 38.0 | 604.4 | to | 594.4 | 38.0 | 594.40 | 34.30 | 600.95 |
| JHC-MW-15015 | 632.46 | 635.20 | Sand | 28.0 | to | 38.0 | 604.5 | to | 594.5 | 40.0 | 592.46 | 33.45 | 601.75 |
| JHC-MW-18001 ⁽²⁾ | 609.09 | 611.98 | Sand | 6.0 | to | 16.0 | 603.1 | to | 593.1 | 17.0 | 592.09 | 10.96 ⁽³⁾ | 601.02 |
| JHC-MW-18002 ⁽²⁾ | 605.53 | 608.93 | Sand | 3.5 | to | 13.5 | 602.0 | to | 592.0 | 15.0 | 590.53 | 8.22 ⁽³⁾ | 600.71 |
| JHC-MW-18003 ⁽²⁾ | 605.36 | 608.78 | Sand | 3.5 | to | 13.5 | 601.9 | to | 591.9 | 15.0 | 590.36 | 8.00 | 600.78 |

Notes:

Survey conducted by Nederveld, November 2015, October 2018, and December 2018.

Elevation in feet relative to North American Vertical Datum 1988 (NAVD 88).

TOC: Top of well casing.

ft BTOC: Feet below top of well casing.

(1) - Surface elevation and TOC resurveyed December 2018 due to construction activities.

(2) - JHC-MW-18001, JHC-MW-18002, JHC-MW-18003, JHC-MW-18004 & JHC-MW-18005 were installed on December 3 through December 5, 2018.

(3) - The static water levels for JHC-MW-18001 and JHC-MW-18002 were collected on December 12, 2018.

Table A2
 Summary of Field Parameter Results – November & December 2018
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location | Sample Date | Dissolved Oxygen (mg/L) | Oxidation Reduction Potential (mV) | pH (SU) | Specific Conductivity (umhos/cm) | Temperature (°C) | Turbidity (NTU) |
|-------------------|-------------|----------------------------|---------------------------------------|------------|-------------------------------------|---------------------|--------------------|
| Background | | | | | | | |
| JHC-MW-15023 | 11/13/2018 | 0.86 | 30.3 | 6.1 | 75 | 9.8 | 6.9 |
| JHC-MW-15024 | 11/13/2018 | 0.97 | 18.7 | 7.1 | 135 | 9.8 | 6.0 |
| JHC-MW-15025 | 11/13/2018 | 2.60 | 30.7 | 7.9 | 145 | 9.7 | 5.9 |
| JHC-MW-15026 | 11/13/2018 | 6.50 | 129.8 | 6.8 | 86 | 9.6 | 3.8 |
| JHC-MW-15027 | 11/13/2018 | 5.90 | 148.8 | 6.4 | 79 | 9.2 | 12.4 |
| JHC-MW-15028 | 11/13/2018 | 5.81 | 17.5 | 7.8 | 82 | 11.9 | 7.0 |
| Unit 1/2 | | | | | | | |
| JHC-MW-18004 | 12/7/2018 | 5.90 | 76.0 | 7.0 | 770 | 7.2 | 6.6 |
| JHC-MW-18005 | 12/7/2018 | 1.58 | 90.3 | 8.8 | 604 | 8.2 | 9.6 |

Notes:

mg/L - Milligrams per Liter.

mV - Millivolts.

SU - Standard units

umhos/cm - Micromhos per centimeter.

°C - Degrees Celsius

NTU - Nephelometric Turbidity Unit.

Table A3
 Summary of Groundwater Sampling Results (Analytical): December 2018
 JH Campbell 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| | | | | | | | Sample Location: | JHC-MW-18004 | JHC-MW-18005 |
|------------------------|-------|--------------------|------------------|---------------------|-----------|------------|------------------|--------------|--------------|
| | | | | | | | Sample Date: | 12/7/2018 | 12/7/2018 |
| Constituent | Unit | EPA MCL | MI Residential* | MI Non-Residential* | MI GSI^ | UTL | GWPS | | |
| Appendix III | | | | | | | | | |
| Boron | ug/L | NC | 500 | 500 | 7,200 | 51 | NA | 970 | 641 |
| Calcium | mg/L | NC | NC | NC | 500 | 46 | NA | 48.9 | 32.5 |
| Chloride | mg/L | 250** | 250 | 250 | 500 | 43 | NA | 25.7 | 29.8 |
| Fluoride | ug/L | 4,000 | NC | NC | NC | 1,000 | NA | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250** | 250 | 250 | 500 | 14 | NA | 109 | 90.0 |
| Total Dissolved Solids | mg/L | 500** | 500 | 500 | 500 | 258 | NA | 306 | 234 |
| pH, Field | SU | 6.5 - 8.5** | 6.5 - 8.5 | 6.5 - 8.5 | 6.5 - 9.0 | 4.8 - 9.2 | NA | 7.0 | 8.8 |
| Appendix IV | | | | | | | | | |
| Antimony | ug/L | 6 | 6.0 | 6.0 | 130 | 2 | 6 | < 1.0 | < 1.0 |
| Arsenic | ug/L | 10 | 10 | 10 | 10 | 1 | 10 | 1.0 | 9.5 |
| Barium | ug/L | 2,000 | 2,000 | 2,000 | 820 | 35 | 2,000 | 92.6 | 58.1 |
| Beryllium | ug/L | 4 | 4.0 | 4.0 | 18 | 1 | 4 | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | 5.0 | 5.0 | 3.5 | 0.2 | 5 | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | 100 | 100 | 11 | 2 | 100 | < 1.0 | 1.5 |
| Cobalt | ug/L | NC | 40 | 100 | 100 | 15 | 15 | < 6.0 | < 6.0 |
| Fluoride | ug/L | 4,000 | NC | NC | NC | 1,000 | 4,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 4.0 | 4.0 | 39 | 1 | 15 | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 170 | 350 | 440 | 10 | 40 | < 10 | < 10 |
| Mercury | ug/L | 2 | 2.0 | 2.0 | 0.20# | 0.2 | 2 | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 73 | 210 | 3,200 | 5 | 100 | 7.4 | 18.6 |
| Radium-226 | pCi/L | NC | NC | NC | NC | NA | NA | < 0.695 | < 0.567 |
| Radium-228 | pCi/L | NC | NC | NC | NC | NA | NA | < 0.708 | < 0.760 |
| Radium-226/228 | pCi/L | 5 | NC | NC | NC | 1.93 | 5 | < 1.40 | < 1.33 |
| Selenium | ug/L | 50 | 50 | 50 | 5 | 5 | 50 | 7.3 | 42.0 |
| Thallium | ug/L | 2 | 2.0 | 2.0 | 3.7 | 2 | 2 | < 2.0 | < 2.0 |

Notes:

ug/L - micrograms per liter.

mg/L - milligrams per liter.

SU - standard units; pH is a field parameter.

pCi/L - picocuries per liter.

MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April 2012.

UTL - Upper Tolerance Limit of the background data set. Appendix III UTLs established in TRC's technical memorandum dated January 15, 2018.

Appendix IV UTLs established in TRC's technical memorandum dated October 15, 2018.

GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/Regional Screening Level and UTL as established in TRC's Technical Memorandum dated October 15, 2018.

NC - no criteria.

* - Michigan Part 201 Generic Drinking Water Cleanup Criteria, December 30, 2013.

** - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April 2012.

^ - Michigan Part 201 Groundwater Surface Water Interface (GSI) Criteria. Hardness-dependent criteria calculated using site-specific hardness of 180 mg CaCO₃/L as measured at surface water sample SW-01 collected on April 9, 2018 from the Pigeon River. Chromium GSI criterion based on hexavalent chromium per footnote (H).

- If detected above 0.20 ug/L, further evaluation of low-level mercury may be necessary to evaluate the GSI pathway per Michigan Part 201 and MDEQ policy and procedure 09-014 dated June 20, 2012.

BOLD value indicates an exceedance of one or more of the listed criteria.

RED value indicates an exceedance of the MCL.

All metals were analyzed as total unless otherwise specified.

Technical Memorandum

Figure




LEGEND

- BACKGROUND MONITORING WELL
- DOWNGRADE BOTTOM ASH POND 1/2 N/S MONITORING WELL
- DOWNGRADE BOTTOM ASH POND 3 N/S MONITORING WELL
- DOWNGRADE LANDFILL MONITORING WELL
- DOWNGRADE POND A MONITORING WELL
- MONITORING WELL (STATIC WATER LEVEL ONLY)
- DECOMMISSIONED MONITORING WELL
- NEW DOWNGRADE BOTTOM ASH POND 1/2 N/S MONITORING WELL (2018)
- NEW DOWNGRADE BOTTOM ASH POND 3 N/S MONITORING WELL (2018)
- (601.75)** GROUNDWATER ELEVATION (FT, NAVD 1988)
- (NM)** NOT MEASURED
- GROUNDWATER ELEVATION CONTOUR (1' INTERVAL, DASHED WHERE INFERRED)

NOTES

1. BASE MAP IMAGERY FROM USDA - NATIONAL AGRICULTURE IMAGERY PROGRAM, 7/20/2016.
2. WELL LOCATIONS SURVEYED BY NEDERVELD ON 11/25/2015.
3. MONITORING WELL DECOMMISSIONED NOVEMBER 13, 2017.
4. MONITORING WELL DECOMMISSIONED JUNE 14, 2018.
5. MONITORING WELL DECOMMISSIONED OCTOBER 10, 2018.
6. JHC-MW-1800X MONITORING WELLS INSTALLED IN DECEMBER 2018.
7. GROUNDWATER ELEVATIONS DISPLAYED IN FEET RELATIVE TO THE NORTH AMERICAN VERTICAL DATUM OF 1988.



| | |
|--|-----------------------------|
| PROJECT: | |
| CONSUMERS ENERGY COMPANY JH CAMPBELL POWER PLANT WEST OLIVE, MICHIGAN | |
| TITLE: | |
| GROUNDWATER CONTOUR MAP DECEMBER 2018 | |
| DRAWN BY: S. MAJOR | PROJ NO.: 322174-001 |
| CHECKED BY: K. LOWERY | |
| APPROVED BY: S. HOLMSTROM | FIGURE A1 |
| DATE: MARCH 2019 | |
| | |
| 1540 Eisenhower Place Ann Arbor, MI 48108-3284 Phone: 734.971.7080 www.trcsolutions.com | |
| FILE NO.: 322174-001-001.mxd | |

Attachment A1

Data Quality Review

**Laboratory Data Quality Review
Groundwater Monitoring Event December 2018
CEC JH Campbell
Units 1 & 2**

Groundwater samples were collected by TRC for the December 2018 sampling event. Samples were analyzed for anions, alkalinity, total dissolved solids, and total metals by Pace Analytical Services, LLC (Pace), located in Grand Rapids, Michigan, and for radium by Pace located in Greensburg, Pennsylvania. The antimony and selenium analyses were subcontracted by Pace in Grand Rapids, MI to the Pace facility in Indianapolis, Indiana. The laboratory analytical results are reported in laboratory reports 4621062 and 4621064.

During the December 2018 sampling event, a groundwater sample was collected from each of the following wells:

- JHC-MW-18004
- JHC-MW-18005

Each sample was analyzed for the following constituents:

| Analyte Group | Method |
|---|--|
| Anions (Fluoride, Chloride, Sulfate) | EPA 300.0 |
| Alkalinity | SM 2320B-11 |
| Total Dissolved Solids (TDS) | SM 2540C-11 |
| Total Metals | SW-846 6020A, SW-846 6010C, SW-846 7470A |
| Radium (Radium-226, Radium-228, Total Radium) | EPA 903.1, EPA 904.0 |

TRC reviewed the laboratory data to assess data usability. The following sections summarize the data review procedure and the results of the review.

Data Quality Review Procedure

The analytical data were reviewed using the USEPA National Functional Guidelines for Inorganic Superfund Data Review (USEPA, 2017) and the Department of Energy Evaluation of Radiochemical Data Usability (USDOE, 1997). The following items were included in the evaluation of the data:

- Sample receipt;
- Technical holding times for analyses;
- Reporting limits (RLs) compared to project-required RLs;

- Data for method blanks, equipment blanks, and field blanks. Method blanks are used to assess potential contamination arising from laboratory sample preparation and/or analytical procedures. Field and equipment blanks are used to assess potential contamination arising from field procedures;
- Data for laboratory control samples (LCSs). The LCSs are used to assess the accuracy of the analytical method using a clean matrix;
- Percent recoveries for matrix spike (MS) and matrix spike duplicates (MSD), when performed on project samples. Percent recoveries are calculated for each analyte spiked and used to assess bias due to sample matrix effects;
- Data for laboratory duplicates, when performed on project samples. The laboratory duplicates are replicate analyses of one sample and are used to assess the precision of the analytical method;
- Percent recoveries for tracers and carriers, where applicable, for radiochemistry only. Tracers and/or carriers are used to assess the chemical yield for the preparation and/or instrument efficiency;
- Data for blind field duplicates. Field duplicate samples are used to assess variability introduced by the sampling and analytical processes; and
- Overall usability of the data.

This data usability report addresses the following items:

- Usability of the data if quality control (QC) results suggest potential problems with all or some of the data;
- Actions regarding specific QC criteria exceedances.

Review Summary

The data quality objectives and laboratory completeness goals for the project were met, and the data are usable for their intended purpose. A summary of the data quality review, including non-conformances and issues identified in this evaluation are noted below.

- The Appendix III and IV constituents will be utilized for the purposes of an assessment monitoring program.
- Data are usable for the purposes of the assessment monitoring program.
- When the data are evaluated through an assessment monitoring statistical program, findings below may be used to support the removal of outliers.

QA/QC Sample Summary:

- Sample receipt: The cooler temperatures for all coolers were $>6^{\circ}\text{C}$ (7.91-13.3 $^{\circ}\text{C}$). Although the coolers were hand delivered to the laboratory and were received by the laboratory on the same day they were collected, the coolers did not contain ice upon receipt; thus, the

positive and nondetect results for alkalinity, anions, and TDS in all samples in this data set were potentially impacted, as summarized in the attached table.

- A method blank was analyzed with each analytical batch. Target analytes were not detected in the method blanks.
- One equipment blank (EB-08) and one field blank (FB-08) were collected. Target analytes were not detected in the equipment blank and field blank.
- LCS recoveries were within laboratory control limits for all analytes.
- MS and/or MSDs were performed on sample JHC-MW-18004 for anions, mercury, metals, alkalinity, and radium. The MS/MSD recoveries and relative percent differences (RPDs), where applicable, were within the acceptance limits with the following exceptions.
 - The recoveries of born were outside of the acceptance criteria. The boron concentration in sample JHC-MW-18004 was >4x the spike concentration; therefore, the MS/MSD results for boron were not evaluated. Data usability was not affected.
 - The recovery for sulfate in the MS performed on sample JHC-MW-18004 was below the lower laboratory control limit. Potential low bias exists for the results for sulfate in the samples in this batch, as summarized in the attached table.
- Laboratory duplicates were performed on sample JHC-MW-18004 for anions, TDS, and alkalinity. All criteria were met.
- The field duplicate pair samples submitted with this data set were JHC-MW-18005 and Dup-08. RPDs between the parent and duplicate samples were within the QC limits for all analytes.
- Carrier and tracer recoveries, where applicable, were within 30-110%.

Attachment A

Summary of Data Non-Conformances for Units 1 and 2 Groundwater Analytical Data
 JH Campbell - RCRA CCR Monitoring Program
 West Olive, Michigan

| Samples | Collection Date | Analyte | Non-Conformance/Issue |
|--|-----------------|--|--|
| Dup-08 EB-08 FB-08 JHC-MW-18004_20181207 JHC-MW-18005_20181207 | 12/7/2018 | Fluoride, Chloride, Sulfate, Total Alkalinity, Bicarbonate Alkalinity, Carbonate Alkalinity, TDS | Coolers were received with temperature >6°C and no ice in coolers. Sample results may be biased low. |
| Dup-08 JHC-MW-18004_20181207 JHC-MW-18005_20181207 | 12/7/2018 | Sulfate | MS recovery below the lower laboratory control limit. Sample results may be biased low. |

Attachment B

Data Quality Reviews

Laboratory Data Quality Review

Groundwater Monitoring Event November 2018

CEC JH Campbell Background

Groundwater samples were collected by TRC for the November 2018 sampling event. Samples were analyzed for anions, total dissolved solids, alkalinity, and total metals (except for antimony and selenium) by Pace Analytical Services, LLC (Pace) located in Grand Rapids, Michigan, for antimony and selenium by Pace located in Indianapolis, IN, and for radium by Pace located in Greensburg, Pennsylvania. The laboratory analytical results are reported in laboratory reports 4620343 and 4620344.

During the November 2018 sampling event, a groundwater sample was collected from each of the following wells:

- JHC-MW-15023
- JHC-MW-15024
- JHC-MW-15025
- JHC-MW-15026
- JHC-MW-15027
- JHC-MW-15028

Each sample was analyzed for the following constituents:

| Analyte Group | Method |
|---|--------------------------|
| Anions (Fluoride, Chloride, Sulfate) | SW-846 300.0 |
| Total Dissolved Solids | SM 2540C-11 |
| Alkalinity (Total, Bicarbonate, Carbonate) | SM 2320B-11 |
| Total Metals | SW-846 6010C/6020A/7470A |
| Radium (Radium-226, Radium-228, Total Radium) | EPA 903.1, EPA 904.0 |

TRC reviewed the laboratory data to assess data usability. The following sections summarize the data review procedure and the results of the review.

Data Usability Review Procedure

The analytical data were reviewed using the USEPA National Functional Guidelines for Inorganic Superfund Methods Data Review (USEPA, 2017) and the Department of Energy Evaluation of Radiochemical Data Usability (USDOE, 1997). The following items were included in the evaluation of the data:

- Sample receipt, as noted in the cover page or case narrative;
- Technical holding times for analyses;
- Reporting limits (RLs) compared to project-required RLs;

- Data for method blanks, equipment blanks, and field blanks. Method blanks are used to assess potential contamination arising from laboratory sample preparation and/or analytical procedures. Field and equipment blanks are used to assess potential contamination arising from field procedures;
- Data for laboratory control samples (LCSs). The LCSs are used to assess the accuracy of the analytical method using a clean matrix;
- Percent recoveries for matrix spike (MS) and matrix spike duplicates (MSD), where applicable. Percent recoveries are calculated for each analyte spiked and used to assess bias due to sample matrix effects;
- Percent recoveries for tracer and carriers, where applicable, for radiochemistry only. Tracers and/or carriers are used to assess the chemical yield for the preparation and/or instrument efficiency;
- Data for laboratory duplicates, when available. The laboratory duplicates are replicate analyses of one sample and are used to assess the precision of the analytical method;
- Data for blind field duplicates. Field duplicate samples are used to assess variability introduced by the sampling and analytical processes; and
- Overall usability of the data.

This data usability report addresses the following items:

- Usability of the data if quality control (QC) results suggest potential problems with all or some of the data;
- Actions regarding specific QC criteria exceedances.

Review Summary

The data quality objectives and laboratory completeness goals for the project were met, and the data are usable for their intended purpose. A summary of the data quality review, including non-conformances and issues identified in this evaluation are noted below.

- Appendix IV constituents will be utilized for the purposes of an assessment monitoring program.
- Data are usable for the purposes of the assessment monitoring program.
- When the data are evaluated through an assessment monitoring statistical program, findings below may be used to support the removal of outliers.

QA/QC Sample Summary

- The temperature for one of the six coolers upon receipt at the laboratory was $>6^{\circ}\text{C}$ (10.3°C). The samples were collected on 11/13/18, but the sample coolers were not received by the laboratory until 11/14/18. The results for fluoride, chloride, sulfate, alkalinity, and TDS in samples JHC-MW-15023_20181113, JHC-MW-15024_20181113; JHC-MW-15025_20181113; JHC-MW-15026_20181113; JHC-MW-15027_20181113, JHC-MW-15028_20181113, Dup#05_20181113, EB#05_20181113, and FB#05_20181113 may be biased low. The data were within or above the range of historical results with the exception of bicarbonate and total alkalinity in JHC-MW-15024 and JHC-MW-15025, which were below the range of historical concentrations.
- No target analytes were detected in the method blank.
- One field blank (FB#05_20181113) and one equipment blank (EB#05_20181113) were collected; no analytes were detected in these blank samples.
- LCS recoveries were within laboratory control limits.
- MS/MSDs were performed on sample JHC-MW-15025_20181113 for radium, metals, and anions, and MS analysis was performed on sample JHC-MW-15025_20181113 for alkalinity. All percent recoveries (%R) and relative percent differences (RPDs) were with the QC limits.
- Laboratory duplicate analyses were performed on sample JHC-MW-15025_20181113 for anions, alkalinity, and TDS; the RPDs between the parent and duplicate sample were within the QC limits.
- The field duplicate pair samples were Dup#05_20181113 and JHC-MW-15028_20181113; the RPDs for total alkalinity (98%) and bicarbonate alkalinity (98%) did not meet criteria. Potential variability exists for total alkalinity and bicarbonate alkalinity results for samples JHC-MW-15023_20181113, JHC-MW-15024_20181113; JHC-MW-15025_20181113; JHC-MW-15026_20181113; JHC-MW-15027_20181113, JHC-MW-15028_20181113, and Dup#05_20181113 due to field duplicate variability (see attached table).
- The RLs for chloride (2 mg/L) and TDS (50 mg/L) in the equipment blank (EB#05_20181113) and field blank (FB#05_20181113), and for TDS (50 mg/L) in sample JHC-MW-15026_20181113 exceeded the project-required RL of 1 mg/L.
 - The nondetect result for TDS in sample JHC-MW-15026_20181113 may not meet project objectives since the RL is above the project-required RL of 1 mg/L. The RL of 50 mg/L is below all project criteria; therefore, data usability is not affected.
 - The exceeded RLs for the nondetect results for chloride and TDS in the equipment blank (EB#05_20181113) and field blank (FB#05_20181113) do not affect data usability.
- Carrier and tracer recoveries, where applicable, were within 30-110%.

Attachment A
 Summary of Data Non-Conformances
 JH Campbell Background – RCRA CCR Monitoring Program
 West Olive, Michigan

| Samples | Collection Date | Analyte | Non-Conformance/Issue |
|-----------------------|-----------------|--|---|
| JHC-MW-15023_20181113 | 11/13/2018 | Fluoride, Chloride, Sulfate, Total Alkalinity, Bicarbonate Alkalinity, Carbonate Alkalinity, TDS | Cooler(s) was received with temperature >6°C. Sample results may be biased low. |
| JHC-MW-15024_20181113 | 11/13/2018 | | |
| JHC-MW-15025_20181113 | 11/13/2018 | | |
| JHC-MW-15026_20181113 | 11/13/2018 | | |
| JHC-MW-15027_20181113 | 11/13/2018 | | |
| JHC-MW-15028_20181113 | 11/13/2018 | | |
| EB#05_20181113 | 11/13/2018 | | |
| FB#05_20181113 | 11/13/2018 | | |
| DUP#05_20181113 | 11/13/2018 | | |
| JHC-MW-15023_20181113 | 11/13/2018 | Total alkalinity, Bicarbonate alkalinity | RPD for the field duplicate pair exceeded 30%. Potential uncertainty exists due to the field duplicate variability. |
| JHC_MW-15024_20181113 | 11/13/2018 | | |
| JHC-MW-15025_20181113 | 11/13/2018 | | |
| JHC-MW-15026_20181113 | 11/13/2018 | | |
| JHC-MW-15027_20181113 | 11/13/2018 | | |
| JHC-MW-15028_20181113 | 11/13/2018 | | |
| DUP#05_20181113 | 11/13/2018 | | |

Notes:

RPD: Relative Percent Difference = $| \text{sample result} - \text{duplicate result} | / ((\text{sample result} + \text{duplicate result}) / 2)$

Laboratory Data Quality Review Groundwater Monitoring Event November 2018 CEC JH Campbell Units 1 & 2

Groundwater samples were collected by TRC for the November 2018 sampling event. Samples were analyzed for anions, total dissolved solids, alkalinity, and total metals (except for antimony and selenium) by Pace Analytical Services, LLC (Pace) located in Grand Rapids, Michigan, for antimony and selenium by Pace located in Indianapolis, IN, and for radium by Pace located in Greensburg, Pennsylvania. The laboratory analytical results are reported in laboratory reports 4620347 and 4620348.

During the November 2018 sampling event, a groundwater sample was collected from each of the following wells:

- JHC-MW-15001
- JHC-MW-15002
- JHC-MW-15003
- JHC-MW-15005
- JHC-MW-15013

Sample JHC-MW-15013 is associated with the Unit 3 groundwater monitoring network.

Each sample was analyzed for the following constituents:

| Analyte Group | Method |
|---|--------------------------|
| Anions (Fluoride, Chloride, Sulfate) | SW-846 300.0 |
| Total Dissolved Solids | SM 2540C-11 |
| Alkalinity (Total, Bicarbonate, Carbonate) | SM 2320B-11 |
| Total Metals | SW-846 6010C/6020A/7470A |
| Radium (Radium-226, Radium-228, Total Radium) | EPA 903.1, EPA 904.0 |

TRC reviewed the laboratory data to assess data usability. The following sections summarize the data review procedure and the results of the review.

Data Usability Review Procedure

The analytical data were reviewed using the USEPA National Functional Guidelines for Inorganic Superfund Methods Data Review (USEPA, 2017) and the Department of Energy Evaluation of Radiochemical Data Usability (USDOE, 1997). The following items were included in the evaluation of the data:

- Sample receipt, as noted in the cover page or case narrative;
- Technical holding times for analyses;
- Reporting limits (RLs) compared to project-required RLs;

- Data for method blanks, equipment blanks, and field blanks. Method blanks are used to assess potential contamination arising from laboratory sample preparation and/or analytical procedures. Field and equipment blanks are used to assess potential contamination arising from field procedures;
- Data for laboratory control samples (LCSs). The LCSs are used to assess the accuracy of the analytical method using a clean matrix;
- Percent recoveries for matrix spike (MS) and matrix spike duplicates (MSD), where applicable. Percent recoveries are calculated for each analyte spiked and used to assess bias due to sample matrix effects;
- Percent recoveries for tracer and carriers, where applicable, for radiochemistry only. Tracers and/or carriers are used to assess the chemical yield for the preparation and/or instrument efficiency;
- Data for laboratory duplicates, when available. The laboratory duplicates are replicate analyses of one sample and are used to assess the precision of the analytical method;
- Data for blind field duplicates. Field duplicate samples are used to assess variability introduced by the sampling and analytical processes; and
- Overall usability of the data.

This data usability report addresses the following items:

- Usability of the data if quality control (QC) results suggest potential problems with all or some of the data;
- Actions regarding specific QC criteria exceedances.

Review Summary

The data quality objectives and laboratory completeness goals for the project were met, and the data are usable for their intended purpose. A summary of the data quality review, including non-conformances and issues identified in this evaluation are noted below.

- Appendix IV constituents will be utilized for the purposes of an assessment monitoring program.
- Data are usable for the purposes of the assessment monitoring program.
- When the data are evaluated through an assessment monitoring statistical program, findings below may be used to support the removal of outliers.

QA/QC Sample Summary

- The temperature for one of six coolers shipped and received on 11/14/18 was $>6^{\circ}\text{C}$ (10.3°C). The results for fluoride, chloride, sulfate, alkalinity, and TDS in sample JHC-MW-15001_20181113 collected on 11/13/18 and received on 11/14/18 may be biased low (see attached table). Concentrations were within the range of historical results with the exception of chloride, which was below historical concentrations. Samples JHC-MW-15003_20181115, DUP#04_20181114, and FB#04_20181114 were collected on 11/14/18, received on the same day as sample collection, and contained ice upon receipt; thus, there was no adverse impact to data usability.
- The temperatures for three out of six coolers received on 11/15/18 were $>6^{\circ}\text{C}$ (ranging from 7.3 - 9.3°C). However, the samples were collected on 11/15/18, and the coolers were hand delivered to the courier and contain ice upon receipt; thus, there was no adverse impact to data usability.
- There were no contaminants detected in the reported method blanks with the following exceptions:
 - Ra-226 was detected in the method blank from batch 321901 at a concentration of 0.992 ± 0.632 pCi/L. There was no impact on data usability since Ra-226 was nondetect in the associated samples JHC-MW-15005_20181115 and EB#03_20181115.
 - The MB data was not provided in the data package for sulfate analyzed on 12/6/18: Sample JHC-MW-15005_20181115 was analyzed 27 minutes beyond the laboratory's 24-hr batch window (starting from the analysis time of the MB). Due to limitations of the laboratory's software, more than one batch QC (i.e. MB) cannot be reported per sample, regardless of analytical date. The laboratory stated that the batch MB was associated with batches of 20 samples; thus, additional QC was not reported by the laboratory for samples that need to be re-analyzed due to instrument verification issues or dilution. The laboratory also stated that instrument verification via calibration blanks and standards was verified daily prior to sample analysis to ensure the instrument was in control. There was no impact on the overall usability of the data for the samples listed above due to this issue.
- Two field blanks (FB#03_20181115 and FB#04_20181115) were collected; no analytes were detected in these blank samples.
- One equipment blank (EB#03_20181115) was collected and the following analyte was detected:
 - Chloride at 2.1 mg/L; the chloride result in sample JHC-MW-15001_20181113, may be a false positive since the result was less than $5\times$ the blank result. The chloride result for JHC-MW-15001 was below the range of historical concentrations.
- LCS recoveries were within laboratory control limits with the following exception:
 - The LCS data was not provided in the data package for the anions analyzed on 12/6/18: Sample JHC-MW-15005_20181115 was analyzed 27 minutes beyond the laboratory's 24-

hr batch window (starting from the analysis time of the MB). Due to limitations of the laboratory's software, more than one batch QC (i.e. LCS) cannot be reported per sample, regardless of analytical date. The laboratory stated that the batch LCS was associated with batches of 20 samples; thus, additional QC was not reported by the laboratory for samples that need to be re-analyzed due to instrument verification issues or dilution. The laboratory also stated that instrument verification via calibration blanks and standards was verified daily prior to sample analysis to ensure the instrument was in control. There was no impact on the overall usability of the data for the samples listed above due to this issue.

- MS/MSDs were performed on sample JHC-MW-15003_20181115 for radium, metals, and anions, and MS analysis was performed on sample JHC-MW-15003_20181115 for alkalinity. The relative percent differences (RPDs) were within the QC limits.
 - The boron recoveries in the MS/MSD analyses performed on sample JHC-MW-15003_20181115 were below the lower laboratory control limits. However, the sample result in the parent sample was >4x the spike added; thus, there was no adverse impact on data usability.
- Laboratory duplicate analyses were performed on the following samples; RPDs between the parent and duplicate sample were within the QC limits.
 - For anions on samples JHC-MW-15001_20181113 and JHC-MW-15003_20181115
 - For alkalinity and TDS on sample JHC-MW-15003_20181115
- The RLs for chloride (2 mg/L) and TDS (50 mg/L) in field blanks (FB#03_20181115 and FB#04_20181114) and for TDS (50 mg/L) in equipment blank (EB#03_20181115) exceeded the project-required RL of 1 mg/L. This does not affect data usability since these are QC samples.
- The field duplicate pair samples were Dup#03_20181115 and JHC-MW-15002_20181115 and Dup#04_20181114 and JHC-MW-15013_20181114; all criteria were met for field duplicate pair Dup#03_20181115 and JHC-MW-15002_20181115. The RPD for chromium in the field duplicate pair Dup#04_20181114 and JHC-MW-15013_20181114 was 32.8% above the 30% acceptance limit. The samples associated with this field duplicate pair were samples JHC-MW15001_20181113, JHC-MW-15013_20181114, and Dup#04_20181114. Potential uncertainties exist for the positive chromium results in samples Dup#04_20181114 and JHC-MW-15013_20181114 (see attached table). The chromium results for JHC-MW-15013 were within the range of historical results.
- Carrier and tracer recoveries, where applicable, were within 30-110%.

Attachment B
 Summary of Data Non-Conformances
 JH Campbell Units 1 & 2 – RCRA CCR Monitoring Program
 West Olive, Michigan

| Samples | Collection Date | Analyte | Non-Conformance/Issue |
|-----------------------|-----------------|--|--|
| JHC-MW-15001_20181113 | 11/13/2018 | Fluoride, Chloride, Sulfate, Total Alkalinity, Bicarbonate Alkalinity, Carbonate Alkalinity, TDS | Cooler(s) was received with temperature >6°C. Sample results may be biased low. |
| JHC-MW-15001_20181113 | 11/13/2018 | Chloride | Detection in equipment blank (EB-01). Sample result ≤5X the blank concentration. Result may be a false positive. |
| JHC-MW-15013_20181114 | 11/14/2018 | Chromium | RPD for the field duplicate pair exceeded 30%. Potential uncertainty exists due to the field duplicate variability; however, results were within the range of historical concentrations. |
| DUP#04_20181114 | 11/14/2018 | | |

Notes:

RPD: Relative Percent Difference = $\frac{|\text{sample result} - \text{duplicate result}|}{(\text{sample result} + \text{duplicate result})/2}$

Attachment C
Statistical Evaluation of November 2018 Assessment
Monitoring Sampling Event

Technical Memorandum

Date: March 14, 2019

To: Bethany Swanberg, CEC

cc: Brad Runkel, CEC
JR Register, CEC
Michelle Marion, CEC

From: Darby Litz, TRC
Sarah Holmstrom, TRC
Kristin Lowery, TRC

Project No.: 290806.0000.0000

Subject: Statistical Evaluation of November 2018 Assessment Monitoring Sampling Event, JH Campbell Bottom Ash Pond Units 1-2 North and 1-2 South CCR Unit, Consumers Energy Company, West Olive, Michigan

During the statistical evaluation of the initial assessment monitoring event, arsenic was present in one or more downgradient monitoring wells at statistically significant levels exceeding the Groundwater Protection Standards (GWPSs). Therefore, Consumers Energy Company (CEC) will initiate an Assessment of Corrective Measures (ACM) within 90 days from when the Appendix IV exceedance was determined (no later than April 14, 2019). Currently, CEC is continuing semiannual assessment monitoring in accordance with §257.95 of the CCR Rule¹ at the JH Campbell Power Plant (JHC) Bottom Ash Pond Unit 1-2 North and 1-2 South (Unit 1-2). The second semiannual assessment monitoring event of 2018 was conducted on November 12 through November 16, 2018. In accordance with §257.95, the assessment monitoring data must be compared to GWPSs to determine whether or not Appendix IV constituents are detected at statistically significant levels above the GWPSs. GWPSs were established in accordance with §257.95(h), as detailed in the October 15, 2018 *Groundwater Protection Standards* technical memorandum, which was also included in the 2018 *Annual Groundwater Monitoring Report* (TRC, January 2019). The following narrative describes the methods employed and the results obtained and the Sanitas™ output files are included as an attachment.

¹ USEPA final rule for the regulation and management of Coal Combustion Residuals (CCR) under the Resource Conservation and Recovery Act (RCRA) published April 17, 2015, as amended per Phase One, Part One of the CCR Rule (83 FR 36435).

Technical Memorandum

The statistical evaluation of the second semiannual assessment monitoring event data indicates that the following constituent is present at statistically significant levels exceeding the GWPS in downgradient monitoring wells at the JHC Unit 1-2 CCR unit:

| <u>Constituent</u> | <u>GWPS</u> | <u># Downgradient Wells Observed</u> |
|--------------------|-------------|--------------------------------------|
| Arsenic | 10 ug/L | 2 of 4 |

These results are consistent with the results of the initial assessment monitoring data statistical evaluation and CEC will continue to initiate an assessment of corrective measures per §257.95(g). CEC will continue executing the self-implementing groundwater compliance schedule in conformance with §257.90 - §257.98.

Assessment Monitoring Statistical Evaluation

The compliance well network at the JHC Unit 1-2 CCR Unit consists of four monitoring wells (JHC-MW-15001, JHC-MW-15002, JHC-MW-15003, and JHC-MW-15005) located on the perimeter of the bottom ash ponds. Former downgradient monitoring well JHC-MW-15004 was decommissioned on June 14, 2018 during deconstruction of Unit 1-2; therefore, statistical analysis for JHC-MW-15004 terminates at the June 2018 monitoring event.

Following the second semiannual assessment monitoring sampling event, compliance well data for the JHC Unit 1-2 were evaluated in accordance with the Groundwater Statistical Evaluation Plan (Stats Plan) (TRC, October 2017). An assessment monitoring program was developed to evaluate concentrations of CCR constituents present in the uppermost aquifer relative to acceptable levels (i.e. GWPSs). In order to decide as to whether or not the GWPSs have been exceeded, the change in concentration observed at the downgradient wells during a given assessment monitoring event must be large enough, after accounting for variability in the sample data, that the result is unlikely to have occurred merely by chance. Consistent with the Unified Guidance², the preferred method for comparisons to a fixed standard are confidence limits. An exceedance of the standard occurs when the 99 percent lower confidence level of the downgradient data exceeds the GWPS. Based on the number of historical observations in the representative sample population, the population mean, the population standard deviation, and a selected confidence level (i.e. 99 percent), an upper and lower confidence limit is calculated. The true concentration, with 99 percent confidence, will fall between the lower and upper confidence limits.

The concentrations observed in the downgradient wells are deemed to be a statistically significant exceedance when the 99 percent lower confidence limit of the downgradient data exceeds the GWPS. If the confidence interval straddles the GWPS (i.e. the lower confidence level is below the GWPS but

² USEPA. 2009. *Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities, Unified Guidance*. Office of Conservation and Recovery. EPA 530/R-09-007.

Technical Memorandum

the upper confidence level is above), the statistical test results are inconclusive and there is not compelling evidence that the measured concentration is a result of a release from the CCR unit versus the inherent variability of the sample data. This statistical approach is consistent with the statistical methods for assessment monitoring presented in §257.93(f) and (g). Statistical evaluation methodologies built into the CCR Rule, and numerous other federal rules, are key in determining whether or not individually measured data points represent a concentration increase over the baseline or a fixed standard (such as a GWPS in an assessment monitoring program).

For each detected Appendix IV constituent, the concentrations for each well were first compared directly to the GWPS, as shown on Table C1. Parameter-well combinations that included a direct exceedance of the GWPS within the past eight monitoring events (August 2016 through November 2018) were retained for further analysis. Arsenic in JHC-MW-15001 and JHC-MW-15003, arsenic and lithium in JHC-MW-15002, and lithium, molybdenum, selenium, and thallium in JHC-MW-15005 at Unit 1-2 had individual results exceeding the GWPS. Cobalt was detected in JHC-MW-15003 at a concentration of 23.6 ug/L, which exceeds its GWPS. However, this is the only detection of cobalt in the Unit 1-2 wells during either baseline sampling or assessment monitoring, and it qualifies as an outlier. The well will be sampled during the next semiannual assessment monitoring sampling event to confirm whether cobalt is present in groundwater at that monitoring well. Per the Stats Plan and the Unified Guidance, cobalt will be subject to the double quantification rule, where a detection above laboratory reporting limits must be observed for two consecutive events (e.g. initial sample and a resample) to confirm the initial detection and rule out a potential false positive result.

Groundwater data were then evaluated utilizing Sanitas™ statistical software. Sanitas™ is a software tool that is commercially available for performing statistical evaluation consistent with procedures outlined in the Unified Guidance. Within the Sanitas™ statistical program, confidence limits were selected to perform the statistical comparison of compliance data to a fixed standard. Parametric and non-parametric confidence intervals were calculated, as appropriate, for each of the CCR Appendix IV parameters using a 99 percent confidence level, i.e., a significance level (α) of 0.01. The following narrative describes the methods employed, the results obtained and the Sanitas™ output files are included as an attachment.

The statistical data evaluation included the following steps:

- Review of data quality checklists for the data sets;
- Graphical representation of the monitoring data as time versus concentration by well-constituent pair;
- Outlier testing of individual data points that appear from the graphical representations as potential outliers;
- Evaluation of visual trends apparent in the graphical representations for statistical significance;

Technical Memorandum

- Evaluation of percentage of non-detects for each well-constituent pair;
- Distribution of the data; and
- Calculation of the confidence intervals for each cumulative dataset.

The results of these evaluations are presented and discussed below.

Initially, the baseline (December 2015 through August 2017) results and the assessment monitoring results (April through November 2018) for these well-constituent pairs were observed visually for potential trends. Potential outliers were noted for lithium (JHC-MW-15002 in November 2018) and molybdenum (JHC-MW-15005 in November 2018), which had not previously exceeded the GWPSs. Groundwater conditions are re-equilibrating following to CCR removal activities at the JHC Unit 1-2 recently completed in September 2018, and the groundwater monitoring system is being re-assessed to account for post-deconstruction groundwater conditions. Because hydrogeologic conditions are in the process of stabilizing, in order to be conservative, the suspect lithium and molybdenum data from November 2018 have been kept in the assessment monitoring data set pending the collection of additional data. The suspect data will be tested for outliers once stabilized groundwater characteristics have been assessed. Data from each round were evaluated for completeness, overall quality, and usability and were deemed appropriate for the purposes of the CCR assessment monitoring program.

The Sanitas™ software was then used to test compliance at the downgradient monitoring wells using the confidence interval method for the most recent eight sampling events. Eight independent sampling events provide the appropriate density of data as recommended per the Unified Guidance yet are collected recently enough to provide an indication of current condition. The tests were run with a per-well significance of $\alpha = 0.01$. The software outputs are included in Attachment C1 along with data reports showing the values used for the evaluation. The percentage of non-detect observations are also included in Attachment C1. Non-detect data was handled in accordance with the Stats Plan for the purposes of calculating the confidence intervals.

The Sanitas™ software generates an output that includes graphs of the parametric or non-parametric confidence intervals for each well along with notes on data transformations, as appropriate. The data sets were found to be normally distributed, except the set for arsenic in JHC-MW-15002 and molybdenum, selenium, and thallium in JHC-MW-15005 for which nonparametric confidence tests were conducted. The confidence interval test compares the lower confidence limit to the GWPS. The statistical evaluation of the Appendix IV constituents shows exceedances for arsenic in JHC-MW-15002 and JHC-MW-15003. These results are consistent with the results of the initial assessment monitoring data statistical evaluation and CEC will continue to initiate an assessment of corrective measures per §257.95(g). CEC will continue executing the self-implementing groundwater compliance schedule in conformance with §257.90 - §257.98.

Technical Memorandum


Although no outliers were identified, the recent data collected during the April, June, and November 2018 assessment monitoring events shows some variation compared to the background data set. The timing of the dissimilarities correlates with CCR removal activities and re-equilibration of groundwater in the vicinity of JHC Unit 1-2 following cessation of hydraulic loading and completion of pond deconstruction. As mentioned above, the JHC Unit 1-2 monitoring system is currently being re-evaluated post-deconstruction to determine which monitoring wells are appropriately positioned to assess groundwater quality downgradient from the JHC Unit 1-2 CCR unit after hydrogeologic conditions re-stabilize.

Sincerely,

TRC



Graham Crockford
Program Manager



Sarah B. Holmstrom
Project Hydrogeologist

Attachments

| | |
|---------------|---|
| Table C1. | Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to November 2018 |
| Attachment C1 | Sanitas™ Output |

Technical Memorandum

Table

Table C1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to November 2018
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15001 | | | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|------------|--------------|----------|-----------|-----------|------------|-----------|-----------|-----------|-----------|--------------------|-----------|-------------|
| Sample Date: | | | | | | 12/7/2015 | 3/8/2016 | 6/21/2016 | 8/29/2016 | 11/15/2016 | 4/19/2017 | 6/20/2017 | 8/14/2017 | 9/25/2017 | 4/25/2018 | 6/18/2018 | 11/13/2018 |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | NA | 51 | NA | 396 | 235 | 195 | 271 | 309 | 149 | 368 | 238 | 287 | -- | 339 | 146 |
| Calcium | mg/L | NC | NA | 46 | NA | 85.6 | 84.1 | 80.7 | 74.0 | 75.5 | 70.3 | 50.7 | 70.9 | 68 | -- | 68.6 | 72.1 |
| Chloride | mg/L | 250* | NA | 43 | NA | 12.3 | 48.4 | 152 | 98.5 | 105 | 7.1 | 51.8 | 94.8 | 73.6 | -- | 109 | 2.7 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250* | NA | 14 | NA | 142 | 46.2 | 34.9 | 46.4 | 68.3 | 42.1 | 88 | 114 | 129 | -- | 78.9 | 59.1 |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 630 | 190 | 570 | 550 | 560 | 440 | 340 | 562 | 563 | -- | 596 | 310 |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 6.6 | 6.4 | 6.2 | 6.0 | 6.4 | 6.3 | 6.2 | 6.3 | 6.2 | 7.2 ⁽¹⁾ | 6.3 | 6.3 |
| Appendix IV | | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 6 | 3 | 3 | 4 | 3 | 4 | 1.8 | 2.2 | -- | < 1.0 | 1.8 | 12.7 |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 160 | 148 | 164 | 148 | 141 | 172 | 106 | 142 | -- | 71.4 | 183 | 84.9 |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | NA | 2 | 100 | 1 | 2 | 2 | 2 | 3 | 2 | 1.0 | 1.0 | -- | < 1.0 | < 1.0 | < 1.0 |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | -- | < 15.0 | < 15.0 | < 6.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 40 | 10 | 40 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | -- | < 10 | < 10 | < 10 |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | < 5 | < 5 | < 5 | < 5 | < 5 | < 5 | < 5.0 | < 5.0 | -- | < 5.0 | < 5.0 | 13.3 |
| Radium-226 | pCi/L | NC | NA | NA | NA | < 0.234 | < 0.211 | 0.344 | < 0.389 | < 0.379 | < 0.352 | < 1.63 | < 0.708 | -- | < 0.545 | < 0.828 | < 0.755 |
| Radium-228 | pCi/L | NC | NA | NA | NA | 1.67 | 1.34 | 2.24 | 1.56 | 1.60 | 2.07 | < 0.628 | 1.20 | -- | < 0.799 | < 1.12 | < 0.879 |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | 1.9 | 1.53 | 2.58 | 1.77 | 1.89 | 2.13 | < 2.26 | 1.61 | -- | < 1.34 | < 1.95 | < 1.63 |
| Selenium | ug/L | 50 | NA | 5 | 50 | < 1 | 1 | 1 | < 1 | 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 |
| Thallium | ug/L | 2 | NA | 2 | 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2.0 | < 2.0 | -- | < 2.0 | < 2.0 | < 2.0 |

Notes:

- ug/L - micrograms per liter.
- mg/L - milligrams per liter.
- SU - standard units; pH is a field parameter.
- pCi/L - picocuries per liter.
- NA - not applicable.
- NC - no criteria.
- - not analyzed.
- MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April, 2012.
- RSL - Regional Screening Level from 83 FR 36435.
- UTL - Upper Tolerance Limit (95%) of the background data set.
- GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
- * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April, 2012.
- Bold** value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
- All metals were analyzed as total unless otherwise specified.
- (1) pH value potentially biased high due to groundwater quality meter malfunction.
- (2) JHC-MW-15004 was decommissioned on June 14th, 2018.

Table C1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to November 2018
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15002 | | | | | | | | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|------------|--------------|-----------|-----------|-----------|------------|-----------|-------------|-------------|-------------|-------------|-----------|-----------|---------------------|------------|------------|-------------|-------------|
| Sample Date: | | | | | | 12/7/2015 | 3/8/2016 | 6/21/2016 | 8/30/2016 | 11/15/2016 | 4/19/2017 | 6/20/2017 | 6/20/2017 | 8/14/2017 | 8/14/2017 | 9/25/2017 | 9/25/2017 | 4/25/2018 | 4/25/2018 | 6/19/2018 | 11/15/2018 | 11/15/2018 |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | Field Dup | | Field Dup | | Field Dup | | Field Dup | | | Field Dup |
| Boron | ug/L | NC | NA | 51 | NA | 661 | 426 | 433 | 831 | 757 | 602 | 768 | 678 | 869 | 946 | 927 | 894 | -- | -- | 430 | 1,470 | 1,360 |
| Calcium | mg/L | NC | NA | 46 | NA | 21.9 | 35.8 | 36.4 | 36.1 | 18.9 | 28.0 | 24.6 | 25.1 | 25.7 | 25.3 | 30.5 | 30.6 | -- | -- | 75.3 | 41.9 | 41.1 |
| Chloride | mg/L | 250* | NA | 43 | NA | 13.2 | 18.5 | 23.4 | 17.4 | 14.4 | 25.7 | 20.7 | 20.7 | 20.7 | 20.2 | 25.8 | 26.0 | -- | -- | 22.3 | 19.3 | 19.2 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250* | NA | 14 | NA | 33.3 | 47.8 | 46.9 | 54.0 | 51.4 | 64.2 | 52.8 | 53.3 | 54.5 | 53.7 | 33.9 | 34.3 | -- | -- | 153 | 95.2 | 94.5 |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 150 | 160 | 180 | 190 | 140 | 190 | 160 | 130 | 236 | 174 | 144 | 148 | -- | -- | 356 | 222 | |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 8.8 | 8.7 | 8.5 | 8.6 | 8.8 | 8.8 | 9.2 | -- | 9.2 | -- | 9.6 | -- | 10.2 ⁽¹⁾ | -- | 8.3 | 8.0 | -- |
| Appendix IV | | | | | | | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | < 1 | < 1 | 4 | 3 | 1 | < 1 | 3.3 | 2.9 | 1.9 | 2.1 | -- | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 34 | 40 | 36 | 34 | 46 | 33 | 35.4 | 32.2 | 44.5 | 45.8 | -- | -- | 129 | 130 | 127 | 60.5 | 59.5 |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 10 | 9 | 8 | 8 | 8 | 8 | 7.2 | 6.3 | 7.8 | 7.7 | -- | -- | 30.4 | 30.4 | 19.8 | 18.4 | 18.1 |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | -- | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | -- | -- | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | NA | 2 | 100 | < 1 | < 1 | < 1 | < 1 | 1 | 2 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | -- | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | < 15.0 | < 15.0 | -- | -- | < 15.0 | < 15.0 | < 15.0 | < 6.0 | < 6.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | -- | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 40 | 10 | 40 | 12.1 | 10.1 | < 10 | < 10 | 11 | < 10 | < 10 | < 10 | 11 | < 10 | -- | -- | 28 | 28 | 19 | 68 | 67 |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | -- | -- | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | 10 | 93 | 18 | 18 | 16 | 48 | 21.4 | 19.2 | 19.0 | 19.0 | -- | -- | 12.6 | 12.7 | 7.5 | 9.2 | 9.0 |
| Radium-226 | pCi/L | NC | NA | NA | NA | < 0.330 | < 0.244 | < 0.219 | < 0.487 | < 0.251 | < 0.409 | < 0.562 | < 0.154 | 0.749 | 0.949 | -- | -- | < 0.823 | < 0.530 | < 0.620 | < 1.09 | 0.921 |
| Radium-228 | pCi/L | NC | NA | NA | NA | 0.986 | < 0.737 | < 0.649 | 2.83 | < 0.496 | < 0.702 | < 0.765 | < 0.690 | < 0.797 | < 0.790 | -- | -- | < 0.729 | < 1.33 | < 1.58 | 1.04 | 0.767 |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | 1.09 | < 0.737 | < 0.649 | 2.9 | < 0.496 | < 0.702 | < 1.33 | < 0.844 | < 1.43 | < 1.26 | -- | -- | < 1.55 | < 1.86 | < 2.20 | < 1.70 | 1.69 |
| Selenium | ug/L | 50 | NA | 5 | 50 | < 1 | 4 | < 1 | < 1 | 2 | 4 | 7.8 | 7.3 | 3.5 | 5.1 | -- | -- | < 1.0 | < 1.0 | < 1.0 | 2.5 | 2.8 |
| Thallium | ug/L | 2 | NA | 2 | 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | -- | -- | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 |

Notes:

- ug/L - micrograms per liter.
- mg/L - milligrams per liter.
- SU - standard units; pH is a field parameter.
- pCi/L - picocuries per liter.
- NA - not applicable.
- NC - no criteria.
- - not analyzed.
- MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April, 2012.
- RSL - Regional Screening Level from 83 FR 36435.
- UTL - Upper Tolerance Limit (95%) of the background data set.
- GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
- * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April, 2012.
- Bold** value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
- All metals were analyzed as total unless otherwise specified.
- (1) pH value potentially biased high due to groundwater quality meter malfunction.
- (2) JHC-MW-15004 was decommissioned on June 14th, 2018.

Table C1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to November 2018
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15003 | | | | | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|------------|--------------|-----------|-----------|-----------|------------|-----------|-------------|-------------|-----------|-------------|-------------|-------------|-------------|--|
| Sample Date: | | | | | | 12/5/2015 | 3/8/2016 | 6/21/2016 | 8/29/2016 | 11/15/2016 | 4/18/2017 | 6/20/2017 | 8/14/2017 | 9/25/2017 | 4/25/2018 | 6/18/2018 | 6/18/2018 | 11/15/2018 | |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | | | | Field Dup | |
| Boron | ug/L | NC | NA | 51 | NA | 439 | 455 | 426 | 882 | 1,670 | 1,280 | 1,240 | 1,150 | 1,120 | -- | 1,170 | 1,320 | 1,120 | |
| Calcium | mg/L | NC | NA | 46 | NA | 27.9 | 46.7 | 38.3 | 44.3 | 31.8 | 34.6 | 28.8 | 36.0 | 30.1 | -- | 60.0 | 59.1 | 115 | |
| Chloride | mg/L | 250* | NA | 43 | NA | 21.7 | 25.7 | 28.5 | 20.1 | 30.8 | 27.9 | 24.0 | 22.0 | 19.3 | -- | 37.5 | 36.6 | 16.3 | |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | |
| Sulfate | mg/L | 250* | NA | 14 | NA | 41.3 | 52.7 | 48.1 | 45.8 | 63.0 | 71.8 | 61.8 | 61.9 | 51.9 | -- | 81.9 | 82.7 | 294 | |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 160 | 200 | 190 | 220 | 230 | 260 | 146 | 208 | 136 | -- | 388 | 344 | 644 | |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 9.0 | 9.3 | 9.2 | 9.1 | 8.6 | 8.7 | 9.3 | 9.3 | 9.7 | 9.3 | 8.9 | -- | 8.7 | |
| Appendix IV | | | | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | < 1 | < 1 | < 1 | < 1 | 2 | 1 | < 1.0 | 1.3 | -- | 1.5 | 1.9 | 1.8 | 2.0 | |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 38 | 31 | 27 | 27 | 36 | 26 | 20.4 | 23.7 | -- | 12.4 | 14.1 | 14.3 | 8.1 | |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 21 | 16 | 15 | 19 | 18 | 16 | 18.0 | 18.0 | -- | 42.3 | 55.7 | 52.5 | 113 | |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 | 1.7 | |
| Chromium | ug/L | 100 | NA | 2 | 100 | 2 | 5 | 2 | 1 | 5 | 12 | 12.3 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | 13.6 | |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | -- | < 15.0 | < 15.0 | < 15.0 | 23.6 | |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | 3.3 | |
| Lithium | ug/L | NC | 40 | 10 | 40 | 11.1 | < 10 | < 10 | < 10 | 11 | < 10 | < 10 | < 10 | -- | < 10 | < 10 | < 10 | < 10 | |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 | < 0.20 | |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | 9 | 11 | 20 | 13 | 24 | 30 | 21.1 | 28.2 | -- | 19.3 | 53.0 | 51.2 | 65.3 | |
| Radium-226 | pCi/L | NC | NA | NA | NA | < 0.250 | < 0.236 | < 0.211 | < 0.365 | < 0.249 | < 0.302 | < 1.12 | 1.15 | -- | < 0.631 | < 0.623 | < 0.733 | < 0.579 | |
| Radium-228 | pCi/L | NC | NA | NA | NA | < 0.412 | < 0.575 | < 0.539 | < 0.724 | < 0.369 | 0.633 | < 0.722 | < 0.938 | -- | < 0.732 | < 1.01 | < 1.08 | < 0.657 | |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | < 0.412 | < 0.575 | < 0.539 | < 0.724 | < 0.369 | 0.769 | < 1.84 | 1.81 | -- | < 1.36 | < 1.63 | < 1.81 | < 1.24 | |
| Selenium | ug/L | 50 | NA | 5 | 50 | < 1 | 3 | < 1 | < 1 | 2 | 3 | < 1.0 | 1.1 | -- | 2.2 | 4.4 | 4.5 | 28.6 | |
| Thallium | ug/L | 2 | NA | 2 | 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2.0 | < 2.0 | -- | < 2.0 | < 2.0 | < 2.0 | < 2.0 | |

Notes:

- ug/L - micrograms per liter.
- mg/L - milligrams per liter.
- SU - standard units; pH is a field parameter.
- pCi/L - picocuries per liter.
- NA - not applicable.
- NC - no criteria.
- - not analyzed.
- MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April, 2012.
- RSL - Regional Screening Level from 83 FR 36435.
- UTL - Upper Tolerance Limit (95%) of the background data set.
- GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
- * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April, 2012.
- Bold** value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
- All metals were analyzed as total unless otherwise specified.
- (1) pH value potentially biased high due to groundwater quality meter malfunction.
- (2) JHC-MW-15004 was decommissioned on June 14th, 2018.

Table C1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to November 2018
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15004 ⁽²⁾ | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|------------|-----------------------------|----------|-----------|-----------|------------|-----------|-----------|------------|-----------|-----------|
| Sample Date: | | | | | | 12/5/2015 | 3/8/2016 | 6/22/2016 | 8/30/2016 | 11/15/2016 | 4/18/2017 | 6/20/2017 | 8/14/2017 | 9/25/2017 | 4/25/2018 |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | NA | 51 | NA | 546 | 268 | 412 | 469 | 578 | 260 | 473 | 660 | 376 | -- |
| Calcium | mg/L | NC | NA | 46 | NA | 43.1 | 42.8 | 45.8 | 64.6 | 101 | 36.9 | 37.7 | 51.2 | 78.6 | -- |
| Chloride | mg/L | 250* | NA | 43 | NA | 41.6 | 35.5 | 26.4 | 23.7 | 70.8 | 46.8 | 67.5 | 95.1 | 41.5 | -- |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250* | NA | 14 | NA | 55.0 | 42.5 | 48.7 | 47.8 | 244 | 58.6 | 85.6 | 122 | 64.6 | -- |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 290 | 220 | 230 | 370 | 560 | 290 | 322 | 402 | 382 | -- |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 7.6 | 7.3 | 7.1 | 6.8 | 7.3 | 7.6 | 7.4 | 7.6 | 7.1 | 7.3 |
| Appendix IV | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | < 1 | < 1 | 1 | 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 21 | 9 | 11 | 8 | 6 | 4 | 4.8 | 5.7 | -- | 3.6 |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 73 | 65 | 117 | 181 | 241 | 110 | 93.2 | 193 | -- | 162 |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 |
| Chromium | ug/L | 100 | NA | 2 | 100 | 1 | 1 | 1 | 1 | 1 | 3 | 6.9 | < 1.0 | -- | < 1.0 |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | -- | < 15.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 |
| Lithium | ug/L | NC | 40 | 10 | 40 | < 10 | < 10 | < 10 | 12 | 12 | < 10 | < 10 | 10 | -- | < 10 |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | 9 | 8 | 10 | 5 | 10 | 6 | 10.1 | 11.2 | -- | < 5.0 |
| Radium-226 | pCi/L | NC | NA | NA | NA | < 0.295 | 0.259 | < 0.189 | < 0.29 | < 0.311 | < 0.333 | < 0.502 | 0.915 | -- | < 0.449 |
| Radium-228 | pCi/L | NC | NA | NA | NA | 0.422 | 0.452 | 0.605 | 1.62 | 0.856 | 0.366 | < 0.685 | < 0.920 | -- | < 0.787 |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | 0.702 | 0.711 | 0.633 | 1.85 | 1.12 | 0.497 | < 1.19 | 1.66 | -- | < 1.24 |
| Selenium | ug/L | 50 | NA | 5 | 50 | 8 | 2 | 2 | 7 | 1 | 2 | < 1.0 | < 1.0 | -- | 5.5 |
| Thallium | ug/L | 2 | NA | 2 | 2 | 2.16 | < 2 | 2 | 4 | 3 | < 2 | < 2.0 | 2.1 | -- | < 2.0 |

Notes:

- ug/L - micrograms per liter.
- mg/L - milligrams per liter.
- SU - standard units; pH is a field parameter.
- pCi/L - picocuries per liter.
- NA - not applicable.
- NC - no criteria.
- - not analyzed.
- MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April, 2012.
- RSL - Regional Screening Level from 83 FR 36435.
- UTL - Upper Tolerance Limit (95%) of the background data set.
- GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
- * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April, 2012.
- Bold** value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
- All metals were analyzed as total unless otherwise specified.
- (1) pH value potentially biased high due to groundwater quality meter malfunction.
- (2) JHC-MW-15004 was decommissioned on June 14th, 2018.

Table C1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to November 2018
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15005 | | | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|------------|--------------|----------|-----------|-----------|------------|-----------|-----------|-----------|-----------|------------|------------|------------|
| Sample Date: | | | | | | 12/5/2015 | 3/8/2016 | 6/22/2016 | 8/30/2016 | 11/15/2016 | 4/18/2017 | 6/20/2017 | 8/14/2017 | 9/25/2017 | 4/25/2018 | 6/19/2018 | 11/15/2018 |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | NA | 51 | NA | 275 | 959 | 1,370 | 706 | 1,500 | 524 | 468 | 546 | 481 | -- | 227 | 1,450 |
| Calcium | mg/L | NC | NA | 46 | NA | 55.0 | 60.2 | 55.1 | 51.6 | 73.4 | 56.8 | 53.6 | 48.0 | 40.3 | -- | 61.8 | 61.9 |
| Chloride | mg/L | 250* | NA | 43 | NA | 27.7 | 42.0 | 46.9 | 19.2 | 29.3 | 64.2 | 50.4 | 27.1 | 21.8 | -- | 90.9 | 30.6 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250* | NA | 14 | NA | 51.2 | 53.0 | 57.9 | 46.5 | 61.8 | 58.3 | 66.0 | 64.9 | 61.9 | -- | 74.3 | 133 |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 270 | 300 | 310 | 230 | 320 | 360 | 306 | 282 | 300 | -- | 462 | 334 |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 7.3 | 7.4 | 7.4 | 7.3 | 7.1 | 7.5 | 7.4 | 7.5 | 7.4 | 7.4 | 7.4 | 7.5 |
| Appendix IV | | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | 4 | 2 | 2 | 3 | 5 | 3 | 3.8 | 4.2 | -- | 2.2 | 1.6 | 5.1 |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 4 | 3 | 3 | 5 | 3 | 2 | 3.3 | 2.5 | -- | 1.7 | 1.3 | 1.2 |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 99 | 74 | 97 | 72 | 159 | 128 | 113 | 109 | -- | 407 | 175 | 149 |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | NA | 2 | 100 | 4 | 5 | 12 | 2 | 3 | 4 | 3.7 | < 1.0 | -- | < 1.0 | 3.0 | < 1.0 |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | -- | < 15.0 | < 15.0 | < 6.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 40 | 10 | 40 | 41.3 | 25.5 | 28 | 31 | 49 | 38 | 39 | 36 | -- | 61 | 35 | 28 |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | 12 | 13 | 25 | 16 | 15 | 18 | 14.0 | 10 | -- | 31.2 | 15.7 | 222 |
| Radium-226 | pCi/L | NC | NA | NA | NA | < 0.277 | < 0.355 | 0.192 | < 0.286 | < 0.246 | 0.461 | < 0.717 | < 0.877 | -- | 0.620 | < 0.758 | < 0.461 |
| Radium-228 | pCi/L | NC | NA | NA | NA | 0.436 | < 0.426 | < 0.395 | 1.58 | 0.745 | < 0.383 | < 0.728 | < 0.856 | -- | 0.700 | 1.220 | 0.967 |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | 0.564 | < 0.426 | < 0.395 | 1.78 | 0.974 | 0.841 | < 1.45 | < 1.73 | -- | 1.32 | 1.91 | 1.41 |
| Selenium | ug/L | 50 | NA | 5 | 50 | 28 | 12 | 33 | 18 | 165 | 10 | 15.5 | 15.7 | -- | 368 | 14 | 158 |
| Thallium | ug/L | 2 | NA | 2 | 2 | 3.04 | < 2 | 2 | 2 | 4 | < 2 | < 2.0 | < 2.0 | -- | 5.8 | 2.1 | < 2.0 |

Notes:

- ug/L - micrograms per liter.
- mg/L - milligrams per liter.
- SU - standard units; pH is a field parameter.
- pCi/L - picocuries per liter.
- NA - not applicable.
- NC - no criteria.
- - not analyzed.
- MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April, 2012.
- RSL - Regional Screening Level from 83 FR 36435.
- UTL - Upper Tolerance Limit (95%) of the background data set.
- GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
- * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April, 2012.
- Bold** value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
- All metals were analyzed as total unless otherwise specified.
- (1) pH value potentially biased high due to groundwater quality meter malfunction.
- (2) JHC-MW-15004 was decommissioned on June 14th, 2018.

Attachment C1
Sanitas™ Output

Summary Report

Constituent: Antimony, Total Analysis Run 2/20/2019 2:39 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

For observations made between 12/5/2015 and 11/15/2018, a summary of the selected data set:

Observations = 44
ND/Trace = 22
Wells = 4
Minimum Value = 1
Maximum Value = 5.1
Mean Value = 1.833
Median Value = 1
Standard Deviation = 1.207
Coefficient of Variation = 0.6584
Skewness = 1.347

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 11 | 11 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15002 | 11 | 6 | 1 | 4 | 1.736 | 1 | 1.116 | 0.6425 | 1.01 |
| JHC-MW-15003 | 11 | 5 | 1 | 2 | 1.332 | 1 | 0.4303 | 0.3231 | 0.6864 |
| JHC-MW-15005 | 11 | 0 | 1.6 | 5.1 | 3.264 | 3 | 1.238 | 0.3793 | 0.1616 |

Summary Report

Constituent: Arsenic, Total Analysis Run 2/20/2019 2:39 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

For observations made between 12/5/2015 and 11/15/2018, a summary of the selected data set:

Observations = 44
ND/Trace = 1
Wells = 4
Minimum Value = 1
Maximum Value = 129.5
Mean Value = 21.7
Median Value = 10.25
Standard Deviation = 28.52
Coefficient of Variation = 1.314
Skewness = 2.415

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 11 | 1 | 1 | 12.7 | 3.864 | 3 | 3.231 | 0.8363 | 2.027 |
| JHC-MW-15002 | 11 | 0 | 33 | 129.5 | 56.22 | 40 | 36.5 | 0.6492 | 1.483 |
| JHC-MW-15003 | 11 | 0 | 8.1 | 38 | 23.98 | 26 | 9.526 | 0.3972 | -0.1992 |
| JHC-MW-15005 | 11 | 0 | 1.2 | 5 | 2.727 | 3 | 1.155 | 0.4235 | 0.4151 |

Summary Report

Constituent: Barium, Total Analysis Run 2/20/2019 2:39 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

For observations made between 12/5/2015 and 11/15/2018, a summary of the selected data set:

Observations = 44
ND/Trace = 0
Wells = 4
Minimum Value = 6.75
Maximum Value = 407
Mean Value = 81.51
Median Value = 71.7
Standard Deviation = 78.87
Coefficient of Variation = 0.9675
Skewness = 1.639

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 11 | 0 | 71.4 | 183 | 138.2 | 148 | 35.84 | 0.2593 | -0.7409 |
| JHC-MW-15002 | 11 | 0 | 6.75 | 30.4 | 12.18 | 8 | 7.488 | 0.6149 | 1.533 |
| JHC-MW-15003 | 11 | 0 | 15 | 113 | 31.85 | 18 | 29.72 | 0.9331 | 2.086 |
| JHC-MW-15005 | 11 | 0 | 72 | 407 | 143.8 | 113 | 93.35 | 0.6491 | 2.229 |

Summary Report

Constituent: Beryllium, Total Analysis Run 2/20/2019 2:39 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

For observations made between 12/5/2015 and 11/15/2018, a summary of the selected data set:

Observations = 44
ND/Trace = 44
Wells = 4
Minimum Value = 1
Maximum Value = 1
Mean Value = 1
Median Value = 1
Standard Deviation = 0
Coefficient of Variation = 0
Skewness = NaN

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 11 | 11 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15002 | 11 | 11 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15003 | 11 | 11 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15005 | 11 | 11 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |

Summary Report

Constituent: Cadmium, Total Analysis Run 2/20/2019 2:39 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

For observations made between 12/5/2015 and 11/15/2018, a summary of the selected data set:

Observations = 44
ND/Trace = 43
Wells = 4
Minimum Value = 0.2
Maximum Value = 1.7
Mean Value = 0.2341
Median Value = 0.2
Standard Deviation = 0.2261
Coefficient of Variation = 0.966
Skewness = 6.405

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 11 | 11 | 0.2 | 0.2 | 0.2 | 0.2 | 0 | 0 | NaN |
| JHC-MW-15002 | 11 | 11 | 0.2 | 0.2 | 0.2 | 0.2 | 0 | 0 | NaN |
| JHC-MW-15003 | 11 | 10 | 0.2 | 1.7 | 0.3364 | 0.2 | 0.4523 | 1.345 | 2.846 |
| JHC-MW-15005 | 11 | 11 | 0.2 | 0.2 | 0.2 | 0.2 | 0 | 0 | NaN |

Summary Report

Constituent: Chromium, Total Analysis Run 2/20/2019 2:39 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

For observations made between 12/5/2015 and 11/15/2018, a summary of the selected data set:

Observations = 44
ND/Trace = 18
Wells = 4
Minimum Value = 1
Maximum Value = 13.6
Mean Value = 2.832
Median Value = 1
Standard Deviation = 3.32
Coefficient of Variation = 1.173
Skewness = 2.266

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 11 | 3 | 1 | 3 | 1.545 | 1 | 0.6876 | 0.4449 | 0.8 |
| JHC-MW-15002 | 11 | 9 | 1 | 2 | 1.091 | 1 | 0.3015 | 0.2764 | 2.846 |
| JHC-MW-15003 | 11 | 3 | 1 | 13.6 | 5.082 | 2 | 5.081 | 0.9999 | 0.7953 |
| JHC-MW-15005 | 11 | 3 | 1 | 12 | 3.609 | 3 | 3.105 | 0.8603 | 1.877 |

Summary Report

Constituent: Cobalt, Total Analysis Run 2/20/2019 2:39 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

For observations made between 12/5/2015 and 11/15/2018, a summary of the selected data set:

Observations = 44
ND/Trace = 43
Wells = 4
Minimum Value = 6
Maximum Value = 23.6
Mean Value = 14.58
Median Value = 15
Standard Deviation = 2.682
Coefficient of Variation = 0.1839
Skewness = -1.414

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 11 | 11 | 6 | 15 | 14.18 | 15 | 2.714 | 0.1913 | -2.846 |
| JHC-MW-15002 | 11 | 11 | 6 | 15 | 14.18 | 15 | 2.714 | 0.1913 | -2.846 |
| JHC-MW-15003 | 11 | 10 | 15 | 23.6 | 15.78 | 15 | 2.593 | 0.1643 | 2.846 |
| JHC-MW-15005 | 11 | 11 | 6 | 15 | 14.18 | 15 | 2.714 | 0.1913 | -2.846 |

Summary Report

Constituent: Fluoride Analysis Run 2/20/2019 2:39 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

For observations made between 12/5/2015 and 11/15/2018, a summary of the selected data set:

Observations = 48
ND/Trace = 48
Wells = 4
Minimum Value = 1000
Maximum Value = 1000
Mean Value = 1000
Median Value = 1000
Standard Deviation = 0
Coefficient of Variation = 0
Skewness = NaN

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 12 | 12 | 1000 | 1000 | 1000 | 1000 | 0 | 0 | NaN |
| JHC-MW-15002 | 12 | 12 | 1000 | 1000 | 1000 | 1000 | 0 | 0 | NaN |
| JHC-MW-15003 | 12 | 12 | 1000 | 1000 | 1000 | 1000 | 0 | 0 | NaN |
| JHC-MW-15005 | 12 | 12 | 1000 | 1000 | 1000 | 1000 | 0 | 0 | NaN |

Summary Report

Constituent: Lead, Total Analysis Run 2/20/2019 2:39 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

For observations made between 12/5/2015 and 11/15/2018, a summary of the selected data set:

Observations = 44
ND/Trace = 43
Wells = 4
Minimum Value = 1
Maximum Value = 3.3
Mean Value = 1.052
Median Value = 1
Standard Deviation = 0.3467
Coefficient of Variation = 0.3295
Skewness = 6.405

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 11 | 11 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15002 | 11 | 11 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15003 | 11 | 10 | 1 | 3.3 | 1.209 | 1 | 0.6935 | 0.5736 | 2.846 |
| JHC-MW-15005 | 11 | 11 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |

Summary Report

Constituent: Lithium, Total Analysis Run 2/20/2019 2:39 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

For observations made between 12/5/2015 and 11/15/2018, a summary of the selected data set:

Observations = 44
ND/Trace = 24
Wells = 4
Minimum Value = 10
Maximum Value = 67.5
Mean Value = 18.91
Median Value = 10
Standard Deviation = 14.93
Coefficient of Variation = 0.7893
Skewness = 1.67

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 11 | 11 | 10 | 10 | 10 | 10 | 0 | 0 | NaN |
| JHC-MW-15002 | 11 | 4 | 10 | 67.5 | 18.02 | 10.5 | 17.35 | 0.9628 | 2.383 |
| JHC-MW-15003 | 11 | 9 | 10 | 11.1 | 10.19 | 10 | 0.4253 | 0.04174 | 1.661 |
| JHC-MW-15005 | 11 | 0 | 25.5 | 61 | 37.44 | 36 | 10.38 | 0.2772 | 1.035 |

Summary Report

Constituent: Mercury, Total Analysis Run 2/20/2019 2:39 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

For observations made between 12/5/2015 and 11/15/2018, a summary of the selected data set:

Observations = 44
ND/Trace = 44
Wells = 4
Minimum Value = 0.2
Maximum Value = 0.2
Mean Value = 0.2
Median Value = 0.2
Standard Deviation = 0
Coefficient of Variation = 0
Skewness = NaN

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 11 | 11 | 0.2 | 0.2 | 0.2 | 0.2 | 0 | 0 | NaN |
| JHC-MW-15002 | 11 | 11 | 0.2 | 0.2 | 0.2 | 0.2 | 0 | 0 | NaN |
| JHC-MW-15003 | 11 | 11 | 0.2 | 0.2 | 0.2 | 0.2 | 0 | 0 | NaN |
| JHC-MW-15005 | 11 | 11 | 0.2 | 0.2 | 0.2 | 0.2 | 0 | 0 | NaN |

Summary Report

Constituent: Molybdenum, Total Analysis Run 2/20/2019 2:39 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

For observations made between 12/5/2015 and 11/15/2018, a summary of the selected data set:

Observations = 44
ND/Trace = 10
Wells = 4
Minimum Value = 5
Maximum Value = 222
Mean Value = 23.18
Median Value = 14.5
Standard Deviation = 35.18
Coefficient of Variation = 1.518
Skewness = 4.449

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 11 | 10 | 5 | 13.3 | 5.755 | 5 | 2.503 | 0.4349 | 2.846 |
| JHC-MW-15002 | 11 | 0 | 7.5 | 93 | 24.69 | 18 | 25.15 | 1.019 | 2.084 |
| JHC-MW-15003 | 11 | 0 | 9 | 65.3 | 26.64 | 21.1 | 17.42 | 0.6539 | 1.223 |
| JHC-MW-15005 | 11 | 0 | 10 | 222 | 35.63 | 15.7 | 62.11 | 1.743 | 2.797 |

Summary Report

Constituent: Radium-226 Analysis Run 2/20/2019 2:39 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

For observations made between 12/5/2015 and 11/15/2018, a summary of the selected data set:

Observations = 44
ND/Trace = 37
Wells = 4
Minimum Value = 0.192
Maximum Value = 1.63
Mean Value = 0.5284
Median Value = 0.435
Standard Deviation = 0.3125
Coefficient of Variation = 0.5915
Skewness = 1.307

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 11 | 10 | 0.211 | 1.63 | 0.5795 | 0.389 | 0.4065 | 0.7015 | 1.64 |
| JHC-MW-15002 | 11 | 9 | 0.219 | 1.006 | 0.5272 | 0.487 | 0.2712 | 0.5144 | 0.4572 |
| JHC-MW-15003 | 11 | 10 | 0.211 | 1.15 | 0.5296 | 0.365 | 0.348 | 0.6571 | 0.8366 |
| JHC-MW-15005 | 11 | 8 | 0.192 | 0.877 | 0.4773 | 0.461 | 0.2331 | 0.4885 | 0.4158 |

Summary Report

Constituent: Radium-226/228 Analysis Run 2/20/2019 2:39 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

For observations made between 12/5/2015 and 11/15/2018, a summary of the selected data set:

Observations = 44
ND/Trace = 25
Wells = 4
Minimum Value = 0.369
Maximum Value = 2.9
Mean Value = 1.362
Median Value = 1.42
Standard Deviation = 0.6433
Coefficient of Variation = 0.4723
Skewness = 0.1074

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 11 | 4 | 1.34 | 2.58 | 1.872 | 1.89 | 0.3554 | 0.1899 | 0.4857 |
| JHC-MW-15002 | 11 | 8 | 0.496 | 2.9 | 1.372 | 1.33 | 0.7476 | 0.545 | 0.6677 |
| JHC-MW-15003 | 11 | 9 | 0.369 | 1.84 | 1.041 | 0.769 | 0.5877 | 0.5647 | 0.326 |
| JHC-MW-15005 | 11 | 4 | 0.395 | 1.91 | 1.164 | 1.32 | 0.5531 | 0.4753 | -0.1473 |

Summary Report

Constituent: Radium-228 Analysis Run 2/20/2019 2:39 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

For observations made between 12/5/2015 and 11/15/2018, a summary of the selected data set:

Observations = 44
ND/Trace = 27
Wells = 4
Minimum Value = 0.369
Maximum Value = 2.83
Mean Value = 0.9704
Median Value = 0.781
Standard Deviation = 0.5331
Coefficient of Variation = 0.5493
Skewness = 1.483

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 11 | 4 | 0.628 | 2.24 | 1.373 | 1.34 | 0.5134 | 0.3738 | 0.2232 |
| JHC-MW-15002 | 11 | 8 | 0.496 | 2.83 | 1.071 | 0.797 | 0.6619 | 0.6183 | 1.878 |
| JHC-MW-15003 | 11 | 10 | 0.369 | 1.08 | 0.671 | 0.657 | 0.2084 | 0.3106 | 0.4613 |
| JHC-MW-15005 | 11 | 5 | 0.383 | 1.58 | 0.7669 | 0.728 | 0.3785 | 0.4935 | 0.8804 |

Summary Report

Constituent: Selenium, Total Analysis Run 2/20/2019 2:39 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

For observations made between 12/5/2015 and 11/15/2018, a summary of the selected data set:

Observations = 44
ND/Trace = 17
Wells = 4
Minimum Value = 1
Maximum Value = 368
Mean Value = 21.05
Median Value = 2
Standard Deviation = 63.29
Coefficient of Variation = 3.007
Skewness = 4.369

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 11 | 8 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15002 | 11 | 5 | 1 | 7.55 | 2.682 | 2 | 2.107 | 0.7857 | 1.122 |
| JHC-MW-15003 | 11 | 4 | 1 | 28.6 | 4.395 | 2 | 8.107 | 1.844 | 2.747 |
| JHC-MW-15005 | 11 | 0 | 10 | 368 | 76.11 | 18 | 112.7 | 1.481 | 1.795 |

Summary Report


Constituent: Thallium, Total Analysis Run 2/20/2019 2:39 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

For observations made between 12/5/2015 and 11/15/2018, a summary of the selected data set:

Observations = 44
ND/Trace = 38
Wells = 4
Minimum Value = 2
Maximum Value = 5.8
Mean Value = 2.158
Median Value = 2
Standard Deviation = 0.6548
Coefficient of Variation = 0.3035
Skewness = 4.617

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 11 | 11 | 2 | 2 | 2 | 2 | 0 | 0 | NaN |
| JHC-MW-15002 | 11 | 11 | 2 | 2 | 2 | 2 | 0 | 0 | NaN |
| JHC-MW-15003 | 11 | 11 | 2 | 2 | 2 | 2 | 0 | 0 | NaN |
| JHC-MW-15005 | 11 | 5 | 2 | 5.8 | 2.631 | 2 | 1.231 | 0.4679 | 1.83 |


Time Series



Constituent: Cobalt, Total Analysis Run 2/20/2019 12:42 PM
Client: Consumers Energy Data: JHC_Sanitas_19.02.18

Parametric and Non-Parametric (NP) Confidence Interval

Compliance limit is exceeded.* Per-well alpha = 0.01 except as noted. Normality Test: Shapiro Wilk, alpha based on



Constituent: Arsenic, Total Analysis Run 2/20/2019 12:45 PM

Client: Consumers Energy Data: JHC_Sanitas_19.02.18


Confidence Interval

Constituent: Arsenic, Total (ug/L) Analysis Run 2/20/2019 12:45 PM

Client: Consumers Energy Data: JHC_Sanitas_19.02.18

| | JHC-MW-15001 | JHC-MW-15002 | JHC-MW-15003 |
|------------|--------------|--------------|--------------|
| 8/29/2016 | 4 | | 27 |
| 8/30/2016 | | 34 | |
| 11/15/2016 | 3 | 46 | 36 |
| 4/18/2017 | | | 26 |
| 4/19/2017 | 4 | 33 | |
| 6/20/2017 | 1.8 | 33.8 (D) | 20.4 |
| 8/14/2017 | 2.2 | 45.15 (D) | 23.7 |
| 4/25/2018 | <1 | 129.5 (D) | 12.4 |
| 6/18/2018 | 1.8 | | 14.2 (D) |
| 6/19/2018 | | 127 | |
| 11/13/2018 | 12.7 | | |
| 11/15/2018 | | 60 (D) | 8.1 |
| Mean | 3.75 | 63.56 | 20.98 |
| Std. Dev. | 3.805 | 40.93 | 9.105 |
| Upper Lim. | 7.067 | 129.5 | 30.63 |
| Lower Lim. | 0.7815 | 33 | 11.32 |

Time Series




Constituent: Lithium, Total Analysis Run 2/20/2019 12:42 PM

Client: Consumers Energy Data: JHC_Sanitas_19.02.18

Parametric Confidence Interval

Compliance Limit is not exceeded. Per-well alpha = 0.01. Normality Test: Shapiro Wilk, alpha based on n.



Constituent: Lithium, Total Analysis Run 2/20/2019 12:46 PM

Client: Consumers Energy Data: JHC_Sanitas_19.02.18


Confidence Interval

Constituent: Lithium, Total (ug/L) Analysis Run 2/20/2019 12:46 PM

Client: Consumers Energy Data: JHC_Sanitas_19.02.18

| | JHC-MW-15002 | JHC-MW-15005 |
|------------|--------------|--------------|
| 8/30/2016 | <10 | 31 |
| 11/15/2016 | 11 | 49 |
| 4/18/2017 | | 38 |
| 4/19/2017 | <10 | |
| 6/20/2017 | <10 (D) | 39 |
| 8/14/2017 | 8 (D) | 36 |
| 4/25/2018 | 28 (D) | 61 |
| 6/19/2018 | 19 | 35 |
| 11/15/2018 | 67.5 (D) | 28 |
| Mean | 18.56 | 39.63 |
| Std. Dev. | 21.4 | 10.64 |
| Upper Lim. | 34.54 | 50.9 |
| Lower Lim. | 3.816 | 28.35 |

Time Series




Constituent: Molybdenum, Total Analysis Run 2/20/2019 12:43 PM

Client: Consumers Energy Data: JHC_Sanitas_19.02.18

Non-Parametric Confidence Interval

Compliance Limit is not exceeded.



Constituent: Molybdenum, Total Analysis Run 2/20/2019 12:47 PM

Client: Consumers Energy Data: JHC_Sanitas_19.02.18

Confidence Interval


Constituent: Molybdenum, Total (ug/L) Analysis Run 2/20/2019 12:47 PM

Client: Consumers Energy Data: JHC_Sanitas_19.02.18

JHC-MW-15005

| | |
|------------|-------|
| 8/30/2016 | 16 |
| 11/15/2016 | 15 |
| 4/18/2017 | 18 |
| 6/20/2017 | 14 |
| 8/14/2017 | 10 |
| 4/25/2018 | 31.2 |
| 6/19/2018 | 15.7 |
| 11/15/2018 | 222 |
| Mean | 42.74 |
| Std. Dev. | 72.7 |
| Upper Lim. | 222 |
| Lower Lim. | 10 |

Time Series




Constituent: Selenium, Total Analysis Run 2/20/2019 12:43 PM

Client: Consumers Energy Data: JHC_Sanitas_19.02.18

Non-Parametric Confidence Interval

Compliance Limit is not exceeded.



Constituent: Selenium, Total Analysis Run 2/20/2019 12:47 PM

Client: Consumers Energy Data: JHC_Sanitas_19.02.18

Confidence Interval


Constituent: Selenium, Total (ug/L) Analysis Run 2/20/2019 12:47 PM

Client: Consumers Energy Data: JHC_Sanitas_19.02.18

JHC-MW-15005

| | |
|------------|-------|
| 8/30/2016 | 18 |
| 11/15/2016 | 165 |
| 4/18/2017 | 10 |
| 6/20/2017 | 15.5 |
| 8/14/2017 | 15.7 |
| 4/25/2018 | 368 |
| 6/19/2018 | 14 |
| 11/15/2018 | 158 |
| Mean | 95.53 |
| Std. Dev. | 128.6 |
| Upper Lim. | 368 |
| Lower Lim. | 10 |

Time Series




Constituent: Thallium, Total Analysis Run 2/20/2019 12:43 PM

Client: Consumers Energy Data: JHC_Sanitas_19.02.18

Non-Parametric Confidence Interval

Compliance Limit is not exceeded.



Constituent: Thallium, Total Analysis Run 2/20/2019 12:48 PM

Client: Consumers Energy Data: JHC_Sanitas_19.02.18

Confidence Interval

Constituent: Thallium, Total (ug/L) Analysis Run 2/20/2019 12:49 PM

Client: Consumers Energy Data: JHC_Sanitas_19.02.18

JHC-MW-15005

| | |
|------------|-------|
| 8/30/2016 | 2 |
| 11/15/2016 | 4 |
| 4/18/2017 | <2 |
| 6/20/2017 | <2 |
| 8/14/2017 | <2 |
| 4/25/2018 | 5.8 |
| 6/19/2018 | 2.1 |
| 11/15/2018 | <2 |
| Mean | 2.738 |
| Std. Dev. | 1.419 |
| Upper Lim. | 5.8 |
| Lower Lim. | 2 |

Appendix D

Data Quality Review

Laboratory Data Quality Review

Groundwater Sample Event February 2019

Consumers Energy JH Campbell Ponds 1 and 2

Groundwater samples were collected by TRC for the February 2019 JH Campbell Ponds 1 and 2 sampling event. Samples were analyzed for anions, total metals, alkalinity, total dissolved solids, and pH by Eurofins TestAmerica Laboratories (Eurofins TA), located in Irvine, CA and for radium by Eurofins TA in St. Louis, MO. The laboratory analytical results are reported in laboratory reports 440-235147-1 and 440-235151-1.

During the February 2019 sampling event, a groundwater sample was collected from each of the following wells:

- JHC-MW-18004
- JHC-MW-18005

Each sample was analyzed for the following constituents:

| Analyte Group | Method |
|--|-------------------------------|
| Anions (Chloride, Fluoride, Sulfate) | EPA 300.0 |
| Total Dissolved Solids | SM 2540C |
| Total Metals | SW846 3005A/6010B/6020A/7470A |
| Radium (Radium-226, Radium-228, Combined Radium) | EPA 903.0, EPA 904.0 |
| Alkalinity (Total, Carbonate, Bicarbonate) | SM 2320B |
| pH | SM 4500 H + B |

TRC reviewed the laboratory data to assess data usability. The following sections summarize the data review procedure and the results of the review

Data Quality Review Procedure

The analytical data were reviewed using the USEPA National Functional Guidelines for Inorganic Superfund Data Review (USEPA, 2017) and the Department of Energy Evaluation of Radiochemical Data Usability (USDOE, 1997). The following items were included in the evaluation of the data:

- Sample receipt, as noted in the cover page or case narrative;
- Technical holding times for analyses;
- Reporting limits (RLs) compared to project-required RLs;

- Data for method blanks, equipment blanks, and field blanks, if applicable. Method blanks are used to assess potential contamination arising from laboratory sample preparation and/or analytical procedures. Field and equipment blanks are used to assess potential contamination arising from field procedures;
- Data for laboratory control samples (LCSs). The LCSs are used to assess the accuracy of the analytical method using a clean matrix;
- Data for matrix spike (MS) and matrix spike duplicate (MSD) samples, when performed on project samples. The MS/MSDs are used to assess the accuracy and precision of the analytical method for each analyte spiked and used to assess bias due to sample matrix effects;
- Data for laboratory duplicates, when performed on project samples. The laboratory duplicates are replicate analyses of one sample and are used to assess the precision of the analytical method;
- Percent recoveries for tracer and carriers, where applicable, for radiochemistry only. Tracers and/or carriers are used to assess the chemical yield for the preparation and/or instrument efficiency;
- Data for blind field duplicates. Field duplicate samples are used to assess variability introduced by the sampling and analytical processes; and
- Overall usability of the data.

This data usability report addresses the following items:

- Usability of the data if quality control (QC) results suggest potential problems with all or some of the data;
- Actions regarding specific QC criteria exceedances.

Review Summary

The data quality objectives and laboratory completeness goals for the project were met, and the data are usable for their intended purpose. A summary of the data quality review, including non-conformances and issues identified in this evaluation are noted below.

- The Appendix III and IV constituents will be utilized for the purposes of an assessment monitoring program.
- Data are usable for the purposes of the assessment monitoring program.
- When the data are evaluated through an assessment monitoring statistical program, findings below may be used to support the removal of outliers.

QA/QC Sample Summary:

- The holding times were met for all parameters for all samples with the following exceptions:
 - Samples JHC-MW-18004, JHC-MW-18005, DUP-1, EB-1, and FB-1 were analyzed for pH outside the 15-minute holding time requirement; these pH results may be estimated since they were analyzed 7 days after sample collection.
- Target analytes were not detected in the method blanks, equipment blank (EB-1) and field blank (FB-1).
- LCS recoveries for all target analytes were within laboratory control limits.
- The field duplicate pair samples were DUP-1 and JHC-MW-18005. The relative percent differences (RPDs) between the parent and duplicate sample were within the acceptance limits.
- MS/MSD analyses were performed on sample JHC-MW-18004 for radium, anions, metals, and mercury; the percent recoveries (%Rs) and RPDs were within the acceptance limits with the following exception:
 - The recoveries of calcium in the MS/MSD were above the acceptance criteria. However, the calcium concentration in the parent sample JHC-MW-18004 was >4x the spike concentration; therefore, the laboratory control limits are not applicable. Data usability was not affected.
- Laboratory duplicate analysis was performed on sample JHC-MW-18004 for pH, alkalinity, and TDS; the RPDs were within the acceptance limit.
- Carrier and tracer recoveries, where applicable, were within 30-110%.
- The RLs for nondetect results for chloride, boron, and TDS in field blank (FB-1) and in equipment blank (EB-1) exceeded the project-required RLs. This does not affect data usability since these are QC samples.

Laboratory Data Quality Review

Groundwater Monitoring Event April 2019

CEC JH Campbell Background

Groundwater samples were collected by TRC for the April 2019 sampling event. Samples were analyzed for anions, total dissolved solids, and total metals by Eurofins TestAmerica, located in Irvine, California (Eurofins TA - Irvine). The lithium analyses by method SW-846 6020 were subcontracted to Eurofins TA in North Canton, Ohio (Eurofins TA – Canton) and the radium analyses were subcontracted to Eurofins TA in St. Louis, Missouri (Eurofins TA – St. Louis). The laboratory analytical results were reported in laboratory sample delivery groups (SDGs) 440-239742-1 and 440-239737-1.

During the April 2019 sampling event, a groundwater sample was collected from each of the following wells:

- JHC-MW-15023
- JHC-MW-15024
- JHC-MW-15025
- JHC-MW-15026
- JHC-MW-15027
- JHC-MW-15028

Each sample was analyzed for the following constituents:

| Analyte Group | Method |
|---|--------------------------|
| Anions (Fluoride, Chloride, Sulfate) | SW-846 300.0 |
| Total Dissolved Solids | SM 2540C-11 |
| Total Metals | SW-846 6010B/6020A/7470A |
| Radium (Radium-226, Radium-228, Total Radium) | EPA 903.0, EPA 904.0 |

TRC reviewed the laboratory data to assess data usability. The following sections summarize the data review procedure and the results of the review.

Data Usability Review Procedure

The analytical data were reviewed using the USEPA National Functional Guidelines for Inorganic Superfund Methods Data Review (USEPA, 2017) and the Department of Energy Evaluation of Radiochemical Data Usability (USDOE, 1997). The following items were included in the evaluation of the data:

- Sample receipt, as noted in the cover page or case narrative;
- Technical holding times for analyses;
- Reporting limits (RLs) compared to project-required RLs;
- Data for method blanks, equipment blanks, and field blanks. Method blanks are used to assess potential contamination arising from laboratory sample preparation and/or

analytical procedures. Field and equipment blanks are used to assess potential contamination arising from field procedures;

- Data for laboratory control samples (LCSs) and/or LCS duplicates (LCSDs). The LCSs and/or LCSDs are used to assess the accuracy and/or precision of the analytical method for each analyte spiked using a clean matrix;
- Data for matrix spikes (MSs) and/or matrix spike duplicates (MSDs), when performed on project samples. The MS/MSDs are used to assess the accuracy and/or precision of the analytical method for each analyte spiked and used to assess bias due to sample matrix effects;
- Percent recoveries for carriers, where applicable, for radiochemistry only. Carriers are used to assess the chemical yield for the preparation and/or instrument efficiency;
- Data for laboratory duplicates, when available. The laboratory duplicates are replicate analyses of one sample and are used to assess the precision of the analytical method;
- Data for blind field duplicates. Field duplicate samples are used to assess variability introduced by the sampling and analytical processes; and
- Overall usability of the data.

This data usability report addresses the following items:

- Usability of the data if quality control (QC) results suggest potential problems with all or some of the data;
- Actions regarding specific QC criteria exceedances.

Review Summary

The data quality objectives and laboratory completeness goals for the project were met, and the data are usable for their intended purpose. A summary of the data quality review, including non-conformances and issues identified in this evaluation are noted below.

- Appendix III and Appendix IV constituents will be utilized for the purposes of an assessment monitoring program.
- Data are usable for the purposes of the assessment monitoring program.
- When the data are evaluated through an assessment monitoring statistical program, findings below may be used to support the removal of outliers.

QA/QC Sample Summary

- The holding time and preservation criteria were met with one exception; the TDS holding time for samples JHC-MW-15024 and JHC-MW-15025 exceeded the 7-day holding time criteria by one hour and two hours, respectively. These results may be estimated, biased low, as summarized in the attached table.

- No target analytes were detected in the method blanks.
- One field blank (FB-05) and one equipment blank (EB-05) were collected; no analytes were detected in these blank samples.
- LCS and/or LCSD recoveries and relative percent differences (RPDs), where applicable, were within laboratory control limits. The following issue was noted:
 - Note that the LCS/LCSD in analytical batch 437243 had an RER (replicate error ratio) result outside of the acceptance criteria of <1 (1.33) for Radium-226. However, duplicate precision was demonstrated by an acceptable RPD (27%), which was within the laboratory control limit of 40%. Thus, there was no impact on the data usability.
- MS/MSDs were not performed on samples in this data set.
- Laboratory duplicate analyses were not performed on samples in this data set.
- The field duplicate pair samples were DUP-05 and JHC-MW-15028; all criteria were met.
- Carrier recoveries for radium analyses were within laboratory control criteria.

Attachment A
Summary of Data Non-Conformances
JH Campbell Background – RCRA CCR Monitoring Program
West Olive, Michigan

| Samples | Collection Date | Analyte | Non-Conformance/Issue |
|----------------|------------------------|----------------|---|
| JHC-MW-15024 | 4/23/2019 | TDS | Analysis performed past holding time; sample results may be biased low. |
| JHC-MW-15025 | 4/23/2019 | | |

Laboratory Data Quality Review

Groundwater Monitoring Event April 2019

Consumers Energy JH Campbell Ponds 1 and 2

Groundwater samples were collected by TRC for the April 2019 sampling event. Samples were analyzed for anions, alkalinity, total dissolved solids, and/or total metals by Eurofins TestAmerica, located in Irvine, California (Eurofins TA - Irvine). The lithium analyses by method SW-846 6020 were subcontracted to Eurofins TA in North Canton, Ohio (Eurofins TA – Canton) and the radium analyses were subcontracted to Eurofins TA in St. Louis, Missouri (Eurofins TA – St. Louis). The laboratory analytical results were reported in laboratory sample delivery groups (SDGs) 440-239941-1, 440-239944-1, 440-240198-1, 440-239935-1, 440-239939-1, and 440-240186-1.

During the April 2019 sampling event, a groundwater sample was collected from each of the following wells:

- JHC-MW-15001
- JHC-MW-15002
- JHC-MW-15003
- JHC-MW-15005
- JHC-MW-18004
- JHC-MW-18005

Each sample was analyzed for the following constituents:

| Analyte Group | Method |
|---|--------------------------|
| Anions (Fluoride, Chloride, Sulfate) | SW-846 300.0 |
| Total Dissolved Solids | SM 2540C-11 |
| Alkalinity (Total, Bicarbonate, Carbonate) | SM 2320B-11 |
| Total Metals | SW-846 6010B/6020A/7470A |
| Radium (Ra-226, Ra-228, Combined Ra-226 & Ra-228) | EPA 903.0, EPA 904.0 |

TRC reviewed the laboratory data to assess data usability. The following sections summarize the data review procedure and the results of the review.

Data Usability Review Procedure

The analytical data were reviewed using the USEPA National Functional Guidelines for Inorganic Superfund Methods Data Review (USEPA, 2017) and the Department of Energy Evaluation of Radiochemical Data Usability (USDOE, 1997). The following items were included in the evaluation of the data:

- Sample receipt, as noted in the cover page or case narrative;
- Technical holding times for analyses;
- Reporting limits (RLs) compared to project-required RLs;

- Data for method blanks, equipment blanks, and field blanks, if applicable. Method blanks are used to assess potential contamination arising from laboratory sample preparation and/or analytical procedures. Field and equipment blanks are used to assess potential contamination arising from field procedures;
- Data for laboratory control samples (LCSs) and/or the LCS duplicate (LCSDs) samples. The LCSs and/or LCSDs are used to assess the accuracy and precision of the analytical method for each analyte spiked using a clean matrix;
- Data for matrix spike (MS) and matrix spike duplicates (MSD), when performed on project samples. The MS/MSDs are used to assess the accuracy and precision of the analytical method for each analyte spiked and used to assess bias due to sample matrix effects;
- Percent recoveries for carriers, where applicable, for radiochemistry only. Carriers are used to assess the chemical yield for the preparation and/or instrument efficiency;
- Data for laboratory duplicates, when performed on project samples. The laboratory duplicates are replicate analyses of one sample and are used to assess the precision of the analytical method;
- Data for blind field duplicates. Field duplicate samples are used to assess variability introduced by the sampling and analytical processes; and
- Overall usability of the data.

This data usability report addresses the following items:

- Usability of the data if quality control (QC) results suggest potential problems with all or some of the data;
- Actions regarding specific QC criteria exceedances.

Review Summary

The data quality objectives and laboratory completeness goals for the project were met, and the data are usable for their intended purpose. A summary of the data quality review, including non-conformances and issues identified in this evaluation are noted below.

- Appendix III and Appendix IV constituents will be utilized for the purposes of an assessment monitoring program.
- Data are usable for the purposes of the assessment monitoring program.
- When the data are evaluated through an assessment monitoring statistical program, findings below may be used to support the removal of outliers.

QA/QC Sample Summary

- Holding time criteria were met for all analytes with the exception of alkalinity. Samples JHC MW 15001, JHC-MW-15002, JHC-MW-15005, and JHC-MW-18005 were analyzed one day past the 14-day holding time criteria. These results may be estimated, biased low, as summarized in the attached table.
- Alkalinity could not be performed on samples JHC-MW-18004 and DUP-03 due to limited sample volume.
- No target analytes were detected in the method blanks.
- One field blank (FB-03) and one equipment blank (EB-03) were collected. FB-03 was not submitted for radium analyses. The following analytes were detected in each blank:
 - Calcium (4.9 mg/L), sodium (2.6 mg/L), potassium (2.5 mg/L), and magnesium (2.5 mg/L) were detected in FB-03; and sodium (0.72 mg/L) and magnesium (0.025 mg/L) were detected in EB-03. The sodium, potassium, and/or magnesium results in several samples, as summarized in the attached table, may be false positives since the results were less than 5x the maximum blank result. There was no impact on data usability for calcium since sample results were >5x the maximum blank concentration.
- LCS and/or LCSD percent recoveries (%Rs) and relative percent differences (RPDs) were within laboratory control limits.
- MS/MSDs were performed on sample DUP-03 for anions and JHC-MW-15003 for metals and anions. The RPDs were within the QC limits.
 - The recoveries of chloride in the MS/MSD performed on sample DUP-03 were outside of the acceptance criteria. However, the concentration of chloride in the parent sample was >4x the spike concentration; therefore, the laboratory control limits were not applicable. Data usability was not affected.
 - The recoveries of thallium in the MS and MSD performed on sample JHC-MW-15003 were outside of the acceptance criteria and the recovery for thallium in the post digestion spike (PDS) was acceptable. Potential low bias may exist for the positive and nondetect results for thallium in all groundwater samples in this data set, as summarized in the attached table.
- Laboratory duplicate analyses were performed for TDS on sample JHC-MW-18004, and for alkalinity and TDS on sample JHC-MW-15003; RPDs between the parent and duplicate samples were within the QC limits.
- The field duplicate samples were DUP-03 and JHC-MW-15005; all criteria were met.
- Carrier recoveries for radium analyses, where applicable, were within laboratory control criteria.

Attachment A
 Summary of Data Non-Conformances
 JH Campbell Ponds 1 & 2 – RCRA CCR Monitoring Program
 West Olive, Michigan

| Samples | Collection Date | Analyte | Non-Conformance/Issue |
|--------------|-----------------|--|--|
| JHC-MW-15001 | 4/25/2019 | Total Alkalinity, Bicarbonate Alkalinity, Carbonate Alkalinity | Holding time exceeded; results may be biased low. |
| JHC-MW-15002 | 4/25/2019 | | |
| JHC-MW-15005 | 4/25/2019 | | |
| JHC-MW-18005 | 4/25/2019 | | |
| JHC-MW-15001 | 4/25/2019 | Thallium | Low recoveries in MS/MSD. Result may be a biased low. |
| JHC-MW-15002 | 4/25/2019 | | |
| JHC-MW-15003 | 4/29/2019 | | |
| JHC-MW-15005 | 4/25/2019 | | |
| DUP-03 | 4/25/2019 | | |
| JHC-MW-18004 | 4/25/2019 | | |
| JHC-MW-18005 | 4/25/2019 | | |
| JHC-MW-15001 | 4/25/2019 | Sodium | Detection in field blank (FB-03). Sample result ≤5X the blank concentration. Result may be a false positive. |
| JHC-MW-15002 | 4/25/2019 | | |
| JHC-MW-15003 | 4/29/2019 | | |
| EB-03 | 4/29/2019 | Potassium | Detection in field blank (FB-03). Sample result ≤5X the blank concentration. Result may be a false positive. |
| JHC-MW-15001 | 4/25/2019 | | |
| JHC-MW-15002 | 4/25/2019 | | |
| JHC-MW-15003 | 4/29/2019 | | |
| JHC-MW-15005 | 4/25/2019 | | |
| DUP-03 | 4/25/2019 | | |
| JHC-MW-18004 | 4/25/2019 | | |
| JHC-MW-18005 | 4/25/2019 | | |
| JHC-MW-15001 | 4/25/2019 | Magnesium | Detection in field blank (FB-03). Sample result ≤5X the blank concentration. Result may be a false positive. |
| JHC-MW-15002 | 4/25/2019 | | |
| JHC-MW-15003 | 4/29/2019 | | |
| EB-03 | 4/29/2019 | | |
| JHC-MW-18005 | 4/25/2019 | | |

Notes:

MS/MSD: Matrix spike/matrix spike duplicate.

Laboratory Data Quality Review

Groundwater Monitoring Event August 2019

Consumers Energy JH Campbell Ponds 1 and 2

Groundwater samples were collected by TRC for the August 2019 sampling event. Samples were analyzed for lithium, anions, and total dissolved solids by Eurofins TA in North Canton, Ohio (Eurofins TA – Canton). The remaining metals analyses were subcontracted to Eurofins TA in Irvine, California (Eurofins TA - Irvine). The radium analyses were subcontracted to Eurofins TA in St. Louis, Missouri (Eurofins TA – St. Louis). The laboratory analytical results were reported in laboratory sample delivery groups (SDGs) 240-117413-1 and 240-117413-2.

During the August 2019 sampling event, a groundwater sample was collected from each of the following wells:

- JHC-MW-18004
- JHC-MW-18005

Each sample was analyzed for the following constituents:

| Analyte Group | Method |
|--|-------------------------|
| Anions (Fluoride, Chloride, Sulfate) | SW-846 300.0 |
| Total Dissolved Solids | SM 2540C-11 |
| Total Metals | SW-846 6010B/6020/7470A |
| Radium (Radium-226, Radium-228, Combined Radium) | EPA 903.0, EPA 904.0 |

TRC reviewed the laboratory data to assess data usability. The following sections summarize the data review procedure and the results of the review.

Data Usability Review Procedure

The analytical data were reviewed using the USEPA National Functional Guidelines for Inorganic Superfund Methods Data Review (USEPA, 2017) and the Department of Energy Evaluation of Radiochemical Data Usability (USDOE, 1997). The following items were included in the evaluation of the data:

- Sample receipt, as noted in the cover page or case narrative;
- Technical holding times for analyses;
- Reporting limits (RLs) compared to project-required RLs;
- Data for method blanks, equipment blanks, and field blanks. Method blanks are used to assess potential contamination arising from laboratory sample preparation and/or analytical procedures. Field and equipment blanks are used to assess potential contamination arising from field procedures;

- Data for laboratory control samples (LCSs) and laboratory control sample duplicates (LCSDs), where applicable. The LCS/LCSDs are used to assess the accuracy and precision, where applicable, of the analytical method using a clean matrix;
- Percent recoveries for matrix spike (MS) and matrix spike duplicates (MSD), where applicable. Percent recoveries are calculated for each analyte spiked and used to assess bias due to sample matrix effects;
- Percent recoveries for carriers, where applicable, for radiochemistry only. Carriers are used to assess the chemical yield for the preparation and/or instrument efficiency;
- Data for laboratory duplicates, where applicable. The laboratory duplicates are replicate analyses of one sample and are used to assess the precision of the analytical method;
- Data for blind field duplicates. Field duplicate samples are used to assess variability introduced by the sampling and analytical processes; and
- Overall usability of the data.

This data usability report addresses the following items:

- Usability of the data if quality control (QC) results suggest potential problems with all or some of the data;
- Actions regarding specific QC criteria exceedances.

Review Summary

The data quality objectives and laboratory completeness goals for the project were met, and the data are usable for their intended purpose. A summary of the data quality review, including non-conformances and issues identified in this evaluation are noted below.

- Appendix III and Appendix IV constituents will be utilized for the purposes of an assessment monitoring program.
- Data are usable for the purposes of the assessment monitoring program.
- When the data are evaluated through an assessment monitoring statistical program, findings below may be used to support the removal of outliers.

QA/QC Sample Summary

- Holding time criteria were met.
- Target analytes were not detected in the laboratory method blanks.
- One field blank (FB-1) and one equipment blank (EB-1) were collected. The following analytes were detected in FB-1: calcium at 94 mg/L, barium at 0.17 mg/L, and mercury at 0.00021 mg/L. The following analytes were detected in EB-1: calcium at 92 mg/L, barium at 0.16 mg/L, TDS at 420 mg/L, chloride at 46 mg/L, and sulfate at 56 mg/L. The presence of TDS in the equipment blank should not impact sample results and there was no impact on

data usability due to mercury blank contamination since mercury was not detected in the associated samples. Potential false positives exist for the results for calcium, barium, chloride, and sulfate in all groundwater samples as noted in the attached table.

- LCS/LCSD recoveries and relative percent differences (RPDs) were within laboratory control limits.
- MS/MSDs were performed on sample JHC-MW-18004 for metals and anions. The RPDs were within the QC limits.
 - The recoveries of calcium in the MS/MSD performed on sample JHC-MW-18004 were outside of the acceptance criteria. However, the calcium concentration in the parent sample JHC-MW-18004 was >4x the spike concentration; therefore, the laboratory control limits for calcium were not applicable. Data usability was not affected.
- Laboratory duplicate analyses were performed for TDS, radium-226, and radium-228 on sample JHC-MW-18004; the RPDs between the parent and duplicate sample was within the QC limits.
- The field duplicate pair samples were Dup-1 and JHC-MW-18005. All criteria were met.
- Carrier recoveries, where applicable, were within 40-110%.

Attachment A
 Summary of Data Non-Conformances
 JH Campbell Ponds 1 and 2 – RCRA CCR Monitoring Program
 West Olive, Michigan

| Samples | Collection Date | Analyte | Non-Conformance/Issue |
|--------------|-----------------|------------------------------------|--|
| JHC-MW-18004 | 8/13/2019 | Calcium, Barium, Chloride, Sulfate | Detection in field blank (FB-1) and/or equipment blank (EB-1). Sample result $\leq 10X$ the blank concentration. Result may be a false positive. |
| JHC-MW-18005 | 8/13/2019 | | |
| DUP-1 | 8/13/2019 | | |

Laboratory Data Quality Review

Groundwater Monitoring Event October 2019

Consumers Energy JH Campbell Background

Groundwater samples were collected by TRC for the October 2019 sampling event. Samples were analyzed for lithium, anions, and total dissolved solids by Eurofins TA in North Canton, Ohio (Eurofins TA – Canton). The remaining analyses were subcontracted to Eurofins TA in Irvine, California (Eurofins TA – Irvine). The radium analyses were subcontracted to Eurofins TA in St. Louis (Eurofins TA – St. Louis). The laboratory analytical results were reported in laboratory sample delivery groups (SDGs) 240-120197-1, 240-120197-2, and 240-120197-3.

During the October 2019 sampling event, a groundwater sample was collected from each of the following wells:

- JHC-MW-15023
- JHC-MW-15024
- JHC-MW-15025
- JHC-MW-15026
- JHC-MW-15027
- JHC-MW-15028

Each sample was analyzed for the following constituents:

| Analyte Group | Method |
|--|-------------------------|
| Anions (Fluoride, Chloride, Sulfate) | EPA 300.0 |
| Total Dissolved Solids | SM 2540C-11 |
| Total Metals | SW-846 6010B/6020/7470A |
| Radium (Radium-226, Radium-228, Combined Radium) | EPA 903.0, EPA 904.0 |

TRC reviewed the laboratory data to assess data usability. The following sections summarize the data review procedure and the results of the review.

Data Usability Review Procedure

The analytical data were reviewed using the USEPA National Functional Guidelines for Inorganic Superfund Methods Data Review (USEPA, 2017) and the Department of Energy Evaluation of Radiochemical Data Usability (USDOE, 1997). The following items were included in the evaluation of the data:

- Sample receipt, as noted in the cover page or case narrative;
- Technical holding times for analyses;
- Reporting limits (RLs) compared to project-required RLs;
- Data for method blanks, equipment blanks, and field blanks. Method blanks are used to assess potential contamination arising from laboratory sample preparation and/or

analytical procedures. Field and equipment blanks are used to assess potential contamination arising from field procedures;

- Data for laboratory control samples (LCSs). The LCSs are used to assess the accuracy of the analytical method using a clean matrix. The LCSs and/or LCSDs are used to assess the accuracy of the analytical method using a clean matrix;
- Percent recoveries for matrix spike (MS) and matrix spike duplicates (MSD), where applicable. Percent recoveries are calculated for each analyte spiked and used to assess bias due to sample matrix effects;
- Percent recoveries for tracer and carriers, where applicable, for radiochemistry only. Tracers and/or carriers are used to assess the chemical yield for the preparation and/or instrument efficiency;
- Data for laboratory duplicates, when available. The laboratory duplicates are replicate analyses of one sample and are used to assess the precision of the analytical method;
- Data for blind field duplicates. Field duplicate samples are used to assess variability introduced by the sampling and analytical processes; and
- Overall usability of the data.

This data usability report addresses the following items:

- Usability of the data if quality control (QC) results suggest potential problems with all or some of the data;
- Actions regarding specific QC criteria exceedances.

Review Summary

The data quality objectives and laboratory completeness goals for the project were met, and the data are usable for their intended purpose. A summary of the data quality review, including non-conformances and issues identified in this evaluation are noted below.

- Appendix III and IV constituents will be utilized for the purposes of an assessment monitoring program.
- Data are usable for the purposes of the assessment monitoring program.
- When the data are evaluated through an assessment monitoring statistical program, findings below may be used to support the removal of outliers.

QA/QC Sample Summary

- Holding time criteria were met with the following exceptions. The holding time for mercury was exceeded by 10 days in samples JHC-MW-15023, JHC-MW-15024, JHC-MW-15025, EB-1, and FB-1 and 11 days in samples JHC-MW-15026, JHC-MW-15027, and JHC-MW-15028. These results may be estimated, biased low, as summarized in the attached table, Attachment A.
- A method blank was analyzed with each analytical batch. Target analytes were not detected in the method blank samples with the following exception. Normalized absolute difference comparisons between blank and sample that are between 1.96 and 2.58 may indicate biased high results and normalized absolute differences <1.96 may indicate a false positive sample result.
 - Radium-228 was detected in method blank 160-446063/20-A at a concentration of 0.5137 ± 0.259 pCi/L. The detected radium-228 results for the samples associated with this method blank were potentially impacted, as summarized in the attached table, Attachment A.
- One equipment blank (EB-1) and one field blank (FB-1) were collected. Target analytes were not detected in these blank samples with the following exceptions:
 - Combined radium was detected in EB-1 at 0.383 ± 0.232 pCi/L. The detected combined results for the samples associated with this equipment blank were potentially impacted, as summarized in the attached table, Attachment A.
- The LCS and/or LCSD recoveries and relative percent differences (RPDs), where applicable, for all analytes were within QC limits.
- MS and MSD analyses were performed on were performed sample JHC-MW-15025 for metals and anions. All recoveries and RPDs were within the QC limits with the following exceptions.
 - The recoveries of calcium were outside of the acceptance criteria in the MS/MSD analyses. The calcium concentration in this sample was >4x the spike concentrations; therefore, the MS/MSD results for calcium were not evaluated. Data usability was not affected.
- Laboratory duplicate analysis was performed on sample JCW-MW-15025 for TDS; the RPD was within QC limits.
- The field duplicate pair samples were DUP-1 and JHC-MW-12028. The absolute difference for chromium (absolute difference >RL) exceeded the acceptance limits. Potential uncertainty exists for positive results for chromium in all groundwater samples in this data set as noted in the attached table, Attachment A.
- Samples did not undergo a 21-day wait period prior to radium analysis; however, combined radium results were all < 5 pCi/L so there is no impact on data usability.
- Carrier recoveries, where applicable, were within 40-110%.

Attachment A
 Summary of Data Non-Conformances
 JH Campbell Background – RCRA CCR Monitoring Program
 West Olive, Michigan

| Samples | Collection Date | Analyte | Non-Conformance/Issue |
|--------------|-----------------|-----------------|---|
| JHC-MW-15024 | 10/8/2019 | Radium-228 | Detection in method blank. Normalized absolute difference between blank and sample <1.96; indicates possible false positive result. |
| JHC-MW-15024 | 10/8/2019 | Combined Radium | Detection in equipment blank (EB-1). Normalized absolute difference between blank and samples <1.96; indicates possible false positive results. |
| JHC-MW-15025 | 10/8/2019 | | |
| JHC-MW-15027 | 10/7/2019 | | |
| JHC-MW-15023 | 10/8/2019 | Mercury | Holding time for mercury exceeded; indicates potential low bias in mercury results. |
| JHC-MW-15024 | 10/8/2019 | | |
| JHC-MW-15025 | 10/8/2019 | | |
| JHC-MW-15026 | 10/7/2019 | | |
| JHC-MW-15027 | 10/7/2019 | | |
| JHC-MW-15028 | 10/7/2019 | | |
| DUP-01 | 10/7/2019 | | |
| EB-1 | 10/8/2019 | | |
| FB-1 | 10/8/2019 | | |
| JHC-MW-15023 | 10/8/2019 | | |
| JHC-MW-15024 | 10/8/2019 | | |
| JHC-MW-15025 | 10/8/2019 | | |
| JHC-MW-15026 | 10/7/2019 | | |
| JHC-MW-15027 | 10/7/2019 | | |
| JHC-MW-15028 | 10/7/2019 | | |
| DUP-01 | 10/7/2019 | | |

Laboratory Data Quality Review

Groundwater Monitoring Event October 2019

Consumers Energy JH Campbell Ponds 1 and 2

Groundwater samples were collected by TRC for the October 2019 sampling event. Samples were analyzed for lithium, anions, and total dissolved solids by Eurofins TA in North Canton, Ohio (Eurofins TA – Canton). The remaining metals analyses were subcontracted to Eurofins TA in Irvine, California (Eurofins TA - Irvine). The radium analyses were subcontracted to Eurofins TA in St. Louis, Missouri (Eurofins TA – St. Louis). The laboratory analytical results were reported in laboratory sample delivery groups (SDGs) 240-120310-1 and 240-120310-2.

During the October 2019 sampling event, a groundwater sample was collected from each of the following wells:

- JHC-MW-15001
- JHC-MW-15002
- JHC-MW-15003
- JHC-MW-15005
- JHC-MW-18004
- JHC-MW-18005

Each sample was analyzed for the following constituents:

| Analyte Group | Method |
|--|--|
| Anions (Fluoride, Chloride, Sulfate) | EPA 300.0 |
| Total Dissolved Solids (TDS) | SM 2540C-11 |
| Total Metals | SW-846 6020, SW-846 6010B, SW-846 7470A |
| Radium (Radium-226, Radium-228, Combined Radium) | EPA 903.0, EPA 904.0 |

TRC reviewed the laboratory data to assess data usability. The following sections summarize the data review procedure and the results of the review.

Data Usability Review Procedure

The analytical data were reviewed using the USEPA National Functional Guidelines for Inorganic Superfund Methods Data Review (USEPA, 2017) and the Department of Energy Evaluation of Radiochemical Data Usability (USDOE, 1997). The following items were included in the evaluation of the data:

- Sample receipt;
- Technical holding times for analyses;
- Reporting limits (RLs) compared to project-required RLs;

- Data for method blanks, equipment blanks, and field blanks. Method blanks are used to assess potential contamination arising from laboratory sample preparation and/or analytical procedures. Field and equipment blanks are used to assess potential contamination arising from field procedures;
- Data for laboratory control samples (LCSs) and laboratory control sample duplicates (LCSDs), when performed. The LCSs and/or LCSDs are used to assess the accuracy of the analytical method using a clean matrix;
- Percent recoveries for matrix spike (MS) and matrix spike duplicates (MSD), when performed on project samples. Percent recoveries are calculated for each analyte spiked and used to assess bias due to sample matrix effects;
- Data for laboratory duplicates, when performed on project samples. The laboratory duplicates are replicate analyses of one sample and are used to assess the precision of the analytical method;
- Percent recoveries for carriers, where applicable, for radiochemistry only. Carriers are used to assess the chemical yield for the preparation and/or instrument efficiency;
- Data for blind field duplicates. Field duplicate samples are used to assess variability introduced by the sampling and analytical processes; and
- Overall usability of the data.

This data usability report addresses the following items:

- Usability of the data if quality control (QC) results suggest potential problems with all or some of the data;
- Actions regarding specific QC criteria exceedances.

Review Summary

The data quality objectives and laboratory completeness goals for the project were met, and the data are usable for their intended purpose. A summary of the data quality review, including non-conformances and issues identified in this evaluation, are noted below.

- Appendix III and IV constituents will be utilized for the purposes of an assessment monitoring program.
- Data are usable for the purposes of the assessment monitoring program.
- When the data are evaluated through an assessment monitoring statistical program, findings below may be used to support the removal of outliers.

QA/QC Sample Summary:

- A method blank was analyzed with each analytical batch. Target analytes were not detected in the method blank samples.

- One equipment blank (EB-3) and one field blank (FB-3) were collected. Target analytes were not detected in these blank samples with the following exception.
 - Boron was detected in FB-3 at 0.083 mg/L. Potential false positive exists for the positive result for boron in sample JHC-MW-15001, as summarized in the attached table, Attachment A.
- The LCS and/or LCSD recoveries and relative percent differences (RPDs), where applicable, for all analytes were within QC limits.
- MS and MSD analyses were performed on were performed on samples JHC-MW-18004 for metals and anions, and JHC-MW-15002 for anions. All recoveries and RPDs were within the QC limits with the following exceptions.
 - The recovery of calcium was outside of the acceptance criteria in the MSD analysis performed on sample JHC-MW-18004. The calcium concentration in this sample was >4x the spike concentration; therefore, the MS/MSD results for calcium were not evaluated. Data usability was not affected.
- The field duplicate pair samples were DUP-3 and JHC-MW-15003. All criteria were met.
- Laboratory duplicate analysis was performed on sample JHC-MW-18004 for TDS; the RPD was within QC limits.
- Samples did not undergo a 21-day wait period prior to radium-226 analysis; however, combined radium results were < 5 pCi/L so there is no impact on data usability.
- Carrier recoveries, where applicable, were within 40-110%.

Attachment A

Summary of Data Non-Conformances for Landfill Groundwater Analytical Data
JH Campbell Ponds 1 and 2 – RCRA CCR Monitoring Program
West Olive, Michigan

| Samples | Collection Date | Analyte | Non-Conformance/Issue |
|--------------|-----------------|---------|---|
| JHC-MW-15001 | 10/8/2019 | Boron | Detection in field blank (FB-3). Result <5x the blank result; indicates possible false positive result. |

Appendix E

June 2018 Statistical Evaluation of Initial Assessment Monitoring Sampling Event



1540 Eisenhower Place
Ann Arbor, MI 48108

734.971.7080 PHONE
734.971.9022 FAX

www.trcsolutions.com

January 14, 2019

Bethany Swanberg
Environmental Services
Consumers Energy Company
1945 W. Parnall Road
Jackson, MI 49201

Subject: Statistical Evaluation of Initial Assessment Monitoring Sampling Event,
JH Campbell Bottom Ash Pond Units 1-2 North and 1-2 South CCR Unit, Consumers Energy
Company, West Olive, Michigan

Dear Ms. Swanberg:

Consumers Energy Company (CEC) reported in the January 31, 2018 *Annual Groundwater Monitoring Report for the JH Campbell Power Plant Units 1-2 North and 1-2 South CCR Unit* for the JH Campbell (JHC) site in West Olive, Michigan, that boron, calcium, chloride, pH, sulfate and total dissolved solids were observed within groundwater at one or more downgradient monitoring well(s) with potential statistically significant increases (SSIs) above background concentration levels. TRC completed an Alternate Source Demonstration for the parameters listed above and did not find strong enough evidence within 90 days to determine the observation of constituents above background was attributable to an error or source other than the coal combustion residual (CCR) unit.

Therefore, CEC initiated an Assessment Monitoring Program for the Units 1-2 North and 1-2 South CCR Unit (Unit 1-2) pursuant to §257.95 of the CCR Rule¹ that included sampling and analyzing groundwater within the groundwater monitoring system for all constituents listed in Appendix IV. The results from the initial assessment monitoring sampling event were used to establish groundwater protection standards (GWPSs) for the Appendix IV constituents in accordance with §257.95(h), as presented in the October 15, 2018 *Assessment Monitoring Data Summary and Establishment of Groundwater Protection Standards*. The GWPS is established as the higher of the EPA Maximum Contaminant Level (MCL) or statistically derived background level for constituents with MCLs and the higher of the EPA Regional Screening Levels (RSLs) or background level for Appendix IV constituents with RSLs. The

¹ USEPA final rule for the regulation and management of Coal Combustion Residuals (CCR) under the Resource Conservation and Recovery Act (RCRA) published April 17, 2015, as amended per Phase One, Part One of the CCR Rule (83 FR 36435).

JHC Unit 1-2 monitoring system was subsequently sampled for the Appendix III and Appendix IV constituents within 90 days from the initial Appendix IV sampling event (June 2018). In accordance with §257.95, the assessment monitoring data must be compared to GWPSs to determine whether or not Appendix IV constituents are detected at statistically significant levels above the GWPSs.

This letter report presents a summary of the collected assessment monitoring data and the comparison of the assessment monitoring data to the GWPSs. The results of the assessment monitoring evaluation indicate that the following constituent is present at statistically significant levels exceeding the GWPS in downgradient monitoring wells at the JHC Unit 1-2 CCR unit:

| <u>Constituent</u> | <u>GWPS</u> | <u># Downgradient Wells Observed</u> |
|--------------------|-------------|--------------------------------------|
| Arsenic | 10 ug/L | 2 of 5 |

As such, per §257.95(g), the facility must either conduct an alternate source demonstration or initiate an assessment of corrective measures according to §257.96 within 90 days of detecting a statistical exceedance of the GWPSs.

Background

The JH Campbell Plant is a coal fired power generation facility located in West Olive, Michigan, on the eastern shore of Lake Michigan. It is bordered by the Pigeon River on the south, 156th Avenue on the east, and Croswell Street to the north with Lakeshore Drive bisecting the site from north to south. The power generating plant consists of three coal fired electric generating units located on the western side of the site and the CCR disposal area is on the east side of the site, east of Lakeshore Drive. Currently, there are no active CCR surface impoundments at the JHC solid waste disposal facility. Figure 1 is a site location map showing the facility and the surrounding area. Site features are shown on Figure 2.

CEC provided notification of initiation of closure on September 7, 2018 to the MDEQ to implement the certified closure plan by removal of CCR under the self-implementing requirements and schedule of the CCR Rule. Groundwater monitoring is also ongoing throughout the JHC site in accordance with the Michigan Department of Environmental Quality (MDEQ)-approved Hydrogeological Monitoring Plan (HMP)² for the Dry Ash Landfill, which includes additional monitoring downgradient from the JHC Unit 1-2 CCR unit.

² Consumers Energy Company. 1996. *Hydrogeological Monitoring Plan (HMP) for JH Campbell Ash Storage Facility, Consumers Power Company, Solid Waste Disposal Area, Coal Ash, Type III*. September.



Groundwater Monitoring System

In accordance with 40 CFR 257.91, CEC established a groundwater monitoring system for the JHC Unit 1-2, which consists of 11 monitoring wells (six background monitoring wells and five downgradient monitoring wells) that are screened in the uppermost aquifer. The monitoring well locations are shown on Figure 2. Six monitoring wells located north-northwest of the JHC Unit 1-2 provide data on background groundwater quality that has not been affected by the CCR unit (JHC-MW-15023 through JHC-MW-15028). Background groundwater quality data from these six background wells are additionally used for the CCR groundwater monitoring program at three other CCR units on the JHC site.

Groundwater within the uppermost aquifer generally flows to the south-southeast across the Site, with a southwesterly groundwater flow component on the western edge of the Site. Groundwater contour maps were constructed using the static water elevation data from the April 2018 and June 2018 assessment monitoring sampling events are provided as Figures 3 and 4, respectively. While the general overall groundwater flow direction observed across the JHC site during these assessment monitoring events is similar to that identified in previous monitoring rounds, groundwater flow changes have occurred in the immediate vicinity of JHC Unit 1-2 as a result of discontinued hydraulic loading and CCR removal at JHC Unit 1-2. Since hydraulic loading has been discontinued, the groundwater flow is predominantly toward the south instead of radially outward.

In addition, one of the downgradient monitoring wells (JHC-MW-15004) had been decommissioned on June 14, 2018, to accommodate the CCR removal activities. As such, groundwater monitoring at JHC-MW-15004 terminates at the April 2018 sampling event. Subsequent to the completion of the CCR removal activities, two additional monitoring wells were installed along the south and southwest edges of JHC Unit 1-2 during the week of December 3, 2018. The JHC Unit 1-2 monitoring system is currently being re-evaluated post-deconstruction, following equilibration of the water table and installation of the new wells to determine which monitoring wells are appropriately positioned to assess groundwater quality downgradient from the JHC Unit 1-2 CCR unit.

Data Quality

Data from each sampling round were evaluated for completeness, overall quality and usability, method-specified sample holding times, precision and accuracy, and potential sample contamination. The review was completed using the following quality control (QC) information which at a minimum included chain-of-custody forms, investigative sample results including blind field duplicates, and, as provided by the laboratory, method blanks, laboratory control spikes, laboratory duplicates. The data were found to be complete and usable for the purposes of the CCR monitoring program.



Assessment Monitoring Statistical Evaluation

Following the initial and resample assessment monitoring sampling event, compliance well data for the JHC Unit 1-2 were evaluated in accordance with the Groundwater Statistical Evaluation Plan (Stats Plan) (TRC, October 2017). Consistent with the Unified Guidance³, the preferred method for comparisons to a fixed standard are confidence limits. An exceedance of the standard occurs when the 99 percent lower confidence level of the downgradient data exceeds the GWPS.

For each detected Appendix IV constituent, the concentrations for each well were first compared directly to the GWPS, as shown on Table 1. Parameter-well combinations that included a direct exceedance of the GWPS were retained for further analysis. Arsenic in JHC-MW-15002 and JHC-MW-15003, arsenic and thallium at JHC-MW-15004, and lithium, selenium, and thallium at JHC-MW-15005 at Unit 1-2 had individual results exceeding the GWPS.

Groundwater data were then evaluated utilizing Sanitas™ statistical software. Sanitas™ is a software tool that is commercially available for performing statistical evaluation consistent with procedures outlined in the Unified Guidance. Within the Sanitas™ statistical program, confidence limits were selected to perform the statistical comparison of compliance data to a fixed standard. Parametric and non-parametric confidence intervals were calculated, as appropriate, for each of the CCR Appendix IV parameters using a 99 percent confidence level, i.e., a significance level (α) of 0.01. The following narrative describes the methods employed, the results obtained and the Sanitas™ output files are included as an attachment.

The statistical data evaluation included the following steps:

- Review of data quality checklists for the data sets for CCR Appendix IV constituents;
- Graphical representation of the monitoring data as time versus concentration by well-constituent pair;
- Outlier testing of individual data points that appear from the graphical representations as potential outliers;
- Evaluation of visual trends apparent in the graphical representations for statistical significance;
- Evaluation of percentage of non-detects for each well-constituent pair;
- Distribution of the data; and
- Calculation of the confidence intervals for each cumulative dataset.

The results of these evaluations are presented and discussed below.

³ USEPA. 2009. *Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities, Unified Guidance*. Office of Conservation and Recovery. EPA 530/R-09-007.

Initially, the baseline (December 2015 through August 2017) results and the two assessment monitoring results (April and June 2018) for these well-constituent pairs were observed visually for potential trends. No outliers were identified. The Sanitas™ software was then used to test compliance at the downgradient monitoring wells using the confidence interval method for the most recent 8 sampling events. Eight independent sampling events provide the appropriate density of data as recommended per the Unified Guidance yet are collected recently enough to provide an indication of current condition. The tests were run with a per-well significance of $\alpha = 0.01$. The software outputs are included in Attachment A along with data reports showing the values used for the evaluation. The percentage of non-detect observations are also included in Attachment A. Non-detect data was handled in accordance with the Stats Plan for the purposes of calculating the confidence intervals.

The Sanitas™ software generates an output that includes graphs of the parametric or non-parametric confidence intervals for each well along with notes on data transformations, as appropriate. The data sets were found to be normally distributed, except the set for JHC-MW-15002 for which a nonparametric confidence test was conducted. The confidence interval test compares the lower confidence limit to the GWPS. The calculated upper and lower confidence limits and comparison of the lower confidence limits to the GWPSs are also summarized in Table 2.

The statistical evaluation of the Appendix IV parameters shows exceedances for arsenic in JHC-MW-15002 and JHC-MW-15003. The lower confidence limits for arsenic and thallium at JHC-MW-15004, and lithium, selenium, and thallium at JHC-MW-15005, were below their respective GWPS. Per §257.95(g), the facility must either conduct an alternate source demonstration or initiate an assessment of corrective measures according to §257.96 within 90 days of detecting a statistical exceedance of the GWPSs.

Although no outliers were identified, the recent data collected during the April and June 2018 assessment monitoring events shows some variation compared to the background data set. The timing of the dissimilarities correlates with CCR removal activities and re-equilibration of groundwater in the vicinity of JHC Unit 1-2 following cessation of hydraulic loading. As mentioned above, the JHC Unit 1-2 monitoring system is currently being re-evaluated post-deconstruction to determine which monitoring wells are appropriately positioned to assess groundwater quality downgradient from the JHC Unit 1-2 CCR unit after hydrogeologic conditions re-stabilize.

Next Steps

In accordance with the CCR Rule, CEC will enter this statistical evaluation of the assessment monitoring data into the operating record by January 14, 2019. The notification of the GWPS exceedances to the state will be posted by CEC to a public CCR compliance website as required by §257.105(h)(8) by February 13, 2019. By April 14, 2019, in accordance with §257.95(g)(3), an



Ms. Swanberg
Consumers Energy Company
January 14, 2019
Page 6


assessment of corrective measures will be initiated. This assessment will be completed no later than September 11, 2019 in accordance with the timeframes provided in §257.96(a)(1).

Sincerely,

TRC



Graham Crockett
Program Manager



Sarah B. Holmstrom
Project Hydrogeologist

Attachments

- | | |
|--------------|---|
| Table 1. | Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to June 2018 |
| Table 2. | Summary of Groundwater Protection Standard Exceedances – June 2018 |
| Figure 1. | Site Location Map |
| Figure 2. | Site Plan |
| Figure 3. | Shallow Groundwater Contour Map – April 2018 |
| Figure 4. | Shallow Groundwater Contour Map – June 2018 |
| Attachment A | Sanitas™ Output |

cc: Brad Runkel, Consumers Energy
JR Register, Consumers Energy
Michelle Marion, Consumers Energy
Central Files

Tables

Table 1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to June 2018
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15001 | | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|-----------|--------------|----------|-----------|-----------|------------|-----------|-----------|-----------|-----------|--------------------|-----------|
| Sample Date: | | | | | | 12/7/2015 | 3/8/2016 | 6/21/2016 | 8/29/2016 | 11/15/2016 | 4/19/2017 | 6/20/2017 | 8/14/2017 | 9/25/2017 | 4/25/2018 | 6/18/2018 |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | NA | 51 | NA | 396 | 235 | 195 | 271 | 309 | 149 | 368 | 238 | 287 | -- | 339 |
| Calcium | mg/L | NC | NA | 46 | NA | 85.6 | 84.1 | 80.7 | 74 | 75.5 | 70.3 | 50.7 | 70.9 | 68.0 | -- | 68.6 |
| Chloride | mg/L | 250* | NA | 43 | NA | 12.3 | 48.4 | 152 | 98.5 | 105 | 7.1 | 51.8 | 94.8 | 73.6 | -- | 109 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 6.6 | 6.4 | 6.2 | 6.0 | 6.4 | 6.3 | 6.2 | 6.3 | 6.2 | 7.2 ⁽¹⁾ | 6.3 |
| Sulfate | mg/L | 250* | NA | 14 | NA | 142 | 46.2 | 34.9 | 46.4 | 68.3 | 42.1 | 88.0 | 114 | 129 | -- | 78.9 |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 630 | 190 | 570 | 550 | 560 | 440 | 340 | 562 | 563 | -- | 596 |
| Appendix IV | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 6 | 3 | 3 | 4 | 3 | 4 | 1.8 | 2.2 | -- | < 1.0 | 1.8 |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 160 | 148 | 164 | 148 | 141 | 172 | 106 | 142 | -- | 71.4 | 183 |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | NA | 2 | 100 | 1 | 2 | 2 | 2 | 3 | 2 | 1.0 | 1.0 | -- | < 1.0 | < 1.0 |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | -- | < 15.0 | < 15.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 40 | 10 | 40 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | -- | < 10 | < 10 |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | < 5 | < 5 | < 5 | < 5 | < 5 | < 5 | < 5.0 | < 5.0 | -- | < 5.0 | < 5.0 |
| Radium-226 | pCi/L | 5 | NA | NA | NA | < 0.234 | < 0.211 | 0.344 | < 0.389 | < 0.379 | < 0.352 | < 1.63 | < 0.708 | -- | < 0.545 | < 0.828 |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | 1.9 | 1.53 | 2.58 | 1.77 | 1.89 | 2.13 | < 2.26 | 1.61 | -- | < 1.34 | < 1.95 |
| Radium-228 | pCi/L | 5 | NA | NA | NA | 1.67 | 1.34 | 2.24 | 1.56 | 1.60 | 2.07 | < 0.628 | 1.20 | -- | < 0.799 | < 1.12 |
| Selenium | ug/L | 50 | NA | 5 | 50 | < 1 | 1 | 1 | < 1 | 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 |
| Thallium | ug/L | 2 | NA | 2 | 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2.0 | < 2.0 | -- | < 2.0 | < 2.0 |

Notes:

ug/L - micrograms per liter.

mg/L - milligrams per liter.

SU - standard units; pH is a field parameter.

pCi/L - picocuries per liter.

NA - not applicable.

NC - no criteria.

-- - not analyzed.

MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April, 2012.

RSL - Regional Screening Level from 83 FR 36435.

UTL - Upper Tolerance Limit (95%) of the background data set.

GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's

Technical Memorandum dated October 15, 2018.

* - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations

(SDWR) April, 2012.

Bold value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against

the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.

All metals were analyzed as total unless otherwise specified.

(1) pH value potentially biased high due to groundwater quality meter malfunction.

(2) JHC-MW-15004 was decommissioned on June 14th, 2018.

Table 1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to June 2018
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15002 | | | | | | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|-----------|--------------|-----------|-----------|-----------|------------|-----------|-------------|------------------|-------------|------------------|-----------|------------------|---------------------|-----------------|------------|
| Sample Date: | | | | | | 12/7/2015 | 3/8/2016 | 6/21/2016 | 8/30/2016 | 11/15/2016 | 4/19/2017 | 6/20/2017 | 6/20/2017 | 8/14/2017 | 8/14/2017 | 9/25/2017 | 9/25/2017 | 4/25/2018 | 4/25/2018 | 6/19/2018 |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | NA | 51 | NA | 661 | 426 | 433 | 831 | 757 | 602 | 768 | Field Dup 678 | 869 | Field Dup 946 | 927 | Field Dup 894 | -- | Field Dup -- | 430 |
| Calcium | mg/L | NC | NA | 46 | NA | 21.9 | 35.8 | 36.4 | 36.1 | 18.9 | 28 | 24.6 | 25.1 | 25.7 | 25.3 | 30.5 | 30.6 | -- | -- | 75.3 |
| Chloride | mg/L | 250* | NA | 43 | NA | 13.2 | 18.5 | 23.4 | 17.4 | 14.4 | 25.7 | 20.7 | 20.7 | 20.7 | 20.2 | 25.8 | 26.0 | -- | -- | 22.3 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 8.8 | 8.7 | 8.5 | 8.6 | 8.8 | 8.8 | 9.2 | -- | 9.2 | -- | 9.6 | -- | 10.2 ⁽¹⁾ | -- | 8.3 |
| Sulfate | mg/L | 250* | NA | 14 | NA | 33.3 | 47.8 | 46.9 | 54 | 51.4 | 64.2 | 52.8 | 53.3 | 54.5 | 53.7 | 33.9 | 34.3 | -- | -- | 153 |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 150 | 160 | 180 | 190 | 140 | 190 | 160 | 130 | 236 | 174 | 144 | 148 | -- | -- | 356 |
| Appendix IV | | | | | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | < 1 | < 1 | 4 | 3 | 1 | < 1 | 3.3 | 2.9 | 1.9 | 2.1 | -- | -- | < 1.0 | < 1.0 | < 1.0 |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 34 | 40 | 36 | 34 | 46 | 33 | 35.4 | 32.2 | 44.5 | 45.8 | -- | -- | 129 | 130 | 127 |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 10 | 9 | 8 | 8 | 8 | 8 | 7.2 | 6.3 | 7.8 | 7.7 | -- | -- | 30.4 | 30.4 | 19.8 |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | -- | -- | < 1.0 | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | -- | -- | < 0.20 | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | NA | 2 | 100 | < 1 | < 1 | < 1 | < 1 | 1 | 2 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | -- | -- | < 1.0 | < 1.0 | < 1.0 |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | < 15.0 | < 15.0 | -- | -- | < 15.0 | < 15.0 | < 15.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | -- | -- | < 1.0 | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 40 | 10 | 40 | 12.1 | 10.1 | < 10 | < 10 | 11 | < 10 | < 10 | < 10 | 11 | < 10 | -- | -- | 28 | 28 | 19 |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | -- | -- | < 0.20 | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | 10 | 93 | 18 | 18 | 16 | 48 | 21.4 | 19.2 | 19.0 | 19.0 | -- | -- | 12.6 | 12.7 | 7.5 |
| Radium-226 | pCi/L | 5 | NA | NA | NA | < 0.33 | < 0.244 | < 0.219 | < 0.487 | < 0.251 | < 0.409 | < 0.562 | < 0.154 | 0.749 | 0.949 | -- | -- | < 0.823 | < 0.530 | < 0.620 |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | 1.09 | < 0.737 | < 0.649 | 2.9 | < 0.496 | < 0.702 | < 1.33 | < 0.844 | < 1.43 | < 1.26 | -- | -- | < 1.55 | < 1.86 | < 2.20 |
| Radium-228 | pCi/L | 5 | NA | NA | NA | 0.986 | < 0.737 | < 0.649 | 2.83 | < 0.496 | < 0.702 | < 0.765 | < 0.690 | < 0.797 | < 0.790 | -- | -- | < 0.729 | < 1.33 | < 1.58 |
| Selenium | ug/L | 50 | NA | 5 | 50 | < 1 | 4 | < 1 | < 1 | 2 | 4 | 7.8 | 7.3 | 3.5 | 5.1 | -- | -- | < 1.0 | < 1.0 | < 1.0 |
| Thallium | ug/L | 2 | NA | 2 | 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | -- | -- | < 2.0 | < 2.0 | < 2.0 |

Notes:

ug/L - micrograms per liter.
 mg/L - milligrams per liter.
 SU - standard units; pH is a field parameter.
 pCi/L - picocuries per liter.
 NA - not applicable.
 NC - no criteria.
 -- - not analyzed.
 MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April, 2012.
 RSL - Regional Screening Level from 83 FR 36435.
 UTL - Upper Tolerance Limit (95%) of the background data set.
 GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
 * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April, 2012.
Bold value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
 All metals were analyzed as total unless otherwise specified.
 (1) pH value potentially biased high due to groundwater quality meter malfunction.
 (2) JHC-MW-15004 was decommissioned on June 14th, 2018.

Table 1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to June 2018
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15003 | | | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|-----------|--------------|-----------|-----------|-----------|------------|-----------|-------------|-------------|-----------|-------------|-------------|-------------|
| Sample Date: | | | | | | 12/5/2015 | 3/8/2016 | 6/21/2016 | 8/29/2016 | 11/15/2016 | 4/18/2017 | 6/20/2017 | 8/14/2017 | 9/25/2017 | 4/25/2018 | 6/18/2018 | 6/18/2018 |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | | | Field Dup |
| Boron | ug/L | NC | NA | 51 | NA | 439 | 455 | 426 | 882 | 1,670 | 1,280 | 1,240 | 1,150 | 1,120 | -- | 1,170 | 1,320 |
| Calcium | mg/L | NC | NA | 46 | NA | 27.9 | 46.7 | 38.3 | 44.3 | 31.8 | 34.6 | 28.8 | 36.0 | 30.1 | -- | 60.0 | 59.1 |
| Chloride | mg/L | 250* | NA | 43 | NA | 21.7 | 25.7 | 28.5 | 20.1 | 30.8 | 27.9 | 24.0 | 22.0 | 19.3 | -- | 37.5 | 36.6 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 9.0 | 9.3 | 9.2 | 9.1 | 8.6 | 8.7 | 9.3 | 9.3 | 9.7 | 9.3 | 8.9 | -- |
| Sulfate | mg/L | 250* | NA | 14 | NA | 41.3 | 52.7 | 48.1 | 45.8 | 63 | 71.8 | 61.8 | 61.9 | 51.9 | -- | 81.9 | 82.7 |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 160 | 200 | 190 | 220 | 230 | 260 | 146 | 208 | 136 | -- | 388 | 344 |
| Appendix IV | | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | < 1 | < 1 | < 1 | < 1 | 2 | 1 | < 1.0 | 1.3 | -- | 1.5 | 1.9 | 1.8 |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 38 | 31 | 27 | 27 | 36 | 26 | 20.4 | 23.7 | -- | 12.4 | 14.1 | 14.3 |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 21 | 16 | 15 | 19 | 18 | 16 | 18.0 | 18.0 | -- | 42.3 | 55.7 | 52.5 |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | NA | 2 | 100 | 2 | 5 | 2 | 1 | 5 | 12 | 12.3 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | -- | < 15.0 | < 15.0 | < 15.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 40 | 10 | 40 | 11.1 | < 10 | < 10 | < 10 | 11 | < 10 | < 10 | < 10 | -- | < 10 | < 10 | < 10 |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | 9 | 11 | 20 | 13 | 24 | 30 | 21.1 | 28.2 | -- | 19.3 | 53.0 | 51.2 |
| Radium-226 | pCi/L | 5 | NA | NA | NA | < 0.25 | < 0.236 | < 0.211 | < 0.365 | < 0.249 | < 0.302 | < 1.12 | 1.15 | -- | < 0.631 | < 0.623 | < 0.733 |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | < 0.412 | < 0.575 | < 0.539 | < 0.724 | < 0.369 | 0.769 | < 1.84 | 1.81 | -- | < 1.36 | < 1.63 | < 1.81 |
| Radium-228 | pCi/L | 5 | NA | NA | NA | < 0.412 | < 0.575 | < 0.539 | < 0.724 | < 0.369 | 0.633 | < 0.722 | < 0.938 | -- | < 0.732 | < 1.01 | < 1.08 |
| Selenium | ug/L | 50 | NA | 5 | 50 | < 1 | 3 | < 1 | < 1 | 2 | 3 | < 1.0 | 1.1 | -- | 2.2 | 4.4 | 4.5 |
| Thallium | ug/L | 2 | NA | 2 | 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2.0 | < 2.0 | -- | < 2.0 | < 2.0 | < 2.0 |

Notes:
 ug/L - micrograms per liter.
 mg/L - milligrams per liter.
 SU - standard units; pH is a field parameter.
 pCi/L - picocuries per liter.
 NA - not applicable.
 NC - no criteria.
 -- - not analyzed.
 MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April, 2012.
 RSL - Regional Screening Level from 83 FR 36435.
 UTL - Upper Tolerance Limit (95%) of the background data set.
 GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
 * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April, 2012.
Bold value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
 All metals were analyzed as total unless otherwise specified.
 (1) pH value potentially biased high due to groundwater quality meter malfunction.
 (2) JHC-MW-15004 was decommissioned on June 14th, 2018.

Table 1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to June 2018
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15004 ⁽²⁾ | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|-----------|-----------------------------|----------|-----------|-----------|------------|-----------|-----------|------------|-----------|-----------|
| Sample Date: | | | | | | 12/5/2015 | 3/8/2016 | 6/22/2016 | 8/30/2016 | 11/15/2016 | 4/18/2017 | 6/20/2017 | 8/14/2017 | 9/25/2017 | 4/25/2018 |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | NA | 51 | NA | 546 | 268 | 412 | 469 | 578 | 260 | 473 | 660 | 376 | -- |
| Calcium | mg/L | NC | NA | 46 | NA | 43.1 | 42.8 | 45.8 | 64.6 | 101 | 36.9 | 37.7 | 51.2 | 78.6 | -- |
| Chloride | mg/L | 250* | NA | 43 | NA | 41.6 | 35.5 | 26.4 | 23.7 | 70.8 | 46.8 | 67.5 | 95.1 | 41.5 | -- |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 7.6 | 7.3 | 7.1 | 6.8 | 7.3 | 7.6 | 7.4 | 7.6 | 7.1 | 7.3 |
| Sulfate | mg/L | 250* | NA | 14 | NA | 55 | 42.5 | 48.7 | 47.8 | 244 | 58.6 | 85.6 | 122 | 64.6 | -- |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 290 | 220 | 230 | 370 | 560 | 290 | 322 | 402 | 382 | -- |
| Appendix IV | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | < 1 | < 1 | 1 | 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 21 | 9 | 11 | 8 | 6 | 4 | 4.8 | 5.7 | -- | 3.6 |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 73 | 65 | 117 | 181 | 241 | 110 | 93.2 | 193 | -- | 162 |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 |
| Chromium | ug/L | 100 | NA | 2 | 100 | 1 | 1 | 1 | 1 | 1 | 3 | 6.9 | < 1.0 | -- | < 1.0 |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | -- | < 15.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 |
| Lithium | ug/L | NC | 40 | 10 | 40 | < 10 | < 10 | < 10 | 12 | 12 | < 10 | < 10 | 10 | -- | < 10 |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | 9 | 8 | 10 | 5 | 10 | 6 | 10.1 | 11.2 | -- | < 5.0 |
| Radium-226 | pCi/L | 5 | NA | NA | NA | < 0.295 | 0.259 | < 0.189 | < 0.29 | < 0.311 | < 0.333 | < 0.502 | 0.915 | -- | < 0.449 |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | 0.702 | 0.711 | 0.633 | 1.85 | 1.12 | 0.497 | < 1.19 | 1.66 | -- | < 1.24 |
| Radium-228 | pCi/L | 5 | NA | NA | NA | 0.422 | 0.452 | 0.605 | 1.62 | 0.856 | 0.366 | < 0.685 | < 0.920 | -- | < 0.787 |
| Selenium | ug/L | 50 | NA | 5 | 50 | 8 | 2 | 2 | 7 | 1 | 2 | < 1.0 | < 1.0 | -- | 5.5 |
| Thallium | ug/L | 2 | NA | 2 | 2 | 2.16 | < 2 | 2 | 4 | 3 | < 2 | < 2.0 | 2.1 | -- | < 2.0 |

Notes:

- ug/L - micrograms per liter.
- mg/L - milligrams per liter.
- SU - standard units; pH is a field parameter.
- pCi/L - picocuries per liter.
- NA - not applicable.
- NC - no criteria.
- - not analyzed.
- MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April, 2012.
- RSL - Regional Screening Level from 83 FR 36435.
- UTL - Upper Tolerance Limit (95%) of the background data set.
- GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
- * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April, 2012.
- Bold** value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
- All metals were analyzed as total unless otherwise specified.
- (1) pH value potentially biased high due to groundwater quality meter malfunction.
- (2) JHC-MW-15004 was decommissioned on June 14th, 2018.

Table 1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to June 2018
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15005 | | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|-----------|--------------|----------|-----------|-----------|------------|-----------|-----------|-----------|-----------|------------|------------|
| Sample Date: | | | | | | 12/5/2015 | 3/8/2016 | 6/22/2016 | 8/30/2016 | 11/15/2016 | 4/18/2017 | 6/20/2017 | 8/14/2017 | 9/25/2017 | 4/25/2018 | 6/19/2018 |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | NA | 51 | NA | 275 | 959 | 1,370 | 706 | 1,500 | 524 | 468 | 546 | 481 | -- | 227 |
| Calcium | mg/L | NC | NA | 46 | NA | 55 | 60.2 | 55.1 | 51.6 | 73.4 | 56.8 | 53.6 | 48.0 | 40.3 | -- | 61.8 |
| Chloride | mg/L | 250* | NA | 43 | NA | 27.7 | 42 | 46.9 | 19.2 | 29.3 | 64.2 | 50.4 | 27.1 | 21.8 | -- | 90.9 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 7.3 | 7.4 | 7.4 | 7.3 | 7.1 | 7.5 | 7.4 | 7.5 | 7.4 | 7.4 | 7.4 |
| Sulfate | mg/L | 250* | NA | 14 | NA | 51.2 | 53 | 57.9 | 46.5 | 61.8 | 58.3 | 66.0 | 64.9 | 61.9 | -- | 74.3 |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 270 | 300 | 310 | 230 | 320 | 360 | 306 | 282 | 300 | -- | 462 |
| Appendix IV | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | 4 | 2 | 2 | 3 | 5 | 3 | 3.8 | 4.2 | -- | 2.2 | 1.6 |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 4 | 3 | 3 | 5 | 3 | 2 | 3.3 | 2.5 | -- | 1.7 | 1.3 |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 99 | 74 | 97 | 72 | 159 | 128 | 113 | 109 | -- | 407 | 175 |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | NA | 2 | 100 | 4 | 5 | 12 | 2 | 3 | 4 | 3.7 | < 1.0 | -- | < 1.0 | 3.0 |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | -- | < 15.0 | < 15.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 40 | 10 | 40 | 41.3 | 25.5 | 28 | 31 | 49 | 38 | 39 | 36 | -- | 61 | 35 |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | 12 | 13 | 25 | 16 | 15 | 18 | 14 | 10 | -- | 31.2 | 15.7 |
| Radium-226 | pCi/L | 5 | NA | NA | NA | < 0.277 | < 0.355 | 0.192 | < 0.286 | < 0.246 | 0.461 | < 0.717 | < 0.877 | -- | 0.620 | < 0.758 |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | 0.564 | < 0.426 | < 0.395 | 1.78 | 0.974 | 0.841 | < 1.45 | < 1.73 | -- | 1.32 | 1.91 |
| Radium-228 | pCi/L | 5 | NA | NA | NA | 0.436 | < 0.426 | < 0.395 | 1.58 | 0.745 | < 0.383 | < 0.728 | < 0.856 | -- | 0.700 | 1.22 |
| Selenium | ug/L | 50 | NA | 5 | 50 | 28 | 12 | 33 | 18 | 165 | 10 | 15.5 | 15.7 | -- | 368 | 14.0 |
| Thallium | ug/L | 2 | NA | 2 | 2 | 3.04 | < 2 | 2 | 2 | 4 | < 2 | < 2.0 | < 2.0 | -- | 5.8 | 2.1 |

Notes:

ug/L - micrograms per liter.

mg/L - milligrams per liter.

SU - standard units; pH is a field parameter.

pCi/L - picocuries per liter.

NA - not applicable.

NC - no criteria.

-- - not analyzed.

MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April, 2012.

RSL - Regional Screening Level from 83 FR 36435.

UTL - Upper Tolerance Limit (95%) of the background data set.

GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's

Technical Memorandum dated October 15, 2018.

* - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations

(SDWR) April, 2012.

Bold value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against

the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.

All metals were analyzed as total unless otherwise specified.

(1) pH value potentially biased high due to groundwater quality meter malfunction.

(2) JHC-MW-15004 was decommissioned on June 14th, 2018.

Table 2
 Summary of Groundwater Protection Standard Exceedances – June 2018
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Constituent | Units | GWPS | JHC-MW-15002 | | JHC-MW-15003 | | JHC-MW-15004 | | JHC-MW-15005 | |
|-------------|-------|------|--------------|-----|--------------|-----|--------------|-----|--------------|-----|
| | | | LCL | UCL | LCL | UCL | LCL | UCL | LCL | UCL |
| Arsenic | ug/L | 10 | 33 | 130 | 15 | 31 | 3.8 | 9.3 | NA | NA |
| Lithium | ug/L | 40 | NA | NA | NA | NA | NA | NA | 28 | 51 |
| Selenium | ug/L | 50 | NA | NA | NA | NA | NA | NA | 10 | 370 |
| Thallium | ug/L | 2 | NA | NA | NA | NA | 1 | 4 | 2 | 4 |

Notes:

ug/L - micrograms per Liter.

NA - Not Applicable; well/parameter pair did not directly exceed the GWPS and was not included in further analysis.


GWPS - Groundwater Protection Standard as established in TRC's Technical Memorandum dated October 15, 2018.

UCL - Upper Confidence Limit ($\alpha = 0.01$) of the downgradient data set.

LCL - Lower Confidence Limit ($\alpha = 0.01$) of the downgradient data set.

Indicates a statistically significant exceedance of the GWPS. An exceedance occurs when the LCL is greater than the GWPS.

Figures



BASE MAP FROM USGS 7.5 MINUTE TOPOGRAPHIC QUADRANGLE SERIES.



1540 Eisenhower Place
Ann Arbor, MI 48108-3284
Phone: 734.971.7080

TRC - GIS

PROJECT: **CONSUMERS ENERGY COMPANY
JH CAMPBELL POWER PLANT
WEST OLIVE, MICHIGAN**

TITLE: **SITE LOCATION MAP**

| | |
|--------------|-----------------------|
| DRAWN BY: | J. PAPEZ |
| CHECKED BY: | S. HOLMSTROM |
| APPROVED BY: | G. CROCKFORD |
| DATE: | NOVEMBER 2018 |
| PROJ. NO.: | 269767-005 |
| FILE: | 269767-005-009SLM.mxd |

FIGURE 1




LEGEND


- BACKGROUND MONITORING WELL
- DOWNGRAIDENT BOTTOM ASH POND 1/2 N/S MONITORING WELL
- DOWNGRAIDENT BOTTOM ASH POND 3 N/S MONITORING WELL
- DOWNGRAIDENT LANDFILL MONITORING WELL
- DOWNGRAIDENT POND A MONITORING WELL
- MONITORING WELL (2018)
- MONITORING WELL (STATIC WATER LEVEL ONLY)
- DECOMMISSIONED MONITORING WELL

NOTES

1. BASE MAP IMAGERY FROM USDA – NATIONAL AGRICULTURE IMAGERY PROGRAM, 7/20/2016.
2. WELL LOCATIONS SURVEYED BY NEDERVELD ON 11/25/2015.
3. MONITORING WELL DECOMMISSIONED NOVEMBER 13, 2017.
4. MONITORING WELL DECOMMISSIONED JUNE 14, 2018.
5. MONITORING WELL DECOMMISSIONED OCTOBER 10, 2018.
6. JHC-MW-1800X MONITORING WELLS INSTALLED IN LATE 2018.



| | |
|--|-----------------------------|
| PROJECT: | |
| CONSUMERS ENERGY COMPANY JH CAMPBELL POWER PLANT WEST OLIVE, MICHIGAN | |
| TITLE: | |
| SITE PLAN WITH CCR MONITORING WELL LOCATIONS | |
| DRAWN BY: J. PAPEZ | PROJ NO.: 290806-001 |
| CHECKED BY: S. HOLMSTROM | |
| APPROVED BY: G. CROCKFORD | |
| DATE: JANUARY 2019 | FIGURE 2 |
| | |
| 1540 Eisenhower Place Ann Arbor, MI 48108-3284 Phone: 734.971.7080 www.trcsolutions.com | |
| FILE NO.: 290806-001-013.mxd | |




LEGEND


- BACKGROUND MONITORING WELL
- DECOMMISSIONED MONITORING WELL
- DOWNGRADIENT BOTTOM ASH POND 1/2 N/S MONITORING WELL
- DOWNGRADIENT BOTTOM ASH POND 3 N/S MONITORING WELL
- DOWNGRADIENT LANDFILL MONITORING WELL
- MONITORING WELL (STATIC WATER LEVEL ONLY)
- POND A MONITORING WELL
- GROUNDWATER ELEVATION CONTOUR (2' INTERVAL, DASHED WHERE INFERRED)
- (600.97) GROUNDWATER ELEVATION (FEET)

NOTES

1. BASE MAP IMAGERY FROM USDAL-NATIONAL AGRICULTURE IMAGERY PROGRAM, 7/20/2016.
2. WELL LOCATIONS SURVEYED BY NEDERVELD ON 11/25/2015.
3. MONITORING WELL DECOMMISSIONED NOVEMBER 13, 2017.
4. GROUNDWATER ELEVATIONS DISPLAYED IN FEET RELATIVE TO THE NORTH AMERICAN VERTICAL DATUM OF 1988.
5. ASH SLUICING OPERATIONS AT UNIT 3 WERE TEMPORARILY CEASED FROM MARCH 14 TO APRIL 26, 2018.



| | | | |
|--------------|---------------|--|------------|
| PROJECT: | | CONSUMERS ENERGY COMPANY JH CAMPBELL POWER PLANT WEST OLIVE, MICHIGAN | |
| TITLE: | | GROUNDWATER CONTOUR MAP APRIL 24, 2018 | |
| DRAWN BY: | S. MAJOR | PROJ NO.: | 290806-001 |
| CHECKED BY: | C. SCIESZKA | FIGURE 3 | |
| APPROVED BY: | S. HOLMSTROM | | |
| DATE: | NOVEMBER 2018 | FILE NO.: 290806-001-007.mxd | |





LEGEND

- BACKGROUND MONITORING WELL
- DECOMMISSIONED MONITORING WELL
- DOWNGRADEMENT BOTTOM ASH POND 1/2 N/S MONITORING WELL
- DOWNGRADEMENT BOTTOM ASH POND 3 N/S MONITORING WELL
- DOWNGRADEMENT LANDFILL MONITORING WELL
- MONITORING WELL (STATIC WATER LEVEL ONLY)
- POND A MONITORING WELL
- GROUNDWATER ELEVATION CONTOUR (2' INTERVAL, DASHED WHERE INFERRED)
- (600.97)** GROUNDWATER ELEVATION (FEET)
- (NU)** ANOMALOUS DATA NOT USED TO CONSTRUCT CONTOUR MAP

NOTES

1. BASE MAP IMAGERY FROM USDAL-NATIONAL AGRICULTURE IMAGERY PROGRAM, 7/20/2016.
2. WELL LOCATIONS SURVEYED BY NEDERVELD ON 11/25/2015.
3. GROUNDWATER ELEVATIONS DISPLAYED IN FEET RELATIVE TO THE NORTH AMERICAN VERTICAL DATUM OF 1988.
4. MONITORING WELL DECOMMISSIONED NOVEMBER 13, 2017.
5. MONITORING WELL DECOMMISSIONED JUNE 14, 2018.
6. GROUNDWATER ELEVATION DATA COLLECTED ON JUNE 11, 2018, MONITORING WELL DECOMMISSIONED ON JUNE 14, 2018.



1" = 600'
1:7,200

| | | | |
|--------------|--------------------|--|------------|
| PROJECT: | | CONSUMERS ENERGY COMPANY JH CAMPBELL POWER PLANT WEST OLIVE, MICHIGAN | |
| TITLE: | | GROUNDWATER CONTOUR MAP JUNE 18, 2018 | |
| DRAWN BY: | S. MAJOR | PROJ NO.: | 290806-001 |
| CHECKED BY: | C. SCIESZKA | FIGURE 4 | |
| APPROVED BY: | S. HOLMSTROM | | |
| DATE: | NOVEMBER 2018 | | |
| | | 1540 Eisenhower Place Ann Arbor, MI 48108-3284 Phone: 734.971.7080 www.trcsolutions.com | |
| FILE NO.: | 290806-001-010.mxd | | |

Attachment A
Sanitas™ Output

Summary Report

Constituent: Antimony, Total Analysis Run 11/26/2018 1:40 PM
Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

For observations made between 12/6/2015 and 6/19/2018, a summary of the selected data set:

Observations = 49
ND/Trace = 27
Wells = 5
Minimum Value = 1
Maximum Value = 5
Mean Value = 1.644
Median Value = 1
Standard Deviation = 1.071
Coefficient of Variation = 0.6514
Skewness = 1.599

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 10 | 10 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15002 | 10 | 5 | 1 | 4 | 1.81 | 1 | 1.147 | 0.6339 | 0.8647 |
| JHC-MW-15003 | 10 | 5 | 1 | 2 | 1.265 | 1 | 0.3888 | 0.3073 | 0.9939 |
| JHC-MW-15004 | 9 | 7 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15005 | 10 | 0 | 1.6 | 5 | 3.08 | 3 | 1.136 | 0.3689 | 0.2549 |

Summary Report

Constituent: Arsenic, Total Analysis Run 11/26/2018 1:40 PM
 Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

For observations made between 12/6/2015 and 6/19/2018, a summary of the selected data set:

Observations = 49
 ND/Trace = 1
 Wells = 5
 Minimum Value = 1
 Maximum Value = 129.5
 Mean Value = 19.3
 Median Value = 6
 Standard Deviation = 26.78
 Coefficient of Variation = 1.388
 Skewness = 2.799

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 10 | 1 | 1 | 6 | 2.98 | 3 | 1.434 | 0.4813 | 0.7201 |
| JHC-MW-15002 | 10 | 0 | 33 | 129.5 | 55.85 | 38 | 38.45 | 0.6885 | 1.447 |
| JHC-MW-15003 | 10 | 0 | 12.4 | 38 | 25.57 | 26.5 | 8.367 | 0.3272 | -0.1355 |
| JHC-MW-15004 | 9 | 0 | 3.6 | 21 | 8.122 | 6 | 5.406 | 0.6655 | 1.626 |
| JHC-MW-15005 | 10 | 0 | 1.3 | 5 | 2.88 | 3 | 1.094 | 0.3799 | 0.4191 |

Summary Report

Constituent: Barium, Total Analysis Run 11/26/2018 1:40 PM
Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

For observations made between 12/6/2015 and 6/19/2018, a summary of the selected data set:

Observations = 49
ND/Trace = 0
Wells = 5
Minimum Value = 6.75
Maximum Value = 407
Mean Value = 90.95
Median Value = 74
Standard Deviation = 80.4
Coefficient of Variation = 0.884
Skewness = 1.307

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 10 | 0 | 71.4 | 183 | 143.5 | 148 | 32.86 | 0.2289 | -1.091 |
| JHC-MW-15002 | 10 | 0 | 6.75 | 30.4 | 11.57 | 8 | 7.602 | 0.6571 | 1.829 |
| JHC-MW-15003 | 10 | 0 | 15 | 54.1 | 23.74 | 18 | 13.3 | 0.5601 | 1.599 |
| JHC-MW-15004 | 9 | 0 | 65 | 241 | 137.2 | 117 | 60.04 | 0.4375 | 0.3878 |
| JHC-MW-15005 | 10 | 0 | 72 | 407 | 143.3 | 111 | 98.38 | 0.6865 | 2.143 |

Summary Report

Constituent: Beryllium, Total Analysis Run 11/26/2018 1:40 PM
Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

For observations made between 12/6/2015 and 6/19/2018, a summary of the selected data set:

Observations = 49
ND/Trace = 49
Wells = 5
Minimum Value = 1
Maximum Value = 1
Mean Value = 1
Median Value = 1
Standard Deviation = 0
Coefficient of Variation = 0
Skewness = NaN

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 10 | 10 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15002 | 10 | 10 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15003 | 10 | 10 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15004 | 9 | 9 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15005 | 10 | 10 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |

Summary Report

Constituent: Cadmium, Total Analysis Run 11/26/2018 1:40 PM
Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

For observations made between 12/6/2015 and 6/19/2018, a summary of the selected data set:

Observations = 49
ND/Trace = 49
Wells = 5
Minimum Value = 0.2
Maximum Value = 0.2
Mean Value = 0.2
Median Value = 0.2
Standard Deviation = 0
Coefficient of Variation = 0
Skewness = NaN

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 10 | 10 | 0.2 | 0.2 | 0.2 | 0.2 | 0 | 0 | NaN |
| JHC-MW-15002 | 10 | 10 | 0.2 | 0.2 | 0.2 | 0.2 | 0 | 0 | NaN |
| JHC-MW-15003 | 10 | 10 | 0.2 | 0.2 | 0.2 | 0.2 | 0 | 0 | NaN |
| JHC-MW-15004 | 9 | 9 | 0.2 | 0.2 | 0.2 | 0.2 | 0 | 0 | NaN |
| JHC-MW-15005 | 10 | 10 | 0.2 | 0.2 | 0.2 | 0.2 | 0 | 0 | NaN |

Summary Report

Constituent: Chromium, Total Analysis Run 11/26/2018 1:40 PM
Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

For observations made between 12/6/2015 and 6/19/2018, a summary of the selected data set:

Observations = 49
ND/Trace = 17
Wells = 5
Minimum Value = 1
Maximum Value = 12.3
Mean Value = 2.549
Median Value = 1
Standard Deviation = 2.829
Coefficient of Variation = 1.11
Skewness = 2.462

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 10 | 2 | 1 | 3 | 1.6 | 1.5 | 0.6992 | 0.437 | 0.6578 |
| JHC-MW-15002 | 10 | 8 | 1 | 2 | 1.1 | 1 | 0.3162 | 0.2875 | 2.667 |
| JHC-MW-15003 | 10 | 3 | 1 | 12.3 | 4.23 | 2 | 4.452 | 1.052 | 1.113 |
| JHC-MW-15004 | 9 | 2 | 1 | 6.9 | 1.878 | 1 | 1.996 | 1.063 | 2.056 |
| JHC-MW-15005 | 10 | 2 | 1 | 12 | 3.87 | 3.35 | 3.143 | 0.8122 | 1.824 |

Summary Report

Constituent: Cobalt, Total Analysis Run 11/26/2018 1:40 PM
Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

For observations made between 12/6/2015 and 6/19/2018, a summary of the selected data set:

Observations = 49
ND/Trace = 49
Wells = 5
Minimum Value = 15
Maximum Value = 15
Mean Value = 15
Median Value = 15
Standard Deviation = 0
Coefficient of Variation = 0
Skewness = NaN

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 10 | 10 | 15 | 15 | 15 | 15 | 0 | 0 | NaN |
| JHC-MW-15002 | 10 | 10 | 15 | 15 | 15 | 15 | 0 | 0 | NaN |
| JHC-MW-15003 | 10 | 10 | 15 | 15 | 15 | 15 | 0 | 0 | NaN |
| JHC-MW-15004 | 9 | 9 | 15 | 15 | 15 | 15 | 0 | 0 | NaN |
| JHC-MW-15005 | 10 | 10 | 15 | 15 | 15 | 15 | 0 | 0 | NaN |

Summary Report

Constituent: Fluoride Analysis Run 11/26/2018 1:40 PM
Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

For observations made between 12/6/2015 and 6/19/2018, a summary of the selected data set:

Observations = 54
ND/Trace = 54
Wells = 5
Minimum Value = 1000
Maximum Value = 1000
Mean Value = 1000
Median Value = 1000
Standard Deviation = 0
Coefficient of Variation = 0
Skewness = NaN

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 11 | 11 | 1000 | 1000 | 1000 | 1000 | 0 | 0 | NaN |
| JHC-MW-15002 | 11 | 11 | 1000 | 1000 | 1000 | 1000 | 0 | 0 | NaN |
| JHC-MW-15003 | 11 | 11 | 1000 | 1000 | 1000 | 1000 | 0 | 0 | NaN |
| JHC-MW-15004 | 10 | 10 | 1000 | 1000 | 1000 | 1000 | 0 | 0 | NaN |
| JHC-MW-15005 | 11 | 11 | 1000 | 1000 | 1000 | 1000 | 0 | 0 | NaN |

Summary Report

Constituent: Lead, Total Analysis Run 11/26/2018 1:40 PM
Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

For observations made between 12/6/2015 and 6/19/2018, a summary of the selected data set:

Observations = 49
ND/Trace = 49
Wells = 5
Minimum Value = 1
Maximum Value = 1
Mean Value = 1
Median Value = 1
Standard Deviation = 0
Coefficient of Variation = 0
Skewness = NaN

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 10 | 10 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15002 | 10 | 10 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15003 | 10 | 10 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15004 | 9 | 9 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15005 | 10 | 10 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |

Summary Report

Constituent: Lithium, Total Analysis Run 11/26/2018 1:40 PM
Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

For observations made between 12/6/2015 and 6/19/2018, a summary of the selected data set:

Observations = 49
ND/Trace = 28
Wells = 5
Minimum Value = 10
Maximum Value = 61
Mean Value = 16.54
Median Value = 10
Standard Deviation = 12.38
Coefficient of Variation = 0.7483
Skewness = 1.88

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 10 | 10 | 10 | 10 | 10 | 10 | 0 | 0 | NaN |
| JHC-MW-15002 | 10 | 4 | 10 | 28 | 13.07 | 10.3 | 5.929 | 0.4537 | 1.892 |
| JHC-MW-15003 | 10 | 8 | 10 | 11.1 | 10.21 | 10 | 0.4433 | 0.04342 | 1.511 |
| JHC-MW-15004 | 9 | 6 | 10 | 12 | 10.44 | 10 | 0.8819 | 0.08444 | 1.336 |
| JHC-MW-15005 | 10 | 0 | 25.5 | 61 | 38.38 | 37 | 10.43 | 0.2717 | 0.9386 |

Summary Report

Constituent: Mercury, Total Analysis Run 11/26/2018 1:40 PM
Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

For observations made between 12/6/2015 and 6/19/2018, a summary of the selected data set:

Observations = 49
ND/Trace = 49
Wells = 5
Minimum Value = 0.2
Maximum Value = 0.2
Mean Value = 0.2
Median Value = 0.2
Standard Deviation = 0
Coefficient of Variation = 0
Skewness = NaN

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 10 | 10 | 0.2 | 0.2 | 0.2 | 0.2 | 0 | 0 | NaN |
| JHC-MW-15002 | 10 | 10 | 0.2 | 0.2 | 0.2 | 0.2 | 0 | 0 | NaN |
| JHC-MW-15003 | 10 | 10 | 0.2 | 0.2 | 0.2 | 0.2 | 0 | 0 | NaN |
| JHC-MW-15004 | 9 | 9 | 0.2 | 0.2 | 0.2 | 0.2 | 0 | 0 | NaN |
| JHC-MW-15005 | 10 | 10 | 0.2 | 0.2 | 0.2 | 0.2 | 0 | 0 | NaN |

Summary Report

Constituent: Molybdenum, Total Analysis Run 11/26/2018 1:40 PM
 Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

For observations made between 12/6/2015 and 6/19/2018, a summary of the selected data set:

Observations = 49
 ND/Trace = 11
 Wells = 5
 Minimum Value = 5
 Maximum Value = 93
 Mean Value = 16.01
 Median Value = 12
 Standard Deviation = 15.23
 Coefficient of Variation = 0.9514
 Skewness = 3.132

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 10 | 10 | 5 | 5 | 5 | 5 | 0 | 0 | NaN |
| JHC-MW-15002 | 10 | 0 | 7.5 | 93 | 26.25 | 18 | 25.95 | 0.9886 | 1.955 |
| JHC-MW-15003 | 10 | 0 | 9 | 52.1 | 22.77 | 20.55 | 12.43 | 0.5457 | 1.253 |
| JHC-MW-15004 | 9 | 1 | 5 | 11.2 | 8.256 | 9 | 2.373 | 0.2875 | -0.3736 |
| JHC-MW-15005 | 10 | 0 | 10 | 31.2 | 16.99 | 15.35 | 6.432 | 0.3786 | 1.24 |

Summary Report

Constituent: Radium-226/228 Analysis Run 11/26/2018 1:40 PM
 Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

For observations made between 12/6/2015 and 6/19/2018, a summary of the selected data set:

Observations = 49
 ND/Trace = 25
 Wells = 5
 Minimum Value = 0.369
 Maximum Value = 2.9
 Mean Value = 1.297
 Median Value = 1.33
 Standard Deviation = 0.6448
 Coefficient of Variation = 0.4971
 Skewness = 0.2816

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 10 | 3 | 1.34 | 2.58 | 1.896 | 1.895 | 0.365 | 0.1925 | 0.325 |
| JHC-MW-15002 | 10 | 8 | 0.496 | 2.9 | 1.339 | 1.21 | 0.7799 | 0.5823 | 0.7796 |
| JHC-MW-15003 | 10 | 8 | 0.369 | 1.84 | 1.021 | 0.7465 | 0.6155 | 0.603 | 0.4153 |
| JHC-MW-15004 | 9 | 2 | 0.497 | 1.85 | 1.067 | 1.12 | 0.4725 | 0.4428 | 0.4212 |
| JHC-MW-15005 | 10 | 4 | 0.395 | 1.91 | 1.139 | 1.147 | 0.5766 | 0.5063 | -0.01908 |

Summary Report

Constituent: Selenium, Total Analysis Run 11/26/2018 1:40 PM
 Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

For observations made between 12/6/2015 and 6/19/2018, a summary of the selected data set:

Observations = 49
 ND/Trace = 18
 Wells = 5
 Minimum Value = 1
 Maximum Value = 368
 Mean Value = 15.62
 Median Value = 2
 Standard Deviation = 56.67
 Coefficient of Variation = 3.628
 Skewness = 5.435

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 10 | 7 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15002 | 10 | 5 | 1 | 7.55 | 2.685 | 1.5 | 2.221 | 0.8272 | 1.065 |
| JHC-MW-15003 | 10 | 4 | 1 | 4.45 | 1.975 | 1.55 | 1.195 | 0.6049 | 0.8893 |
| JHC-MW-15004 | 9 | 2 | 1 | 8 | 3.278 | 2 | 2.774 | 0.8463 | 0.7835 |
| JHC-MW-15005 | 10 | 0 | 10 | 368 | 67.92 | 16.85 | 115.3 | 1.698 | 2.055 |

Summary Report

Constituent: Thallium, Total Analysis Run 11/26/2018 1:40 PM
Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas


For observations made between 12/6/2015 and 6/19/2018, a summary of the selected data set:

Observations = 49
ND/Trace = 38
Wells = 5
Minimum Value = 2
Maximum Value = 5.8
Mean Value = 2.208
Median Value = 2
Standard Deviation = 0.6838
Coefficient of Variation = 0.3097
Skewness = 3.854

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 10 | 10 | 2 | 2 | 2 | 2 | 0 | 0 | NaN |
| JHC-MW-15002 | 10 | 10 | 2 | 2 | 2 | 2 | 0 | 0 | NaN |
| JHC-MW-15003 | 10 | 10 | 2 | 2 | 2 | 2 | 0 | 0 | NaN |
| JHC-MW-15004 | 9 | 4 | 2 | 4 | 2.362 | 2 | 0.6942 | 0.2939 | 1.74 |
| JHC-MW-15005 | 10 | 4 | 2 | 5.8 | 2.694 | 2 | 1.279 | 0.4746 | 1.682 |

Parametric and Non-Parametric (NP) Confidence Interval

Compliance limit is exceeded.* Per-well alpha = 0.01 except as noted. Normality Test: Shapiro Wilk, alpha based on



Constituent: Arsenic, Total Analysis Run 11/29/2018 10:28 AM

Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

Confidence Interval


Constituent: Arsenic, Total (ug/L) Analysis Run 11/29/2018 10:29 AM

Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

| | JHC-MW-15002 | JHC-MW-15003 | JHC-MW-15004 |
|------------|--------------|--------------|--------------|
| 3/9/2016 | | | 9 |
| 6/22/2016 | 36 | 27 | 11 |
| 8/30/2016 | 34 | 27 | 8 |
| 11/15/2016 | 46 | 36 | |
| 11/16/2016 | | | 6 |
| 4/18/2017 | | 26 | 4 |
| 4/20/2017 | 33 | | |
| 6/20/2017 | 33.8 (D) | | 4.8 |
| 6/21/2017 | | 20.4 | |
| 8/14/2017 | 45.15 (D) | | |
| 8/15/2017 | | 23.7 | 5.7 |
| 4/25/2018 | 129.5 (D) | 12.4 | |
| 4/26/2018 | | | 3.6 |
| 6/18/2018 | | 14.2 (D) | |
| 6/19/2018 | 127 | | |
| Mean | 60.56 | 23.34 | 6.513 |
| Std. Dev. | 42.09 | 7.617 | 2.596 |
| Upper Lim. | 129.5 | 31.41 | 9.265 |
| Lower Lim. | 33 | 15.26 | 3.76 |

Parametric Confidence Interval

Compliance Limit is not exceeded. Per-well alpha = 0.01. Normality Test: Shapiro Wilk, alpha based on n.



Constituent: Lithium, Total Analysis Run 11/27/2018 4:22 PM

Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

Confidence Interval

Constituent: Lithium, Total (ug/L) Analysis Run 11/27/2018 4:23 PM


Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

JHC-MW-15005

| | |
|------------|-------|
| 6/22/2016 | 28 |
| 8/30/2016 | 31 |
| 11/16/2016 | 49 |
| 4/18/2017 | 38 |
| 6/21/2017 | 39 |
| 8/15/2017 | 36 |
| 4/26/2018 | 61 |
| 6/19/2018 | 35 |
| Mean | 39.63 |
| Std. Dev. | 10.64 |
| Upper Lim. | 50.9 |
| Lower Lim. | 28.35 |

Non-Parametric Confidence Interval

Compliance Limit is not exceeded.



Constituent: Selenium, Total Analysis Run 11/27/2018 4:31 PM

Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

Confidence Interval

Constituent: Selenium, Total (ug/L) Analysis Run 11/27/2018 4:31 PM


Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

JHC-MW-15005

| | |
|------------|-------|
| 6/22/2016 | 33 |
| 8/30/2016 | 18 |
| 11/16/2016 | 165 |
| 4/18/2017 | 10 |
| 6/21/2017 | 15.5 |
| 8/15/2017 | 15.7 |
| 4/26/2018 | 368 |
| 6/19/2018 | 14 |
| Mean | 79.9 |
| Std. Dev. | 127.5 |
| Upper Lim. | 368 |
| Lower Lim. | 10 |

Parametric and Non-Parametric (NP) Confidence Interval

Compliance Limit is not exceeded. Per-well alpha = 0.01 except as noted. Normality Test: Shapiro Wilk, alpha based on n.



Constituent: Thallium, Total Analysis Run 11/27/2018 4:18 PM

Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

Confidence Interval

Constituent: Thallium, Total (ug/L) Analysis Run 11/27/2018 4:18 PM

Client: Consumers Energy Data: JHC_Unit_1_2_Sanitas

| | JHC-MW-15004 | JHC-MW-15005 |
|------------|--------------|--------------|
| 3/9/2016 | <2 | |
| 6/22/2016 | 2 | 2 |
| 8/30/2016 | 4 | 2 |
| 11/16/2016 | 3 | 4 |
| 4/18/2017 | <2 | <2 |
| 6/20/2017 | <2 | |
| 6/21/2017 | | <2 |
| 8/15/2017 | 2.1 | <2 |
| 4/26/2018 | <2 | 5.8 |
| 6/19/2018 | | 2.1 |
| Mean | 1.888 | 2.363 |
| Std. Dev. | 1.128 | 1.707 |
| Upper Lim. | 4 | 3.908 |
| Lower Lim. | 1 | 1.585 |

Appendix F

April 2019 Assessment Monitoring Statistical Evaluation

Technical Memorandum

Date: June 12, 2019

To: Bethany Swanberg, Consumers Energy

cc: Brad Runkel, Consumers Energy
JR Register, Consumers Energy
Michelle Marion, Consumers Energy

From: Darby Litz, TRC
Sarah Holmstrom, TRC
Meredith Brehob, TRC

Project No.: 322174.0000.0000 Phase 1 Task 3

Subject: Statistical Evaluation of April 2019 Assessment Monitoring Sampling Event,
JH Campbell Bottom Ash Pond 1-2 North and 1-2 South CCR Unit, Consumers Energy
Company, West Olive, Michigan

During the statistical evaluation of the initial assessment monitoring event, arsenic was present in one or more downgradient monitoring wells at statistically significant levels exceeding the Groundwater Protection Standards (GWPSs). Therefore, Consumers Energy Company (Consumers Energy) initiated an Assessment of Corrective Measures (ACM) within 90 days from when the Appendix IV exceedance was determined. Currently, Consumers Energy is continuing semiannual assessment monitoring in accordance with §257.95 of the CCR Rule¹ at the JH Campbell Power Plant (JHC) Bottom Ash Pond 1-2 North and 1-2 South (Pond 1-2). The first semiannual assessment monitoring event of 2019 was conducted on April 22 through April 29, 2019. In accordance with §257.95, the assessment monitoring data must be compared to GWPSs to determine whether or not Appendix IV constituents are detected at statistically significant levels above the GWPSs. GWPSs were established in accordance with §257.95(h), as detailed in the October 15, 2018 *Groundwater Protection Standards* technical memorandum, which was also included in the 2018 *Annual Groundwater Monitoring Report* (TRC, January 2019). The following narrative describes the methods employed and the results obtained and the Sanitas™ output files are included as an attachment.

¹ USEPA final rule for the regulation and management of Coal Combustion Residuals (CCR) under the Resource Conservation and Recovery Act (RCRA) published April 17, 2015, as amended per Phase One, Part One of the CCR Rule (83 FR 36435).

Technical Memorandum

The statistical evaluation of the first semiannual assessment monitoring event for 2019 indicates that the following constituent is present at statistically significant levels exceeding the GWPS in downgradient monitoring wells at the Pond 1-2 CCR Unit:

| <u>Constituent</u> | <u>GWPS</u> | <u># Downgradient Wells Observed</u> |
|--------------------|-------------|--------------------------------------|
| Arsenic | 10 ug/L | 1 of 4 |

These results are consistent with the results of the initial, and previous, assessment monitoring data statistical evaluation and Consumers Energy will continue the assessment of corrective measures per §257.95(g). Consumers Energy will continue executing the self-implementing groundwater compliance schedule in conformance with §257.90 - §257.98.

Assessment Monitoring Statistical Evaluation

The compliance well network at the Pond 1-2 CCR Unit consists of four monitoring wells (JHC-MW-15001, JHC-MW-15002, JHC-MW-15003, and JHC-MW-15005) located on the perimeter of the bottom ash ponds. Former downgradient monitoring well JHC-MW-15004 was decommissioned on June 14, 2018 during deconstruction of Pond 1-2; therefore, statistical analysis for JHC-MW-15004 terminates at the June 2018 monitoring event.

Following the first semiannual assessment monitoring sampling event, compliance well data for the JHC Pond 1-2 were evaluated in accordance with the Groundwater Statistical Evaluation Plan (Stats Plan) (TRC, October 2017). An assessment monitoring program was developed to evaluate concentrations of CCR constituents present in the uppermost aquifer relative to acceptable levels (i.e. GWPSs). To evaluate whether or not a GWPS exceedance is statistically significant, the difference in concentration observed at the downgradient wells during a given assessment monitoring event compared to the GWPS must be large enough, after accounting for variability in the sample data, that the result is unlikely to have occurred merely by chance. Consistent with the Unified Guidance², the preferred method for comparisons to a fixed standard are confidence limits. An exceedance of the standard occurs when the 99 percent lower confidence level of the downgradient data exceeds the GWPS. Based on the number of historical observations in the representative sample population, the population mean, the population standard deviation, and a selected confidence level (i.e. 99 percent), an upper and lower confidence limit is calculated. The true concentration, with 99 percent confidence, will fall between the lower and upper confidence limits.

The concentrations observed in the downgradient wells are deemed to be a statistically significant exceedance when the 99 percent lower confidence limit of the downgradient data exceeds the GWPS. If the confidence interval straddles the GWPS (i.e. the lower confidence level is below the GWPS but the upper confidence level is above), the statistical test result indicates that there is insufficient confidence that the measured concentrations are different from the GWPS and thus there is no

² USEPA. 2009. *Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities, Unified Guidance*. Office of Conservation and Recovery. EPA 530/R-09-007.

Technical Memorandum

compelling evidence that the measured concentration is a result of a release from the CCR unit versus the inherent variability of the sample data. This statistical approach is consistent with the statistical methods for assessment monitoring presented in §257.93(f) and (g). Statistical evaluation methodologies built into the CCR Rule, and numerous other federal rules, are key in determining whether or not individually measured data points represent a concentration increase over the baseline or a fixed standard (such as a GWPS in an assessment monitoring program).

For each detected Appendix IV constituent, the concentrations for each well were first compared directly to the GWPS, as shown on Table A1. Parameter-well combinations that included a direct exceedance of the GWPS within the past eight monitoring events (November 2016 through April 2019) were retained for further analysis. Arsenic in JHC-MW-15001 and JHC-MW-15003, arsenic and lithium in JHC-MW-15002, and lithium, molybdenum, selenium, and thallium in JHC-MW-15005 at Pond 1-2 had individual results exceeding the GWPS. Cobalt was detected in JHC-MW-15003 at a concentration of 23.6 ug/L in November 2018, which exceeds its GWPS. However, this is the only detection of cobalt in the Pond 1-2 wells during either baseline sampling or assessment monitoring, and it qualifies as an outlier. The well was sampled during the April 2019 assessment monitoring sampling event which confirmed that cobalt is not present in groundwater at that monitoring well. Per the Stats Plan and the Unified Guidance, cobalt is subject to the double quantification rule, where a detection above laboratory reporting limits must be observed for two consecutive events (e.g. initial sample and a resample) to confirm the initial detection and rule out a potential false positive result.

Groundwater data for the remaining parameter-well combinations with direct-comparison exceedances of a GWPS were then evaluated utilizing Sanitas™ statistical software. Sanitas™ is a software tool that is commercially available for performing statistical evaluation consistent with procedures outlined in the Unified Guidance. Within the Sanitas™ statistical program, confidence limits were selected to perform the statistical comparison of compliance data to a fixed standard. Parametric and non-parametric confidence intervals were calculated, as appropriate, for each of the CCR Appendix IV parameters using a 99 percent confidence level, i.e., a significance level (α) of 0.01. The following narrative describes the methods employed, the results obtained and the Sanitas™ output files are included as an attachment.

The statistical data evaluation included the following steps:

- Review of data quality checklists for the data sets;
- Graphical representation of the monitoring data as time versus concentration by well-constituent pair;
- Outlier testing of individual data points that appear from the graphical representations as potential outliers;
- Evaluation of visual trends apparent in the graphical representations for statistical significance;
- Evaluation of percentage of non-detects for each well-constituent pair;
- Distribution of the data; and

Technical Memorandum

- Calculation of the confidence intervals for each cumulative dataset.

The results of these evaluations are presented and discussed below.

Initially, the baseline (December 2015 through August 2017) results and the assessment monitoring results (April 2018 through April 2019) for these well-constituent pairs were observed visually for potential trends. Potential increasing trends were noted for lithium in JHC-MW-15002 and molybdenum in JHC-MW-15005 beginning in November 2018. Groundwater conditions are re-equilibrating following to CCR removal activities at the JHC Pond 1-2 recently completed in September 2018, and the groundwater monitoring system is being re-assessed to account for post-deconstruction groundwater conditions. Because hydrogeologic conditions are in the process of stabilizing, in order to be conservative, the suspect lithium and molybdenum data from November 2018 and April 2019 have been kept in the assessment monitoring data set pending the collection of additional data. The suspect data will be tested for outliers once stabilized groundwater characteristics have been assessed. Data from each round were evaluated for completeness, overall quality, and usability and were deemed appropriate for the purposes of the CCR assessment monitoring program.

The Sanitas™ software was then used to test compliance at the downgradient monitoring wells using the confidence interval method for the most recent eight sampling events. Eight independent sampling events provide the appropriate density of data as recommended per the Unified Guidance yet are collected recently enough to provide an indication of current condition. The tests were run with a per-well significance of $\alpha = 0.01$. The software outputs are included in Attachment C1 along with data reports showing the values used for the evaluation. The percentage of non-detect observations are also included in Attachment C1. Non-detect data was handled in accordance with the Stats Plan for the purposes of calculating the confidence intervals.

The Sanitas™ software generates an output that includes graphs of the parametric or non-parametric confidence intervals for each well along with notes on data transformations, as appropriate. The data sets were found to be normally distributed, except the set for arsenic in JHC-MW-15002, which was first transformed as noted on the graph, and lithium in JHC-MW-15002 and molybdenum, selenium, and thallium in JHC-MW-15005 for which nonparametric confidence intervals were calculated. The confidence interval test compares the lower confidence limit to the GWPS. The statistical evaluation of the Appendix IV constituents shows exceedances for arsenic in JHC-MW-15002. These results are consistent with the results of the initial assessment monitoring data statistical evaluation and Consumers Energy will continue the assessment of corrective measures per §257.95(g). Consumers Energy will continue executing the self-implementing groundwater compliance schedule in conformance with §257.90 - §257.98.

Technical Memorandum

Attachments

| | |
|--------------|--|
| Table A1. | Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to April 2019 |
| Attachment 1 | Sanitas™ Output |

Technical Memorandum

Table

Table A1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to April 2019
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15001 | | | | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|------------|--------------|----------|-----------|-----------|------------|-----------|-----------|-----------|-----------|--------------------|-----------|-------------|-----------|
| Sample Date: | | | | | | 12/7/2015 | 3/8/2016 | 6/21/2016 | 8/29/2016 | 11/15/2016 | 4/19/2017 | 6/20/2017 | 8/14/2017 | 9/25/2017 | 4/25/2018 | 6/18/2018 | 11/13/2018 | 4/25/2019 |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | NA | 51 | NA | 396 | 235 | 195 | 271 | 309 | 149 | 368 | 238 | 287 | -- | 339 | 146 | 78 |
| Calcium | mg/L | NC | NA | 46 | NA | 85.6 | 84.1 | 80.7 | 74.0 | 75.5 | 70.3 | 50.7 | 70.9 | 68 | -- | 68.6 | 72.1 | 69 |
| Chloride | mg/L | 250* | NA | 43 | NA | 12.3 | 48.4 | 152 | 98.5 | 105 | 7.1 | 51.8 | 94.8 | 73.6 | -- | 109 | 2.7 | < 2.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250* | NA | 14 | NA | 142 | 46.2 | 34.9 | 46.4 | 68.3 | 42.1 | 88 | 114 | 129 | -- | 78.9 | 59.1 | 39 |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 630 | 190 | 570 | 550 | 560 | 440 | 340 | 562 | 563 | -- | 596 | 310 | 280 |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 6.6 | 6.4 | 6.2 | 6.0 | 6.4 | 6.3 | 6.2 | 6.3 | 6.2 | 7.2 ⁽¹⁾ | 6.3 | 6.3 | 6.0 |
| Appendix IV | | | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 6 | 3 | 3 | 4 | 3 | 4 | 1.8 | 2.2 | -- | < 1.0 | 1.8 | 12.7 | 5.8 |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 160 | 148 | 164 | 148 | 141 | 172 | 106 | 142 | -- | 71.4 | 183 | 84.9 | 58 |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | NA | 2 | 100 | 1 | 2 | 2 | 2 | 3 | 2 | 1.0 | 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | -- | < 15.0 | < 15.0 | < 6.0 | < 6.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 40 | 10 | 40 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | -- | < 10 | < 10 | < 10 | < 10 |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | < 5 | < 5 | < 5 | < 5 | < 5 | < 5 | < 5.0 | < 5.0 | -- | < 5.0 | < 5.0 | 13.3 | < 5.0 |
| Radium-226 | pCi/L | NC | NA | NA | NA | < 0.234 | < 0.211 | 0.344 | < 0.389 | < 0.379 | < 0.352 | < 1.63 | < 0.708 | -- | < 0.545 | < 0.828 | < 0.755 | < 0.101 |
| Radium-228 | pCi/L | NC | NA | NA | NA | 1.67 | 1.34 | 2.24 | 1.56 | 1.60 | 2.07 | < 0.628 | 1.20 | -- | < 0.799 | < 1.12 | < 0.879 | < 0.447 |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | 1.90 | 1.53 | 2.58 | 1.77 | 1.89 | 2.13 | < 2.26 | 1.61 | -- | < 1.34 | < 1.95 | < 1.63 | < 0.447 |
| Selenium | ug/L | 50 | NA | 5 | 50 | < 1 | 1 | 1 | < 1 | 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Thallium | ug/L | 2 | NA | 2 | 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2.0 | < 2.0 | -- | < 2.0 | < 2.0 | < 2.0 | < 2.0 |

Notes:

- ug/L - micrograms per liter.
- mg/L - milligrams per liter.
- SU - standard units; pH is a field parameter.
- pCi/L - picocuries per liter.
- NA - not applicable.
- NC - no criteria.
- - not analyzed.
- MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April, 2012.
- RSL - Regional Screening Level from 83 FR 36435.
- UTL - Upper Tolerance Limit (95%) of the background data set.
- GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
- * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April, 2012.
- Bold** value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
- All metals were analyzed as total unless otherwise specified.
- (1) pH value potentially biased high due to groundwater quality meter malfunction.
- (2) JHC-MW-15004 was decommissioned on June 14th, 2018.
- (3) Outlier; single detection above reporting limit.

Table A1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to April 2019
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15002 | | | | | | | | | | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|------------|--------------|-----------|-----------|-----------|------------|-----------|-------------|-------------|-------------|-------------|-----------|-----------|---------------------|------------|------------|-------------|-------------|-----------|--|
| Sample Date: | | | | | | 12/7/2015 | 3/8/2016 | 6/21/2016 | 8/30/2016 | 11/15/2016 | 4/19/2017 | 6/20/2017 | 6/20/2017 | 8/14/2017 | 8/14/2017 | 9/25/2017 | 9/25/2017 | 4/25/2018 | 4/25/2018 | 6/19/2018 | 11/15/2018 | 11/15/2018 | 4/25/2019 | |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | Field Dup | | Field Dup | | Field Dup | | Field Dup | | Field Dup | | Field Dup | |
| Boron | ug/L | NC | NA | 51 | NA | 661 | 426 | 433 | 831 | 757 | 602 | 768 | 678 | 869 | 946 | 927 | 894 | -- | -- | 430 | 1,470 | 1,360 | 3,200 | |
| Calcium | mg/L | NC | NA | 46 | NA | 21.9 | 35.8 | 36.4 | 36.1 | 18.9 | 28.0 | 24.6 | 25.1 | 25.7 | 25.3 | 30.5 | 30.6 | -- | -- | 75.3 | 41.9 | 41.1 | 85 | |
| Chloride | mg/L | 250* | NA | 43 | NA | 13.2 | 18.5 | 23.4 | 17.4 | 14.4 | 25.7 | 20.7 | 20.7 | 20.7 | 20.2 | 25.8 | 26.0 | -- | -- | 22.3 | 19.3 | 19.2 | 17 | |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | |
| Sulfate | mg/L | 250* | NA | 14 | NA | 33.3 | 47.8 | 46.9 | 54.0 | 51.4 | 64.2 | 52.8 | 53.3 | 54.5 | 53.7 | 33.9 | 34.3 | -- | -- | 153 | 95.2 | 94.5 | 190 | |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 150 | 160 | 180 | 190 | 140 | 190 | 160 | 130 | 236 | 174 | 144 | 148 | -- | -- | 356 | 222 | 274 | 410 | |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 8.8 | 8.7 | 8.5 | 8.6 | 8.8 | 8.8 | 9.2 | -- | 9.2 | -- | 9.6 | -- | 10.2 ⁽¹⁾ | -- | 8.3 | 8.0 | -- | 6.9 | |
| Appendix IV | | | | | | | | | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | < 1 | < 1 | 4 | 3 | 1 | < 1 | 3.3 | 2.9 | 1.9 | 2.1 | -- | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 34 | 40 | 36 | 34 | 46 | 33 | 35.4 | 32.2 | 44.5 | 45.8 | -- | -- | 129 | 130 | 127 | 60.5 | 59.5 | 50 | |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 10 | 9 | 8 | 8 | 8 | 8 | 7.2 | 6.3 | 7.8 | 7.7 | -- | -- | 30.4 | 30.4 | 19.8 | 18.4 | 18.1 | 49 | |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | -- | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | -- | -- | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | |
| Chromium | ug/L | 100 | NA | 2 | 100 | < 1 | < 1 | < 1 | < 1 | 1 | 2 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | -- | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | < 15.0 | < 15.0 | -- | -- | < 15.0 | < 15.0 | < 15.0 | < 6.0 | < 6.0 | < 6.0 | |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | -- | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | |
| Lithium | ug/L | NC | 40 | 10 | 40 | 12.1 | 10.1 | < 10 | < 10 | 11 | < 10 | < 10 | < 10 | 11 | < 10 | -- | -- | 28 | 28 | 19 | 68 | 67 | 96 | |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | -- | -- | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | 10 | 93 | 18 | 18 | 16 | 48 | 21.4 | 19.2 | 19.0 | 19.0 | -- | -- | 12.6 | 12.7 | 7.5 | 9.2 | 9.0 | < 5.0 | |
| Radium-226 | pCi/L | NC | NA | NA | NA | < 0.330 | < 0.244 | < 0.219 | < 0.487 | < 0.251 | < 0.409 | < 0.562 | < 0.154 | 0.749 | 0.949 | -- | -- | < 0.823 | < 0.530 | < 0.620 | < 1.09 | 0.921 | 0.233 | |
| Radium-228 | pCi/L | NC | NA | NA | NA | 0.986 | < 0.737 | < 0.649 | 2.83 | < 0.496 | < 0.702 | < 0.765 | < 0.690 | < 0.797 | < 0.790 | -- | -- | < 0.729 | < 1.33 | < 1.58 | 1.04 | 0.767 | 0.409 | |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | 1.09 | < 0.737 | < 0.649 | 2.9 | < 0.496 | < 0.702 | < 1.33 | < 0.844 | < 1.43 | < 1.26 | -- | -- | < 1.55 | < 1.86 | < 2.20 | < 1.70 | 1.69 | 0.642 | |
| Selenium | ug/L | 50 | NA | 5 | 50 | < 1 | 4 | < 1 | < 1 | 2 | 4 | 7.8 | 7.3 | 3.5 | 5.1 | -- | -- | < 1.0 | < 1.0 | < 1.0 | 2.5 | 2.8 | < 1.0 | |
| Thallium | ug/L | 2 | NA | 2 | 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | -- | -- | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | |

Notes:
 ug/L - micrograms per liter.
 mg/L - milligrams per liter.
 SU - standard units; pH is a field parameter.
 pCi/L - picocuries per liter.
 NA - not applicable.
 NC - no criteria.
 -- - not analyzed.
 MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April, 2012.
 RSL - Regional Screening Level from 83 FR 36435.
 UTL - Upper Tolerance Limit (95%) of the background data set.
 GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
 * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April, 2012.
Bold value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
 All metals were analyzed as total unless otherwise specified.
 (1) pH value potentially biased high due to groundwater quality meter malfunction.
 (2) JHC-MW-15004 was decommissioned on June 14th, 2018.
 (3) Outlier; single detection above reporting limit.

Table A1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to April 2019
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15003 | | | | | | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|------------|--------------|-----------|-----------|-----------|------------|-----------|-------------|-------------|-----------|-------------|-------------|-------------|---------------------|-----------|--|
| Sample Date: | | | | | | 12/5/2015 | 3/8/2016 | 6/21/2016 | 8/29/2016 | 11/15/2016 | 4/18/2017 | 6/20/2017 | 8/14/2017 | 9/25/2017 | 4/25/2018 | 6/18/2018 | 6/18/2018 | 11/15/2018 | 4/29/2019 | |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | NA | 51 | NA | 439 | 455 | 426 | 882 | 1,670 | 1,280 | 1,240 | 1,150 | 1,120 | -- | 1,170 | 1,320 | 1,120 | 1,700 | |
| Calcium | mg/L | NC | NA | 46 | NA | 27.9 | 46.7 | 38.3 | 44.3 | 31.8 | 34.6 | 28.8 | 36.0 | 30.1 | -- | 60.0 | 59.1 | 115 | 36 | |
| Chloride | mg/L | 250* | NA | 43 | NA | 21.7 | 25.7 | 28.5 | 20.1 | 30.8 | 27.9 | 24.0 | 22.0 | 19.3 | -- | 37.5 | 36.6 | 16.3 | 18 | |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | |
| Sulfate | mg/L | 250* | NA | 14 | NA | 41.3 | 52.7 | 48.1 | 45.8 | 63.0 | 71.8 | 61.8 | 61.9 | 51.9 | -- | 81.9 | 82.7 | 294 | 75 | |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 160 | 200 | 190 | 220 | 230 | 260 | 146 | 208 | 136 | -- | 388 | 344 | 644 | 200 | |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 9.0 | 9.3 | 9.2 | 9.1 | 8.6 | 8.7 | 9.3 | 9.3 | 9.7 | 9.3 | 8.9 | -- | 8.7 | 8.4 | |
| Appendix IV | | | | | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | < 1 | < 1 | < 1 | < 1 | 2 | 1 | < 1.0 | 1.3 | -- | 1.5 | 1.9 | 1.8 | 2.0 | 2.2 | |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 38 | 31 | 27 | 27 | 36 | 26 | 20.4 | 23.7 | -- | 12.4 | 14.1 | 14.3 | 8.1 | 10 | |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 21 | 16 | 15 | 19 | 18 | 16 | 18.0 | 18.0 | -- | 42.3 | 55.7 | 52.5 | 113 | 42 | |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 | 1.7 | 0.41 | |
| Chromium | ug/L | 100 | NA | 2 | 100 | 2 | 5 | 2 | 1 | 5 | 12 | 12.3 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | 13.6 | 4.2 | |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | -- | < 15.0 | < 15.0 | < 15.0 | 23.6 ⁽³⁾ | < 6.0 | |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | 3.3 | < 1.0 | |
| Lithium | ug/L | NC | 40 | 10 | 40 | 11.1 | < 10 | < 10 | < 10 | 11 | < 10 | < 10 | < 10 | -- | < 10 | < 10 | < 10 | < 10 | < 10 | |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | 9 | 11 | 20 | 13 | 24 | 30 | 21.1 | 28.2 | -- | 19.3 | 53.0 | 51.2 | 65.3 | 20 | |
| Radium-226 | pCi/L | NC | NA | NA | NA | < 0.250 | < 0.236 | < 0.211 | < 0.365 | < 0.249 | < 0.302 | < 1.12 | 1.15 | -- | < 0.631 | < 0.623 | < 0.733 | < 0.579 | < 0.113 | |
| Radium-228 | pCi/L | NC | NA | NA | NA | < 0.412 | < 0.575 | < 0.539 | < 0.724 | < 0.369 | 0.633 | < 0.722 | < 0.938 | -- | < 0.732 | < 1.01 | < 1.08 | < 0.657 | < 0.530 | |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | < 0.412 | < 0.575 | < 0.539 | < 0.724 | < 0.369 | 0.769 | < 1.84 | 1.81 | -- | < 1.36 | < 1.63 | < 1.81 | < 1.24 | < 0.530 | |
| Selenium | ug/L | 50 | NA | 5 | 50 | < 1 | 3 | < 1 | < 1 | 2 | 3 | < 1.0 | 1.1 | -- | 2.2 | 4.4 | 4.5 | 28.6 | 2.9 | |
| Thallium | ug/L | 2 | NA | 2 | 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2.0 | < 2.0 | -- | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | |

Notes:

- ug/L - micrograms per liter.
- mg/L - milligrams per liter.
- SU - standard units; pH is a field parameter.
- pCi/L - picocuries per liter.
- NA - not applicable.
- NC - no criteria.
- - not analyzed.
- MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April, 2012.
- RSL - Regional Screening Level from 83 FR 36435.
- UTL - Upper Tolerance Limit (95%) of the background data set.
- GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
- * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April, 2012.
- Bold** value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
- All metals were analyzed as total unless otherwise specified.
- (1) pH value potentially biased high due to groundwater quality meter malfunction.
- (2) JHC-MW-15004 was decommissioned on June 14th, 2018.
- (3) Outlier; single detection above reporting limit.

Table A1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to April 2019
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15004 ⁽²⁾ | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|------------|-----------------------------|----------|-----------|-----------|------------|-----------|-----------|------------|-----------|-----------|
| Sample Date: | | | | | | 12/5/2015 | 3/8/2016 | 6/22/2016 | 8/30/2016 | 11/15/2016 | 4/18/2017 | 6/20/2017 | 8/14/2017 | 9/25/2017 | 4/25/2018 |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | NA | 51 | NA | 546 | 268 | 412 | 469 | 578 | 260 | 473 | 660 | 376 | -- |
| Calcium | mg/L | NC | NA | 46 | NA | 43.1 | 42.8 | 45.8 | 64.6 | 101 | 36.9 | 37.7 | 51.2 | 78.6 | -- |
| Chloride | mg/L | 250* | NA | 43 | NA | 41.6 | 35.5 | 26.4 | 23.7 | 70.8 | 46.8 | 67.5 | 95.1 | 41.5 | -- |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250* | NA | 14 | NA | 55.0 | 42.5 | 48.7 | 47.8 | 244 | 58.6 | 85.6 | 122 | 64.6 | -- |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 290 | 220 | 230 | 370 | 560 | 290 | 322 | 402 | 382 | -- |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 7.6 | 7.3 | 7.1 | 6.8 | 7.3 | 7.6 | 7.4 | 7.6 | 7.1 | 7.3 |
| Appendix IV | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | < 1 | < 1 | 1 | 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 21 | 9 | 11 | 8 | 6 | 4 | 4.8 | 5.7 | -- | 3.6 |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 73 | 65 | 117 | 181 | 241 | 110 | 93.2 | 193 | -- | 162 |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 |
| Chromium | ug/L | 100 | NA | 2 | 100 | 1 | 1 | 1 | 1 | 1 | 3 | 6.9 | < 1.0 | -- | < 1.0 |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | -- | < 15.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 |
| Lithium | ug/L | NC | 40 | 10 | 40 | < 10 | < 10 | < 10 | 12 | 12 | < 10 | < 10 | 10 | -- | < 10 |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | 9 | 8 | 10 | 5 | 10 | 6 | 10.1 | 11.2 | -- | < 5.0 |
| Radium-226 | pCi/L | NC | NA | NA | NA | < 0.295 | 0.259 | < 0.189 | < 0.29 | < 0.311 | < 0.333 | < 0.502 | 0.915 | -- | < 0.449 |
| Radium-228 | pCi/L | NC | NA | NA | NA | 0.422 | 0.452 | 0.605 | 1.62 | 0.856 | 0.366 | < 0.685 | < 0.920 | -- | < 0.787 |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | 0.702 | 0.711 | 0.633 | 1.85 | 1.12 | 0.497 | < 1.19 | 1.66 | -- | < 1.24 |
| Selenium | ug/L | 50 | NA | 5 | 50 | 8 | 2 | 2 | 7 | 1 | 2 | < 1.0 | < 1.0 | -- | 5.5 |
| Thallium | ug/L | 2 | NA | 2 | 2 | 2.16 | < 2 | 2 | 4 | 3 | < 2 | < 2.0 | 2.1 | -- | < 2.0 |

Notes:

- ug/L - micrograms per liter.
- mg/L - milligrams per liter.
- SU - standard units; pH is a field parameter.
- pCi/L - picocuries per liter.
- NA - not applicable.
- NC - no criteria.
- - not analyzed.
- MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April, 2012.
- RSL - Regional Screening Level from 83 FR 36435.
- UTL - Upper Tolerance Limit (95%) of the background data set.
- GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
- * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April, 2012.
- Bold** value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
- All metals were analyzed as total unless otherwise specified.
- (1) pH value potentially biased high due to groundwater quality meter malfunction.
- (2) JHC-MW-15004 was decommissioned on June 14th, 2018.
- (3) Outlier; single detection above reporting limit.

Table A1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to April 2019
 JH Campbell Unit 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15005 | | | | | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|-------|--------------|----------|-----------|-----------|------------|-----------|-----------|-----------|-----------|-----------|-----------|------------|-----------|-----------|
| Sample Date: | | | | | | 12/5/2015 | 3/8/2016 | 6/22/2016 | 8/30/2016 | 11/15/2016 | 4/18/2017 | 6/20/2017 | 8/14/2017 | 9/25/2017 | 4/25/2018 | 6/19/2018 | 11/15/2018 | 4/25/2019 | 4/25/2019 |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | NA | 51 | NA | 275 | 959 | 1,370 | 706 | 1,500 | 524 | 468 | 546 | 481 | -- | 227 | 1,450 | 2,800 | 2,900 |
| Calcium | mg/L | NC | NA | 46 | NA | 55.0 | 60.2 | 55.1 | 51.6 | 73.4 | 56.8 | 53.6 | 48.0 | 40.3 | -- | 61.8 | 61.9 | 170 | 180 |
| Chloride | mg/L | 250* | NA | 43 | NA | 27.7 | 42.0 | 46.9 | 19.2 | 29.3 | 64.2 | 50.4 | 27.1 | 21.8 | -- | 90.9 | 30.6 | 28 | 28 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250* | NA | 14 | NA | 51.2 | 53.0 | 57.9 | 46.5 | 61.8 | 58.3 | 66.0 | 64.9 | 61.9 | -- | 74.3 | 133 | 240 | 320 |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 270 | 300 | 310 | 230 | 320 | 360 | 306 | 282 | 300 | -- | 462 | 334 | 800 | 780 |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 7.3 | 7.4 | 7.4 | 7.3 | 7.1 | 7.5 | 7.4 | 7.5 | 7.4 | 7.4 | 7.4 | 7.5 | 7.2 | -- |
| Appendix IV | | | | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | 4 | 2 | 2 | 3 | 5 | 3 | 3.8 | 4.2 | -- | 2.2 | 1.6 | 5.1 | 4.4 | 4.2 |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 4 | 3 | 3 | 5 | 3 | 2 | 3.3 | 2.5 | -- | 1.7 | 1.3 | 1.2 | 1.2 | 1.1 |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 99 | 74 | 97 | 72 | 159 | 128 | 113 | 109 | -- | 407 | 175 | 149 | 150 | 150 |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | NA | 2 | 100 | 4 | 5 | 12 | 2 | 3 | 4 | 3.7 | < 1.0 | -- | < 1.0 | 3.0 | < 1.0 | 1.3 | 1.3 |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | -- | < 15.0 | < 15.0 | < 6.0 | < 6.0 | < 6.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 40 | 10 | 40 | 41.3 | 25.5 | 28 | 31 | 49 | 38 | 39 | 36 | -- | 61 | 35 | 28 | 38 | 38 |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | 12 | 13 | 25 | 16 | 15 | 18 | 14.0 | 10 | -- | 31.2 | 15.7 | 222 | 900 | 870 |
| Radium-226 | pCi/L | NC | NA | NA | NA | < 0.277 | < 0.355 | 0.192 | < 0.286 | < 0.246 | 0.461 | < 0.717 | < 0.877 | -- | 0.620 | < 0.758 | < 0.461 | 0.169 | 0.248 |
| Radium-228 | pCi/L | NC | NA | NA | NA | 0.436 | < 0.426 | < 0.395 | 1.58 | 0.745 | < 0.383 | < 0.728 | < 0.856 | -- | 0.700 | 1.220 | 0.967 | < 0.350 | 0.495 |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | 0.564 | < 0.426 | < 0.395 | 1.78 | 0.974 | 0.841 | < 1.45 | < 1.73 | -- | 1.32 | 1.91 | 1.41 | < 0.350 | 0.743 |
| Selenium | ug/L | 50 | NA | 5 | 50 | 28 | 12 | 33 | 18 | 165 | 10 | 15.5 | 15.7 | -- | 368 | 14 | 158 | 140 | 130 |
| Thallium | ug/L | 2 | NA | 2 | 2 | 3.04 | < 2 | 2 | 2 | 4 | < 2 | < 2.0 | < 2.0 | -- | 5.8 | 2.1 | < 2.0 | 2.0 | < 2.0 |

Notes:


- ug/L - micrograms per liter.
- mg/L - milligrams per liter.
- SU - standard units; pH is a field parameter.
- pCi/L - picocuries per liter.
- NA - not applicable.
- NC - no criteria.
- - not analyzed.
- MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April, 2012.
- RSL - Regional Screening Level from 83 FR 36435.
- UTL - Upper Tolerance Limit (95%) of the background data set.
- GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
- * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April, 2012.
- Bold** value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
- All metals were analyzed as total unless otherwise specified.
- (1) pH value potentially biased high due to groundwater quality meter malfunction.
- (2) JHC-MW-15004 was decommissioned on June 14th, 2018.
- (3) Outlier; single detection above reporting limit.

Attachment 1

Sanitas™ Output

Parametric and Non-Parametric (NP) Confidence Interval

Compliance limit is exceeded.* Per-well alpha = 0.01 except as noted. Normality Test: Shapiro Wilk, alpha based on n.



Constituent: Arsenic, Total Analysis Run 6/10/2019 4:04 PM

Client: Consumers Energy Data: JHC_Sanitas_19.06.03

Confidence Interval


Constituent: Arsenic, Total (ug/L) Analysis Run 6/10/2019 4:05 PM

Client: Consumers Energy Data: JHC_Sanitas_19.06.03

| | JHC-MW-15001 | JHC-MW-15002 | JHC-MW-15003 |
|------------|--------------|--------------|--------------|
| 11/15/2016 | 3 | 46 | 36 |
| 4/18/2017 | | | 26 |
| 4/19/2017 | 4 | 33 | |
| 6/20/2017 | 1.8 | 33.8 (D) | 20.4 |
| 8/14/2017 | 2.2 | 45.15 (D) | 23.7 |
| 4/25/2018 | <1 | 129.5 (D) | 12.4 |
| 6/18/2018 | 1.8 | | 14.2 (D) |
| 6/19/2018 | | 127 | |
| 11/13/2018 | 12.7 | | |
| 11/15/2018 | | 60 (D) | 8.1 |
| 4/25/2019 | 5.8 | 50 | |
| 4/29/2019 | | | 10 |
| Mean | 3.975 | 65.56 | 18.85 |
| Std. Dev. | 3.875 | 39.65 | 9.474 |
| Upper Lim. | 7.502 | 129.5 | 28.89 |
| Lower Lim. | 0.8199 | 33 | 8.808 |

Parametric and Non-Parametric (NP) Confidence Interval

Compliance Limit is not exceeded. Per-well alpha = 0.01 except as noted. Normality Test: Shapiro Wilk, alpha based on n.



Constituent: Lithium, Total Analysis Run 6/10/2019 4:05 PM

Client: Consumers Energy Data: JHC_Sanitas_19.06.03

Confidence Interval


Constituent: Lithium, Total (ug/L) Analysis Run 6/10/2019 4:05 PM

Client: Consumers Energy Data: JHC_Sanitas_19.06.03

| | JHC-MW-15002 | JHC-MW-15005 |
|-------------------|--------------|--------------|
| 11/15/2016 | 11 | 49 |
| 4/18/2017 | | 38 |
| 4/19/2017 | <10 | |
| 6/20/2017 | <10 (D) | 39 |
| 8/14/2017 | 10.5 (D) | 36 |
| 4/25/2018 | 28 (D) | 61 |
| 6/19/2018 | 19 | 35 |
| 11/15/2018 | 67.5 (D) | 28 |
| 4/25/2019 | 96 | 38 (D) |
| Mean | 30.25 | 40.5 |
| Std. Dev. | 33.55 | 10.1 |
| Upper Lim. | 96 | 51.2 |
| Lower Lim. | 5 | 29.8 |

Non-Parametric Confidence Interval

Compliance Limit is not exceeded.



Constituent: Molybdenum, Total Analysis Run 6/10/2019 4:05 PM

Client: Consumers Energy Data: JHC_Sanitas_19.06.03

Confidence Interval


Constituent: Molybdenum, Total (ug/L) Analysis Run 6/10/2019 4:05 PM

Client: Consumers Energy Data: JHC_Sanitas_19.06.03

| | JHC-MW-15005 |
|-------------------|--------------|
| 11/15/2016 | 15 |
| 4/18/2017 | 18 |
| 6/20/2017 | 14 |
| 8/14/2017 | 10 |
| 4/25/2018 | 31.2 |
| 6/19/2018 | 15.7 |
| 11/15/2018 | 222 |
| 4/25/2019 | 885 (D) |
| Mean | 151.4 |
| Std. Dev. | 305 |
| Upper Lim. | 885 |
| Lower Lim. | 10 |

Non-Parametric Confidence Interval

Compliance Limit is not exceeded.



Constituent: Selenium, Total Analysis Run 6/10/2019 4:05 PM

Client: Consumers Energy Data: JHC_Sanitas_19.06.03

Confidence Interval

Constituent: Selenium, Total (ug/L) Analysis Run 6/10/2019 4:05 PM


Client: Consumers Energy Data: JHC_Sanitas_19.06.03

JHC-MW-15005

| | |
|-------------------|---------|
| 11/15/2016 | 165 |
| 4/18/2017 | 10 |
| 6/20/2017 | 15.5 |
| 8/14/2017 | 15.7 |
| 4/25/2018 | 368 |
| 6/19/2018 | 14 |
| 11/15/2018 | 158 |
| 4/25/2019 | 135 (D) |
| Mean | 110.2 |
| Std. Dev. | 125.1 |
| Upper Lim. | 368 |
| Lower Lim. | 10 |

Non-Parametric Confidence Interval

Compliance Limit is not exceeded.



Constituent: Thallium, Total Analysis Run 6/10/2019 4:05 PM

Client: Consumers Energy Data: JHC_Sanitas_19.06.03

Confidence Interval


Constituent: Thallium, Total (ug/L) Analysis Run 6/10/2019 4:05 PM

Client: Consumers Energy Data: JHC_Sanitas_19.06.03


JHC-MW-15005

| | |
|-------------------|-------|
| 11/15/2016 | 4 |
| 4/18/2017 | <2 |
| 6/20/2017 | <2 |
| 8/14/2017 | <2 |
| 4/25/2018 | 5.8 |
| 6/19/2018 | 2.1 |
| 11/15/2018 | <2 |
| 4/25/2019 | 2 (D) |
| Mean | 2.738 |
| Std. Dev. | 1.419 |
| Upper Lim. | 5.8 |
| Lower Lim. | 2 |

Arsenic, Total




Selenium, Total




Time Series Analysis Run 6/10/2019 3:58 PM
Client: Consumers Energy Data: JHC_Sanitas_19.06.03

Thallium, Total



Time Series Analysis Run 6/10/2019 3:58 PM
Client: Consumers Energy Data: JHC_Sanitas_19.06.03

Arsenic, Total
JHC-MW-15003



n = 12
Slope = -8.242
units per year.
Mann-Kendall
statistic = -53
critical = -35
Decreasing trend
significant at 98%
confidence level
($\alpha = 0.01$ per
tail).

Sen's Slope Estimator Analysis Run 6/10/2019 4:07 PM
Client: Consumers Energy Data: JHC_Sanitas_19.06.03

Appendix G October 2019 Assessment Monitoring Statistical Evaluation

Technical Memorandum

Date: December 17, 2019

To: Bethany Swanberg, Consumers Energy

cc: Brad Runkel, Consumers Energy
JR Register, Consumers Energy
Michelle Marion, Consumers Energy

From: Darby Litz, TRC
Sarah Holmstrom, TRC
Kristin Lowery, TRC

Project No.: 322174.0000.0000 Phase 1 Task 3

Subject: Statistical Evaluation of October 2019 Assessment Monitoring Sampling Event,
JH Campbell Bottom Ash Ponds 1-2 North and 1-2 South CCR Unit, Consumers Energy
Company, West Olive, Michigan

During the statistical evaluation of the initial assessment monitoring event, arsenic was present in one or more downgradient monitoring wells at statistically significant levels exceeding the Groundwater Protection Standards (GWPSs). Therefore, Consumers Energy Company (Consumers Energy) initiated an Assessment of Corrective Measures (ACM) within 90 days from when the Appendix IV exceedance was determined. The ACM was completed on September 11, 2019.

Currently, Consumers Energy is continuing semiannual assessment monitoring in accordance with §257.95 of the CCR Rule¹ at the JH Campbell Power Plant (JHC) Bottom Ash Ponds 1-2 North and 1-2 South (Ponds 1-2). The second semiannual assessment monitoring event of 2019 was conducted on October 7 through October 11, 2019. In accordance with §257.95, the assessment monitoring data must be compared to GWPSs to determine whether or not Appendix IV constituents are detected at statistically significant levels above the GWPSs. GWPSs were established in accordance with §257.95(h), as detailed in the October 15, 2018 *Groundwater Protection Standards* technical memorandum, which was also included in the 2018 *Annual Groundwater Monitoring Report* (2018

¹ USEPA final rule for the regulation and management of Coal Combustion Residuals (CCR) under the Resource Conservation and Recovery Act (RCRA) published April 17, 2015, as amended per Phase One, Part One of the CCR Rule (83 FR 36435).

Technical Memorandum

Annual Report) (TRC, January 2019). The following narrative describes the methods employed and the results obtained and the Sanitas™ output files are included as an attachment.

The statistical evaluation of the second semiannual assessment monitoring event for 2019 indicates that the following constituent is present at statistically significant levels exceeding the GWPS in downgradient monitoring wells at the Ponds 1-2 CCR Unit:

| <u>Constituent</u> | <u>GWPS</u> | <u># Downgradient Wells Observed</u> |
|--------------------|-------------|--------------------------------------|
| Arsenic | 10 ug/L | 1 of 6 |

These results are consistent with the results of the initial, and previous, assessment monitoring data statistical evaluation and Consumers Energy will continue to evaluate corrective measures per §257.96 and §257.97. Consumers Energy will continue executing the self-implementing groundwater compliance schedule in conformance with §257.90 - §257.98.

Assessment Monitoring Statistical Evaluation

The compliance well network at the Ponds 1-2 CCR Unit consists of six monitoring wells. JHC-MW-15001, JHC-MW-15002, JHC-MW-15003, and JHC-MW-15005 are located on the perimeter of the bottom ash ponds. Former downgradient monitoring well JHC-MW-15004 was decommissioned on June 14, 2018, during deconstruction of Unit 1-2; therefore, statistical analysis for JHC-MW-15004 terminates at the June 2018 monitoring event. Due to the cessation of hydraulic loading to Ponds 1-2 and Bottom Ash Ponds 3 North and 3 South (Pond 3), the groundwater flow direction changed significantly from the previous baseline and assessment monitoring events. In response, as documented in the 2018 Annual Report, Consumers Energy installed two new downgradient wells (JHC-MW-18004 and JHC-MW-18005) on the south and southwest edge of former Ponds 1-2 from December 3 through December 5, 2018 to reassess groundwater flow and ensure sufficient wells were appropriately located to assess groundwater quality downgradient from the Ponds 1-2 CCR Units. These wells were sampled for Appendix III and Appendix IV constituents in February and March 2019 in addition to the April 2019 semiannual assessment monitoring event. These data confirm that the monitoring wells are appropriately positioned to assess groundwater quality downgradient from the Ponds 1-2 CCR Unit. Therefore, JHC-MW-18004 and JHC-MW-18005 have been added to the downgradient monitoring network for Ponds 1-2 and are included in the statistical evaluation.

Following the second semiannual assessment monitoring sampling event, compliance well data for the JHC Ponds 1-2 were evaluated in accordance with the Groundwater Statistical Evaluation Plan (Stats Plan) (TRC, October 2017). An assessment monitoring program was developed to evaluate concentrations of CCR constituents present in the uppermost aquifer relative to acceptable levels (i.e. GWPSs). To evaluate whether or not a GWPS exceedance is statistically significant, the difference in concentration observed at the downgradient wells during a given assessment monitoring event compared to the GWPS must be large enough, after accounting for variability in the sample data, that

Technical Memorandum

the result is unlikely to have occurred merely by chance. Consistent with the Unified Guidance², the preferred method for comparisons to a fixed standard are confidence limits. An exceedance of the standard occurs when the 99 percent lower confidence level of the downgradient data exceeds the GWPS. Based on the number of historical observations in the representative sample population, the population mean, the population standard deviation, and a selected confidence level (*i.e.* 99 percent), an upper and lower confidence limit is calculated. The true concentration, with 99 percent confidence, will fall between the lower and upper confidence limits.

The concentrations observed in the downgradient wells are deemed to be a statistically significant exceedance when the 99 percent lower confidence limit of the downgradient data exceeds the GWPS. If the confidence interval straddles the GWPS (*i.e.* the lower confidence level is below the GWPS but the upper confidence level is above), the statistical test result indicates that there is insufficient confidence that the measured concentrations are different from the GWPS and thus there is no compelling evidence that the measured concentration is a result of a release from the CCR unit versus the inherent variability of the sample data. This statistical approach is consistent with the statistical methods for assessment monitoring presented in §257.93(f) and (g). Statistical evaluation methodologies built into the CCR Rule, and numerous other federal rules, are key in determining whether or not individually measured data points represent a concentration increase over the baseline or a fixed standard (such as a GWPS in an assessment monitoring program).

For each detected Appendix IV constituent, the concentrations for each well were first compared directly to the GWPS, as shown on Table A1. Parameter-well combinations that included a direct exceedance of the GWPS within the past eight monitoring events (April 2017 through October 2019) for JHC-MW-15001, JHC-MW-15002, JHC-MW-15003, and JHC-MW-15005 and the past five events (December 2018 through October 2019) for JHC-MW-18004 and JHC-MW-18005 were retained for further analysis. Direct comparison GWPS exceedances included the following parameter-well combinations:

- Arsenic in JHC-MW-15001,
- Arsenic and lithium in JHC-MW-15002,
- Arsenic, cobalt, and molybdenum in JHC-MW-15003,
- Lithium, molybdenum, selenium, and thallium in JHC-MW-15005, and
- Arsenic and selenium in JHC-MW-18005 at Ponds 1-2.

Cobalt was detected in JHC-MW-15003 at a concentration of 23.6 ug/L in November 2018, which exceeds its GWPS but did not exceed its GWPS in April 2019. Cobalt again exceeded its GWPS in October 2019. These are the only detections of cobalt in the Ponds 1-2 wells during either baseline sampling or assessment monitoring, and it was also not detected in the site background monitoring

² USEPA. 2009. *Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities, Unified Guidance*. Office of Conservation and Recovery. EPA 530/R-09-007.

Technical Memorandum

wells. However, to be conservative, the cobalt data have been retained in the assessment monitoring data set for this assessment monitoring data evaluation.

Groundwater data for the remaining parameter-well combinations with direct-comparison exceedances of a GWPS were then evaluated utilizing Sanitas™ statistical software. Sanitas™ is a software tool that is commercially available for performing statistical evaluation consistent with procedures outlined in the Unified Guidance. Within the Sanitas™ statistical program, confidence limits were selected to perform the statistical comparison of compliance data to a fixed standard. Parametric and non-parametric confidence intervals were calculated, as appropriate, for each of the CCR Appendix IV parameters using a 99 percent confidence level, i.e., a significance level (α) of 0.01. The following narrative describes the methods employed, the results obtained and the Sanitas™ output files are included as an attachment.

The statistical data evaluation included the following steps:

- Review of data quality checklists for the data sets;
- Graphical representation of the monitoring data as time versus concentration by well-constituent pair;
- Outlier testing of individual data points that appear from the graphical representations as potential outliers;
- Evaluation of visual trends apparent in the graphical representations for statistical significance;
- Evaluation of percentage of non-detects for each well-constituent pair;
- Distribution of the data; and
- Calculation of the confidence intervals for each cumulative dataset.

The results of these evaluations are presented and discussed below.

Initially, the baseline (December 2015 through August 2017) results and the assessment monitoring results (April 2018 through October 2019) for these well-constituent pairs were observed visually for potential trends. Potential increasing trends were noted for lithium in JHC-MW-15002 and molybdenum in JHC-MW-15005 beginning in November 2018. Groundwater conditions are re-equilibrating following to CCR removal activities at the JHC Ponds 1-2 that were completed in September 2018, and the groundwater monitoring system is being re-assessed to account for post-deconstruction groundwater conditions. Hydrogeologic conditions are in the process of stabilizing and recent groundwater samples from JHC-MW-15002 and JHC-MW-15005 may no longer represent groundwater passing beneath JHC Ponds 1-2. In order to be conservative, the suspect lithium and molybdenum data from November 2018 through October 2019 have been kept in the assessment monitoring data set pending the collection of additional data. The suspect data will be tested for outliers once stabilized groundwater characteristics have been assessed. Data from each round were evaluated for completeness, overall quality, and usability and were deemed appropriate for the purposes of the CCR assessment monitoring program.

Technical Memorandum

The Sanitas™ software was then used to test compliance at the downgradient monitoring wells using the confidence interval method for the most recent eight sampling events (five events for JHC-MW-18005). Eight independent sampling events provide the appropriate density of data as recommended per the Unified Guidance yet are collected recently enough to provide an indication of current condition. The tests were run with a per-well significance of $\alpha = 0.01$. The software outputs are included in Attachment 1 along with data reports showing the values used for the evaluation. Non-detect data was handled in accordance with the Stats Plan for the purposes of calculating the confidence intervals.

The Sanitas™ software generates an output that includes graphs of the parametric or non-parametric confidence intervals for each well along with notes on data transformations, as appropriate. Data distributions were as follows:

| DISTRIBUTION | PARAMETER-WELL COMBINATIONS |
|--|--|
| Normal | Arsenic in JHC-MW-15003 and JHC-MW-18005 Lithium in JHC-MW-15005 |
| Normalized by square root transformation | Arsenic in JHC-MW-15001 Lithium in JHC-MW-15002 Selenium in JHC-MW-15005 and JHC-MW-18005 Thallium in JHC-MW-15005 (Kaplan-Meier) |
| Normalized by natural log transformation | Arsenic in JHC-MW-15002 Molybdenum in JHC-MW-15003 |
| Non-Parametric (not normalizable) | Cobalt in JHC-MW-15003 Molybdenum in JHC-MW-15005 |

The confidence interval test compares the lower confidence limit to the GWPS. The statistical evaluation of the Appendix IV constituents shows a statistically significance GWPS exceedances for arsenic in JHC-MW-15002. These results are consistent with the results of the initial assessment monitoring data statistical evaluation and Consumers Energy will continue to evaluate corrective measures per §257.96 and §257.97. Consumers Energy will continue executing the self-implementing groundwater compliance schedule in conformance with §257.90 - §257.98.

Attachments

- Table A1. Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to October 2019
- Attachment 1 Sanitas™ Output

Technical Memorandum

Table

Table A1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to October 2019
 JH Campbell Ponds 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15001 | | | | | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|------------|--------------|----------|-----------|-----------|------------|-----------|-----------|-----------|-----------|--------------------|-----------|-------------|-----------|-----------|
| Sample Date: | | | | | | 12/7/2015 | 3/8/2016 | 6/21/2016 | 8/29/2016 | 11/15/2016 | 4/19/2017 | 6/20/2017 | 8/14/2017 | 9/25/2017 | 4/25/2018 | 6/18/2018 | 11/13/2018 | 4/25/2019 | 10/9/2019 |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | NA | 51 | NA | 396 | 235 | 195 | 271 | 309 | 149 | 368 | 238 | 287 | -- | 339 | 146 | 78 | 150 |
| Calcium | mg/L | NC | NA | 46 | NA | 85.6 | 84.1 | 80.7 | 74.0 | 75.5 | 70.3 | 50.7 | 70.9 | 68 | -- | 68.6 | 72.1 | 69 | 73 |
| Chloride | mg/L | 250* | NA | 43 | NA | 12.3 | 48.4 | 152 | 98.5 | 105 | 7.1 | 51.8 | 94.8 | 73.6 | -- | 109 | 2.7 | < 2.0 | < 2.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250* | NA | 14 | NA | 142 | 46.2 | 34.9 | 46.4 | 68.3 | 42.1 | 88 | 114 | 129 | -- | 78.9 | 59.1 | 39 | 21 |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 630 | 190 | 570 | 550 | 560 | 440 | 340 | 562 | 563 | -- | 596 | 310 | 280 | 350 |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 6.6 | 6.4 | 6.2 | 6.0 | 6.4 | 6.3 | 6.2 | 6.3 | 6.2 | 7.2 ⁽¹⁾ | 6.3 | 6.3 | 6.0 | 6.4 |
| Appendix IV | | | | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 6 | 3 | 3 | 4 | 3 | 4 | 1.8 | 2.2 | -- | < 1.0 | 1.8 | 12.7 | 5.8 | 6.3 |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 160 | 148 | 164 | 148 | 141 | 172 | 106 | 142 | -- | 71.4 | 183 | 84.9 | 58 | 95 |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | NA | 2 | 100 | 1 | 2 | 2 | 2 | 3 | 2 | 1.0 | 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | 1.2 |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | -- | < 15.0 | < 15.0 | < 6.0 | < 6.0 | < 6.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 40 | 10 | 40 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | -- | < 10 | < 10 | < 10 | < 10 | < 10 |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 | < 0.20 | 0.25 |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | < 5 | < 5 | < 5 | < 5 | < 5 | < 5 | < 5.0 | < 5.0 | -- | < 5.0 | < 5.0 | 13.3 | < 5.0 | < 5.0 |
| Radium-226 | pCi/L | NC | NA | NA | NA | < 0.234 | < 0.211 | 0.344 | < 0.389 | < 0.379 | < 0.352 | < 1.63 | < 0.708 | -- | < 0.545 | < 0.828 | < 0.755 | < 0.101 | < 0.162 |
| Radium-228 | pCi/L | NC | NA | NA | NA | 1.67 | 1.34 | 2.24 | 1.56 | 1.60 | 2.07 | < 0.628 | 1.20 | -- | < 0.799 | < 1.12 | < 0.879 | < 0.447 | < 0.516 |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | 1.90 | 1.53 | 2.58 | 1.77 | 1.89 | 2.13 | < 2.26 | 1.61 | -- | < 1.34 | < 1.95 | < 1.63 | < 0.447 | < 0.516 |
| Selenium | ug/L | 50 | NA | 5 | 50 | < 1 | 1 | 1 | < 1 | 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Thallium | ug/L | 2 | NA | 2 | 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2.0 | < 2.0 | -- | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 |

Notes:

- ug/L - micrograms per liter.
- mg/L - milligrams per liter.
- SU - standard units; pH is a field parameter.
- pCi/L - picocuries per liter.
- NA - not applicable.
- NC - no criteria.
- - not analyzed.
- MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April 2012.
- RSL - Regional Screening Level from 83 FR 36435.
- UTL - Upper Tolerance Limit (95%) of the background data set.
- GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
- * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April 2012.
- Bold** value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
- All metals were analyzed as total unless otherwise specified.
- (1) pH value potentially biased high due to groundwater quality meter malfunction.
- (2) JHC-MW-15004 was decommissioned on June 14th, 2018.
- (3) Field meter reading not usable due to malfunctioning groundwater meter. Displayed value is lab pH reading from an unpreserved bottle.

Table A1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to October 2019
 JH Campbell Ponds 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15002 | | | | | | | | | | | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|------------|--------------|-----------|-----------|-----------|------------|-----------|-------------|-------------|-------------|-------------|-----------|-----------|---------------------|------------|------------|-------------|-------------|-----------|------------|-------|
| Sample Date: | | | | | | 12/7/2015 | 3/8/2016 | 6/21/2016 | 8/30/2016 | 11/15/2016 | 4/19/2017 | 6/20/2017 | 6/20/2017 | 8/14/2017 | 8/14/2017 | 9/25/2017 | 9/25/2017 | 4/25/2018 | 4/25/2018 | 6/19/2018 | 11/15/2018 | 11/15/2018 | 4/25/2019 | 10/9/2019 | |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | NA | 51 | NA | 661 | 426 | 433 | 831 | 757 | 602 | 768 | Field Dup | 678 | 869 | 946 | 927 | 894 | -- | -- | 430 | 1,470 | 1,360 | 3,200 | 1,700 |
| Calcium | mg/L | NC | NA | 46 | NA | 21.9 | 35.8 | 36.4 | 36.1 | 18.9 | 28.0 | 24.6 | 25.1 | 25.7 | 18.2 | 25.3 | 30.5 | 30.6 | -- | -- | 75.3 | 41.9 | 41.1 | 85 | 99 |
| Chloride | mg/L | 250* | NA | 43 | NA | 13.2 | 18.5 | 23.4 | 17.4 | 14.4 | 25.7 | 20.7 | 20.7 | 20.7 | 20.2 | 25.8 | 26.0 | -- | -- | 22.3 | 19.3 | 19.2 | 17 | 20 | |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | |
| Sulfate | mg/L | 250* | NA | 14 | NA | 33.3 | 47.8 | 46.9 | 54.0 | 51.4 | 64.2 | 52.8 | 53.3 | 54.5 | 53.7 | 33.9 | 34.3 | -- | -- | 153 | 95.2 | 94.5 | 190 | 280 | |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 150 | 160 | 180 | 190 | 140 | 190 | 160 | 130 | 236 | 174 | 144 | 148 | -- | -- | 356 | 222 | 274 | 410 | 480 | |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 8.8 | 8.7 | 8.5 | 8.6 | 8.8 | 8.8 | 9.2 | -- | 9.2 | -- | 9.6 | -- | 10.2 ⁽¹⁾ | -- | 8.3 | 8.0 | -- | 6.9 | 6.5 | |
| Appendix IV | | | | | | | | | | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | < 1 | < 1 | 4 | 3 | 1 | < 1 | 3.3 | 2.9 | 1.9 | 2.1 | -- | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 34 | 40 | 36 | 34 | 46 | 33 | 35.4 | 32.2 | 44.5 | 45.8 | -- | -- | 129 | 130 | 127 | 60.5 | 59.5 | 50 | 57 | |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 10 | 9 | 8 | 8 | 8 | 8 | 7.2 | 6.3 | 7.8 | 7.7 | -- | -- | 30.4 | 30.4 | 19.8 | 18.4 | 18.1 | 49 | 150 | |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | -- | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | -- | -- | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | |
| Chromium | ug/L | 100 | NA | 2 | 100 | < 1 | < 1 | < 1 | < 1 | 1 | 2 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | -- | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | < 15.0 | < 15.0 | -- | -- | < 15.0 | < 15.0 | < 15.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | -- | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | |
| Lithium | ug/L | NC | 40 | 10 | 40 | 12.1 | 10.1 | < 10 | < 10 | 11 | < 10 | < 10 | < 10 | 11 | < 10 | -- | -- | 28 | 28 | 19 | 68 | 67 | 96 | 240 | |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | -- | -- | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | 10 | 93 | 18 | 18 | 16 | 48 | 21.4 | 19.2 | 19.0 | 19.0 | -- | -- | 12.6 | 12.7 | 7.5 | 9.2 | 9.0 | < 5.0 | 15 | |
| Radium-226 | pCi/L | NC | NA | NA | NA | < 0.330 | < 0.244 | < 0.219 | < 0.487 | < 0.251 | < 0.409 | < 0.562 | < 0.154 | 0.749 | 0.949 | -- | -- | < 0.823 | < 0.530 | < 0.620 | < 1.09 | 0.921 | 0.233 | 0.698 | |
| Radium-228 | pCi/L | NC | NA | NA | NA | 0.986 | < 0.737 | < 0.649 | 2.83 | < 0.496 | < 0.702 | < 0.765 | < 0.690 | < 0.797 | < 0.790 | -- | -- | < 0.729 | < 1.33 | < 1.58 | 1.04 | 0.767 | 0.409 | < 0.394 | |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | 1.09 | < 0.737 | < 0.649 | 2.9 | < 0.496 | < 0.702 | < 1.33 | < 0.844 | < 1.43 | < 1.26 | -- | -- | < 1.55 | < 1.86 | < 2.20 | < 1.70 | 1.69 | 0.642 | 1.04 | |
| Selenium | ug/L | 50 | NA | 5 | 50 | < 1 | 4 | < 1 | < 1 | 2 | 4 | 7.8 | 7.3 | 3.5 | 5.1 | -- | -- | < 1.0 | < 1.0 | < 1.0 | 2.5 | 2.8 | < 1.0 | < 1.0 | |
| Thallium | ug/L | 2 | NA | 2 | 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | -- | -- | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | |

Notes:
 ug/L - micrograms per liter.
 mg/L - milligrams per liter.
 SU - standard units; pH is a field parameter.
 pCi/L - picocuries per liter.
 NA - not applicable.
 NC - no criteria.
 -- - not analyzed.
 MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April 2012.
 RSL - Regional Screening Level from 83 FR 36435.
 UTL - Upper Tolerance Limit (95%) of the background data set.
 GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
 * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April 2012.
Bold value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
 All metals were analyzed as total unless otherwise specified.
 (1) pH value potentially biased high due to groundwater quality meter malfunction.
 (2) JHC-MW-15004 was decommissioned on June 14th, 2018.
 (3) Field meter reading not usable due to malfunctioning groundwater meter. Displayed value is lab pH reading from an unpreserved bottle.

Table A1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to October 2019
 JH Campbell Ponds 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15003 | | | | | | | | | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|------------|--------------|-----------|-----------|-----------|------------|-----------|-------------|-------------|-----------|-------------|-------------|-------------|-------------|-----------|------------|------------|--|--|
| Sample Date: | | | | | | 12/5/2015 | 3/8/2016 | 6/21/2016 | 8/29/2016 | 11/15/2016 | 4/18/2017 | 6/20/2017 | 8/14/2017 | 9/25/2017 | 4/25/2018 | 6/18/2018 | 6/18/2018 | 11/15/2018 | 4/29/2019 | 10/9/2019 | 10/9/2019 | | |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | NA | 51 | NA | 439 | 455 | 426 | 882 | 1,670 | 1,280 | 1,240 | 1,150 | 1,120 | -- | 1,170 | 1,320 | 1,120 | 1,700 | 3,500 | 3,300 | | |
| Calcium | mg/L | NC | NA | 46 | NA | 27.9 | 46.7 | 38.3 | 44.3 | 31.8 | 34.6 | 28.8 | 36.0 | 30.1 | -- | 60.0 | 59.1 | 115 | 36 | 110 | 110 | | |
| Chloride | mg/L | 250* | NA | 43 | NA | 21.7 | 25.7 | 28.5 | 20.1 | 30.8 | 27.9 | 24.0 | 22.0 | 19.3 | -- | 37.5 | 36.6 | 16.3 | 18 | 47 | 47 | | |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | | |
| Sulfate | mg/L | 250* | NA | 14 | NA | 41.3 | 52.7 | 48.1 | 45.8 | 63.0 | 71.8 | 61.8 | 61.9 | 51.9 | -- | 81.9 | 82.7 | 294 | 75 | 210 | 220 | | |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 160 | 200 | 190 | 220 | 230 | 260 | 146 | 208 | 136 | -- | 388 | 344 | 644 | 200 | 580 | 600 | | |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 9.0 | 9.3 | 9.2 | 9.1 | 8.6 | 8.7 | 9.3 | 9.3 | 9.7 | 9.3 | 8.9 | -- | 8.7 | 8.4 | 8.7 | -- | | |
| Appendix IV | | | | | | | | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | < 1 | < 1 | < 1 | < 1 | 2 | 1 | < 1.0 | 1.3 | -- | 1.5 | 1.9 | 1.8 | 2.0 | 2.2 | 1.4 | 1.4 | | |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 38 | 31 | 27 | 27 | 36 | 26 | 20.4 | 23.7 | -- | 12.4 | 14.1 | 14.3 | 8.1 | 10 | 8.4 | 7.7 | | |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 21 | 16 | 15 | 19 | 18 | 16 | 18.0 | 18.0 | -- | 42.3 | 55.7 | 52.5 | 113 | 42 | 91 | 89 | | |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | | |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 | 1.7 | 0.41 | 2.5 | 2.5 | | |
| Chromium | ug/L | 100 | NA | 2 | 100 | 2 | 5 | 2 | 1 | 5 | 12 | 12.3 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | 13.6 | 4.2 | 11 | 10 | | |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | -- | < 15.0 | < 15.0 | < 15.0 | 23.6 | < 6.0 | 43 | 41 | | |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | | |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | | |
| Lithium | ug/L | NC | 40 | 10 | 40 | 11.1 | < 10 | < 10 | < 10 | 11 | < 10 | < 10 | < 10 | -- | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | | |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | | |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | 9 | 11 | 20 | 13 | 24 | 30 | 21.1 | 28.2 | -- | 19.3 | 53.0 | 51.2 | 65.3 | 20 | 120 | 120 | | |
| Radium-226 | pCi/L | NC | NA | NA | NA | < 0.250 | < 0.236 | < 0.211 | < 0.365 | < 0.249 | < 0.302 | < 1.12 | 1.15 | -- | < 0.631 | < 0.623 | < 0.733 | < 0.579 | < 0.113 | 0.301 | 0.430 | | |
| Radium-228 | pCi/L | NC | NA | NA | NA | < 0.412 | < 0.575 | < 0.539 | < 0.724 | < 0.369 | 0.633 | < 0.722 | < 0.938 | -- | < 0.732 | < 1.01 | < 1.08 | < 0.657 | < 0.530 | 0.421 | < 0.361 | | |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | < 0.412 | < 0.575 | < 0.539 | < 0.724 | < 0.369 | 0.769 | < 1.84 | 1.81 | -- | < 1.36 | < 1.63 | < 1.81 | < 1.24 | < 0.530 | 0.722 | 0.559 | | |
| Selenium | ug/L | 50 | NA | 5 | 50 | < 1 | 3 | < 1 | < 1 | 2 | 3 | < 1.0 | 1.1 | -- | 2.2 | 4.4 | 4.5 | 28.6 | 2.9 | 18 | 19 | | |
| Thallium | ug/L | 2 | NA | 2 | 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2.0 | < 2.0 | -- | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | | |

Notes:
 ug/L - micrograms per liter.
 mg/L - milligrams per liter.
 SU - standard units; pH is a field parameter.
 pCi/L - picocuries per liter.
 NA - not applicable.
 NC - no criteria.
 -- - not analyzed.
 MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April 2012.
 RSL - Regional Screening Level from 83 FR 36435.
 UTL - Upper Tolerance Limit (95%) of the background data set.
 GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
 * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April 2012.
Bold value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
 All metals were analyzed as total unless otherwise specified.
 (1) pH value potentially biased high due to groundwater quality meter malfunction.
 (2) JHC-MW-15004 was decommissioned on June 14th, 2018.
 (3) Field meter reading not usable due to malfunctioning groundwater meter. Displayed value is lab pH reading from an unpreserved bottle.

Table A1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to October 2019
 JH Campbell Ponds 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15004 ⁽²⁾ | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|------------|-----------------------------|----------|-----------|-----------|------------|-----------|-----------|------------|-----------|-----------|
| Sample Date: | | | | | | 12/5/2015 | 3/8/2016 | 6/22/2016 | 8/30/2016 | 11/15/2016 | 4/18/2017 | 6/20/2017 | 8/14/2017 | 9/25/2017 | 4/25/2018 |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | NA | 51 | NA | 546 | 268 | 412 | 469 | 578 | 260 | 473 | 660 | 376 | -- |
| Calcium | mg/L | NC | NA | 46 | NA | 43.1 | 42.8 | 45.8 | 64.6 | 101 | 36.9 | 37.7 | 51.2 | 78.6 | -- |
| Chloride | mg/L | 250* | NA | 43 | NA | 41.6 | 35.5 | 26.4 | 23.7 | 70.8 | 46.8 | 67.5 | 95.1 | 41.5 | -- |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250* | NA | 14 | NA | 55.0 | 42.5 | 48.7 | 47.8 | 244 | 58.6 | 85.6 | 122 | 64.6 | -- |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 290 | 220 | 230 | 370 | 560 | 290 | 322 | 402 | 382 | -- |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 7.6 | 7.3 | 7.1 | 6.8 | 7.3 | 7.6 | 7.4 | 7.6 | 7.1 | 7.3 |
| Appendix IV | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | < 1 | < 1 | 1 | 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 21 | 9 | 11 | 8 | 6 | 4 | 4.8 | 5.7 | -- | 3.6 |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 73 | 65 | 117 | 181 | 241 | 110 | 93.2 | 193 | -- | 162 |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 |
| Chromium | ug/L | 100 | NA | 2 | 100 | 1 | 1 | 1 | 1 | 1 | 3 | 6.9 | < 1.0 | -- | < 1.0 |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | -- | < 15.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 |
| Lithium | ug/L | NC | 40 | 10 | 40 | < 10 | < 10 | < 10 | 12 | 12 | < 10 | < 10 | 10 | -- | < 10 |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | 9 | 8 | 10 | 5 | 10 | 6 | 10.1 | 11.2 | -- | < 5.0 |
| Radium-226 | pCi/L | NC | NA | NA | NA | < 0.295 | 0.259 | < 0.189 | < 0.29 | < 0.311 | < 0.333 | < 0.502 | 0.915 | -- | < 0.449 |
| Radium-228 | pCi/L | NC | NA | NA | NA | 0.422 | 0.452 | 0.605 | 1.62 | 0.856 | 0.366 | < 0.685 | < 0.920 | -- | < 0.787 |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | 0.702 | 0.711 | 0.633 | 1.85 | 1.12 | 0.497 | < 1.19 | 1.66 | -- | < 1.24 |
| Selenium | ug/L | 50 | NA | 5 | 50 | 8 | 2 | 2 | 7 | 1 | 2 | < 1.0 | < 1.0 | -- | 5.5 |
| Thallium | ug/L | 2 | NA | 2 | 2 | 2.16 | < 2 | 2 | 4 | 3 | < 2 | < 2.0 | 2.1 | -- | < 2.0 |

Notes:

ug/L - micrograms per liter.

mg/L - milligrams per liter.

SU - standard units; pH is a field parameter.

pCi/L - picocuries per liter.

NA - not applicable.

NC - no criteria.

-- - not analyzed.

MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April 2012.

RSL - Regional Screening Level from 83 FR 36435.

UTL - Upper Tolerance Limit (95%) of the background data set.

GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's

Technical Memorandum dated October 15, 2018.

* - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations

(SDWR) April 2012.

Bold value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.

All metals were analyzed as total unless otherwise specified.

(1) pH value potentially biased high due to groundwater quality meter malfunction.

(2) JHC-MW-15004 was decommissioned on June 14th, 2018.

(3) Field meter reading not usable due to malfunctioning groundwater meter. Displayed value is lab pH reading from an unpreserved bottle.

Table A1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to October 2019
 JH Campbell Ponds 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan

| Sample Location: | | | | | | JHC-MW-15005 | | | | | | | | | | | | | | |
|------------------------|-------|------------|---------|-----------|-------|--------------|----------|-----------|-----------|------------|-----------|-----------|-----------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| Sample Date: | | | | | | 12/5/2015 | 3/8/2016 | 6/22/2016 | 8/30/2016 | 11/15/2016 | 4/18/2017 | 6/20/2017 | 8/14/2017 | 9/25/2017 | 4/25/2018 | 6/19/2018 | 11/15/2018 | 4/25/2019 | 4/25/2019 | 10/9/2019 |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | NA | 51 | NA | 275 | 959 | 1,370 | 706 | 1,500 | 524 | 468 | 546 | 481 | -- | 227 | 1,450 | 2,800 | 2,900 | 1,200 |
| Calcium | mg/L | NC | NA | 46 | NA | 55.0 | 60.2 | 55.1 | 51.6 | 73.4 | 56.8 | 53.6 | 48.0 | 40.3 | -- | 61.8 | 61.9 | 170 | 180 | 110 |
| Chloride | mg/L | 250* | NA | 43 | NA | 27.7 | 42.0 | 46.9 | 19.2 | 29.3 | 64.2 | 50.4 | 27.1 | 21.8 | -- | 90.9 | 30.6 | 28 | 28 | 30 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250* | NA | 14 | NA | 51.2 | 53.0 | 57.9 | 46.5 | 61.8 | 58.3 | 66.0 | 64.9 | 61.9 | -- | 74.3 | 133 | 240 | 320 | 130 |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 270 | 300 | 310 | 230 | 320 | 360 | 306 | 282 | 300 | -- | 462 | 334 | 800 | 780 | 360 |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 7.3 | 7.4 | 7.4 | 7.3 | 7.1 | 7.5 | 7.4 | 7.5 | 7.4 | 7.4 | 7.4 | 7.5 | 7.2 | -- | 7.3 |
| Appendix IV | | | | | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | 4 | 2 | 2 | 3 | 5 | 3 | 3.8 | 4.2 | -- | 2.2 | 1.6 | 5.1 | 4.4 | 4.2 | 3.3 |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 4 | 3 | 3 | 5 | 3 | 2 | 3.3 | 2.5 | -- | 1.7 | 1.3 | 1.2 | 1.2 | 1.1 | 1.4 |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 99 | 74 | 97 | 72 | 159 | 128 | 113 | 109 | -- | 407 | 175 | 149 | 150 | 150 | 190 |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | NA | 2 | 100 | 4 | 5 | 12 | 2 | 3 | 4 | 3.7 | < 1.0 | -- | < 1.0 | 3.0 | < 1.0 | 1.3 | 1.3 | 1.3 |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15 | < 15.0 | < 15.0 | -- | < 15.0 | < 15.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 1.0 | < 1.0 | -- | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 40 | 10 | 40 | 41.3 | 25.5 | 28 | 31 | 49 | 38 | 39 | 36 | -- | 61 | 35 | 28 | 38 | 38 | 50 |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.20 | -- | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | 12 | 13 | 25 | 16 | 15 | 18 | 14.0 | 10 | -- | 31.2 | 15.7 | 222 | 900 | 870 | 370 |
| Radium-226 | pCi/L | NC | NA | NA | NA | < 0.277 | < 0.355 | 0.192 | < 0.286 | < 0.246 | 0.461 | < 0.717 | < 0.877 | -- | 0.620 | < 0.758 | < 0.461 | 0.169 | 0.248 | 0.592 |
| Radium-228 | pCi/L | NC | NA | NA | NA | 0.436 | < 0.426 | < 0.395 | 1.58 | 0.745 | < 0.383 | < 0.728 | < 0.856 | -- | 0.700 | 1.220 | 0.967 | < 0.350 | 0.495 | 0.427 |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | 0.564 | < 0.426 | < 0.395 | 1.78 | 0.974 | 0.841 | < 1.45 | < 1.73 | -- | 1.32 | 1.91 | 1.41 | < 0.350 | 0.743 | 1.02 |
| Selenium | ug/L | 50 | NA | 5 | 50 | 28 | 12 | 33 | 18 | 165 | 10 | 15.5 | 15.7 | -- | 368 | 14 | 158 | 140 | 130 | 66 |
| Thallium | ug/L | 2 | NA | 2 | 2 | 3.04 | < 2 | 2 | 2 | 4 | < 2 | < 2.0 | < 2.0 | -- | 5.8 | 2.1 | < 2.0 | 2.0 | < 2.0 | 2.9 |

Notes:

- ug/L - micrograms per liter.
- mg/L - milligrams per liter.
- SU - standard units; pH is a field parameter.
- pCi/L - picocuries per liter.
- NA - not applicable.
- NC - no criteria.
- - not analyzed.
- MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April 2012.
- RSL - Regional Screening Level from 83 FR 36435.
- UTL - Upper Tolerance Limit (95%) of the background data set.
- GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
- * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April 2012.
- Bold** value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
- All metals were analyzed as total unless otherwise specified.
- (1) pH value potentially biased high due to groundwater quality meter malfunction.
- (2) JHC-MW-15004 was decommissioned on June 14th, 2018.
- (3) Field meter reading not usable due to malfunctioning groundwater meter. Displayed value is lab pH reading from an unpreserved bottle.

Table A1
 Comparison of Groundwater Sampling Results to Groundwater Protection Standards – December 2015 to October 2019
 JH Campbell Ponds 1-2N/1-2S – RCRA CCR Monitoring Program
 West Olive, Michigan


| Sample Location: | | | | | | JHC-MW-18004 | | | | | JHC-MW-18005 | | | | | | |
|------------------------|-------|------------|---------|-----------|------------|--------------|--------------------|-----------|-----------|-----------|--------------|--------------------|-----------|-----------|-----------|-----------|------------|
| Sample Date: | | | | | | 12/7/2018 | 2/28/2019 | 4/25/2019 | 8/13/2019 | 10/9/2019 | 12/7/2018 | 2/28/2019 | 2/28/2019 | 4/25/2019 | 8/13/2019 | 8/13/2019 | 10/9/2019 |
| Constituent | Unit | EPA MCL | EPA RSL | UTL | GWPS | downgradient | | | | | | | | | | | |
| Appendix III | | | | | | | | | | | | | | | | | |
| Boron | ug/L | NC | NA | 51 | NA | 970 | 900 | 920 | 1,200 | 620 | 641 | 660 | 720 | 650 | 750 | 780 | 660 |
| Calcium | mg/L | NC | NA | 46 | NA | 48.9 | 55 | 72 | 97 | 73 | 32.5 | 43 | 42 | 41 | 43 | 45 | 55 |
| Chloride | mg/L | 250* | NA | 43 | NA | 25.7 | 50 | 34 | 35 | 40 | 29.8 | 27 | 26 | 25 | 27 | 27 | 18 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | NA | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Sulfate | mg/L | 250* | NA | 14 | NA | 109 | 69 | 100 | 110 | 120 | 90 | 89 | 85 | 66 | 95 | 95 | 110 |
| Total Dissolved Solids | mg/L | 500* | NA | 258 | NA | 306 | 330 | 380 | 490 | 310 | 234 | 280 | 260 | 250 | 270 | 290 | 330 |
| pH, Field | SU | 6.5 - 8.5* | NA | 4.8 - 9.2 | NA | 7.0 | 7.6 ⁽³⁾ | 7.2 | 7.5 | 7.2 | 8.8 | 8.6 ⁽³⁾ | -- | 9.0 | 8.9 | -- | 8.8 |
| Appendix IV | | | | | | | | | | | | | | | | | |
| Antimony | ug/L | 6 | NA | 2 | 6 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Arsenic | ug/L | 10 | NA | 1 | 10 | 1.0 | < 1.0 | 1.1 | 1.2 | 1.1 | 9.5 | 10 | 11 | 8.8 | 7.4 | 7.3 | 7.1 |
| Barium | ug/L | 2,000 | NA | 35 | 2,000 | 92.6 | 170 | 220 | 680 | 270 | 58.1 | 72 | 73 | 73 | 120 | 120 | 150 |
| Beryllium | ug/L | 4 | NA | 1 | 4 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Cadmium | ug/L | 5 | NA | 0.2 | 5 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Chromium | ug/L | 100 | NA | 2 | 100 | < 1.0 | 1.2 | 2.0 | 1.8 | 1.3 | 1.5 | 4.0 | 4.1 | 2.8 | 2.3 | 2.4 | 1.9 |
| Cobalt | ug/L | NC | 6 | 15 | 15 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 |
| Fluoride | ug/L | 4,000 | NA | 1,000 | 4,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 | < 1,000 |
| Lead | ug/L | NC | 15 | 1 | 15 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 | < 1.0 |
| Lithium | ug/L | NC | 40 | 10 | 40 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 |
| Mercury | ug/L | 2 | NA | 0.2 | 2 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 | < 0.20 |
| Molybdenum | ug/L | NC | 100 | 5 | 100 | 7.4 | 7.4 | 8.2 | 9.0 | 10 | 18.6 | 14 | 15 | 14 | 15 | 15 | 66 |
| Radium-226 | pCi/L | NC | NA | NA | NA | < 0.695 | < 0.0742 | 0.110 | 0.352 | 0.179 | < 0.567 | < 0.0795 | < 0.0779 | < 0.0785 | < 0.145 | 0.150 | 0.497 |
| Radium-228 | pCi/L | NC | NA | NA | NA | < 0.708 | 0.589 | < 0.430 | 0.469 | 0.672 | < 0.760 | < 0.386 | < 0.337 | < 0.357 | < 0.400 | < 0.374 | 0.456 |
| Radium-226/228 | pCi/L | 5 | NA | 1.93 | 5 | < 1.40 | 0.654 | < 0.430 | 0.822 | 0.851 | < 1.33 | < 0.386 | < 0.337 | < 0.357 | < 0.400 | < 0.374 | 0.953 |
| Selenium | ug/L | 50 | NA | 5 | 50 | 7.3 | 12 | 12 | 39 | 33 | 42.0 | 35 | 34 | 16 | 11 | 11 | 140 |
| Thallium | ug/L | 2 | NA | 2 | 2 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 |

Notes:

- ug/L - micrograms per liter.
- mg/L - milligrams per liter.
- SU - standard units; pH is a field parameter.
- pCi/L - picocuries per liter.
- NA - not applicable.
- NC - no criteria.
- - not analyzed.
- MCL - Maximum Contaminant Level, EPA Drinking Water Standards and Health Advisories, April 2012.
- RSL - Regional Screening Level from 83 FR 36435.
- UTL - Upper Tolerance Limit (95%) of the background data set.
- GWPS - Groundwater Protection Standard. GWPS is the higher of the MCL/RSL and UTL as established in TRC's Technical Memorandum dated October 15, 2018.
- * - Secondary Maximum Contaminant Level (SMCL), EPA Secondary Drinking Water Regulations (SDWR) April 2012.
- Bold** value indicates an exceedance of the GWPS. Data from downgradient monitoring wells are screened against the GWPS for evaluation purposes only. Confidence intervals will be used to determine compliance per the CCR rules.
- All metals were analyzed as total unless otherwise specified.
- (1) pH value potentially biased high due to groundwater quality meter malfunction.
- (2) JHC-MW-15004 was decommissioned on June 14th, 2018.
- (3) Field meter reading not usable due to malfunctioning groundwater meter. Displayed value is lab pH reading from an unpreserved bottle.

Attachment 1
Sanitas™ Output


Time Series



Constituent: Arsenic, Total Analysis Run 12/10/2019 6:47 AM

Client: Consumers Energy Data: JHC_Sanitas_19.11.14


Time Series



Constituent: Cobalt, Total Analysis Run 12/10/2019 6:48 AM


Client: Consumers Energy Data: JHC_Sanitas_19.11.14

Time Series



Constituent: Lithium, Total Analysis Run 12/10/2019 6:48 AM
Client: Consumers Energy Data: JHC_Sanitas_19.11.14


Time Series



Constituent: Molybdenum, Total Analysis Run 12/10/2019 6:49 AM

Client: Consumers Energy Data: JHC_Sanitas_19.11.14


Time Series



Constituent: Selenium, Total Analysis Run 12/10/2019 6:49 AM

Client: Consumers Energy Data: JHC_Sanitas_19.11.14

Time Series




Constituent: Thallium, Total Analysis Run 12/10/2019 6:50 AM

Client: Consumers Energy Data: JHC_Sanitas_19.11.14

Sen's Slope Estimator

JHC-MW-15002




n = 8
Slope = 46
units per year.
Mann-Kendall
statistic = 25
critical = 20
Increasing trend
significant at 98%
confidence level
($\alpha = 0.01$ per
tail).

Constituent: Lithium, Total Analysis Run 12/10/2019 6:50 AM

Client: Consumers Energy Data: JHC_Sanitas_19.11.14

Sen's Slope Estimator

JHC-MW-15005



n = 8
Slope = 151.2
units per year.
Mann-Kendall
statistic = 16
critical = 20
Trend not sig-
nificant at 98%
confidence level
($\alpha = 0.01$ per
tail).

Constituent: Molybdenum, Total Analysis Run 12/17/2019 8:18 AM

Client: Consumers Energy Data: JHC_Sanitas_19.11.14

Summary Report

Constituent: Arsenic, Total Analysis Run 12/10/2019 6:47 AM
 Client: Consumers Energy Data: JHC_Sanitas_19.11.14

For observations made between 4/18/2017 and 10/9/2019, a summary of the selected data set:

Observations = 42
 ND/Trace = 2
 Wells = 6
 Minimum Value = 1
 Maximum Value = 129.5
 Mean Value = 18.03
 Median Value = 7.225
 Standard Deviation = 29.55
 Coefficient of Variation = 1.639
 Skewness = 2.664

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 8 | 1 | 1 | 12.7 | 4.45 | 3.1 | 3.864 | 0.8683 | 1.272 |
| JHC-MW-15002 | 8 | 0 | 33 | 129.5 | 66.93 | 53.5 | 39.06 | 0.5836 | 0.9476 |
| JHC-MW-15003 | 8 | 0 | 8.05 | 26 | 15.36 | 13.3 | 7.103 | 0.4625 | 0.41 |
| JHC-MW-15005 | 8 | 0 | 1.15 | 3.3 | 1.819 | 1.55 | 0.754 | 0.4146 | 1.005 |
| JHC-MW-18004 | 5 | 1 | 1 | 1.2 | 1.08 | 1.1 | 0.08367 | 0.07747 | 0.3436 |
| JHC-MW-18005 | 5 | 0 | 7.1 | 10.5 | 8.67 | 8.8 | 1.452 | 0.1675 | 0.06981 |

Summary Report

Constituent: Cobalt, Total Analysis Run 12/10/2019 6:47 AM
Client: Consumers Energy Data: JHC_Sanitas_19.11.14

For observations made between 4/18/2017 and 10/9/2019, a summary of the selected data set:

Observations = 42
ND/Trace = 40
Wells = 6
Minimum Value = 6
Maximum Value = 42
Mean Value = 11.56
Median Value = 15
Standard Deviation = 6.855
Coefficient of Variation = 0.5929
Skewness = 2.094

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 8 | 8 | 6 | 15 | 11.63 | 15 | 4.658 | 0.4007 | -0.5164 |
| JHC-MW-15002 | 8 | 8 | 6 | 15 | 11.63 | 15 | 4.658 | 0.4007 | -0.5164 |
| JHC-MW-15003 | 8 | 6 | 6 | 42 | 18.33 | 15 | 10.66 | 0.5817 | 1.432 |
| JHC-MW-15005 | 8 | 8 | 6 | 15 | 11.63 | 15 | 4.658 | 0.4007 | -0.5164 |
| JHC-MW-18004 | 5 | 5 | 6 | 6 | 6 | 6 | 0 | 0 | NaN |
| JHC-MW-18005 | 5 | 5 | 6 | 6 | 6 | 6 | 0 | 0 | NaN |

Summary Report

Constituent: Lithium, Total Analysis Run 12/10/2019 6:47 AM
Client: Consumers Energy Data: JHC_Sanitas_19.11.14

For observations made between 4/18/2017 and 10/9/2019, a summary of the selected data set:

Observations = 42
ND/Trace = 28
Wells = 6
Minimum Value = 10
Maximum Value = 240
Mean Value = 25.38
Median Value = 10
Standard Deviation = 38.98
Coefficient of Variation = 1.536
Skewness = 4.282

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 8 | 8 | 10 | 10 | 10 | 10 | 0 | 0 | NaN |
| JHC-MW-15002 | 8 | 2 | 10 | 240 | 60.13 | 23.5 | 79.2 | 1.317 | 1.657 |
| JHC-MW-15003 | 8 | 8 | 10 | 10 | 10 | 10 | 0 | 0 | NaN |
| JHC-MW-15005 | 8 | 0 | 28 | 61 | 40.63 | 38 | 10.23 | 0.2517 | 0.9932 |
| JHC-MW-18004 | 5 | 5 | 10 | 10 | 10 | 10 | 0 | 0 | NaN |
| JHC-MW-18005 | 5 | 5 | 10 | 10 | 10 | 10 | 0 | 0 | NaN |

Summary Report

Constituent: Molybdenum, Total Analysis Run 12/10/2019 6:47 AM
 Client: Consumers Energy Data: JHC_Sanitas_19.11.14

For observations made between 4/18/2017 and 10/9/2019, a summary of the selected data set:

Observations = 42
 ND/Trace = 8
 Wells = 6
 Minimum Value = 5
 Maximum Value = 885
 Mean Value = 54.21
 Median Value = 14.75
 Standard Deviation = 146.7
 Coefficient of Variation = 2.705
 Skewness = 4.754

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 8 | 7 | 5 | 13.3 | 6.038 | 5 | 2.934 | 0.486 | 2.268 |
| JHC-MW-15002 | 8 | 1 | 5 | 48 | 17.07 | 13.83 | 13.6 | 0.797 | 1.601 |
| JHC-MW-15003 | 8 | 0 | 19.3 | 120 | 44.5 | 29.1 | 34.74 | 0.7807 | 1.416 |
| JHC-MW-15005 | 8 | 0 | 10 | 885 | 195.7 | 24.6 | 308.2 | 1.574 | 1.589 |
| JHC-MW-18004 | 5 | 0 | 7.4 | 10 | 8.4 | 8.2 | 1.114 | 0.1326 | 0.4664 |
| JHC-MW-18005 | 5 | 0 | 14 | 66 | 25.59 | 15 | 22.66 | 0.8854 | 1.478 |

Summary Report

Constituent: Selenium, Total Analysis Run 12/10/2019 6:47 AM
 Client: Consumers Energy Data: JHC_Sanitas_19.11.14

For observations made between 4/18/2017 and 10/9/2019, a summary of the selected data set:

Observations = 42
 ND/Trace = 13
 Wells = 6
 Minimum Value = 1
 Maximum Value = 368
 Mean Value = 29.03
 Median Value = 5.875
 Standard Deviation = 65.4
 Coefficient of Variation = 2.253
 Skewness = 3.814

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 8 | 8 | 1 | 1 | 1 | 1 | 0 | 0 | NaN |
| JHC-MW-15002 | 8 | 4 | 1 | 7.55 | 2.813 | 1.825 | 2.367 | 0.8418 | 1.007 |
| JHC-MW-15003 | 8 | 1 | 1 | 28.6 | 7.719 | 2.95 | 10.2 | 1.321 | 1.346 |
| JHC-MW-15005 | 8 | 0 | 10 | 368 | 97.78 | 40.85 | 123.8 | 1.266 | 1.417 |
| JHC-MW-18004 | 5 | 0 | 7.3 | 39 | 20.66 | 12 | 14.29 | 0.6918 | 0.4178 |
| JHC-MW-18005 | 5 | 0 | 11 | 140 | 48.29 | 34.5 | 52.69 | 1.091 | 1.305 |

Summary Report

Constituent: Thallium, Total Analysis Run 12/10/2019 6:47 AM
Client: Consumers Energy Data: JHC_Sanitas_19.11.14


For observations made between 4/18/2017 and 10/9/2019, a summary of the selected data set:

Observations = 42
ND/Trace = 38
Wells = 6
Minimum Value = 2
Maximum Value = 5.8
Mean Value = 2.114
Median Value = 2
Standard Deviation = 0.599
Coefficient of Variation = 0.2833
Skewness = 5.8

| <u>Well</u> | <u>#Obs.</u> | <u>ND/Trace</u> | <u>Min</u> | <u>Max</u> | <u>Mean</u> | <u>Median</u> | <u>Std.Dev.</u> | <u>CV</u> | <u>Skewness</u> |
|--------------|--------------|-----------------|------------|------------|-------------|---------------|-----------------|-----------|-----------------|
| JHC-MW-15001 | 8 | 8 | 2 | 2 | 2 | 2 | 0 | 0 | NaN |
| JHC-MW-15002 | 8 | 8 | 2 | 2 | 2 | 2 | 0 | 0 | NaN |
| JHC-MW-15003 | 8 | 8 | 2 | 2 | 2 | 2 | 0 | 0 | NaN |
| JHC-MW-15005 | 8 | 4 | 2 | 5.8 | 2.6 | 2 | 1.33 | 0.5115 | 2.051 |
| JHC-MW-18004 | 5 | 5 | 2 | 2 | 2 | 2 | 0 | 0 | NaN |
| JHC-MW-18005 | 5 | 5 | 2 | 2 | 2 | 2 | 0 | 0 | NaN |

Parametric Confidence Interval

Compliance limit is exceeded.* Per-well alpha = 0.01. Normality Test: Shapiro Wilk, alpha based on n.



Constituent: Arsenic, Total Analysis Run 12/10/2019 5:33 PM

Client: Consumers Energy Data: JHC_Sanitas_19.11.14

Confidence Interval


Constituent: Arsenic, Total (ug/L) Analysis Run 12/10/2019 5:35 PM

Client: Consumers Energy Data: JHC_Sanitas_19.11.14

| | JHC-MW-15001 | JHC-MW-15002 | JHC-MW-15003 | JHC-MW-18005 |
|------------|--------------|--------------|--------------|--------------|
| 11/15/2016 | 3 | 46 | 36 | |
| 6/20/2017 | 1.8 | 33.8 (D) | 20.4 | |
| 8/14/2017 | 2.2 | 45.15 (D) | 23.7 | |
| 4/25/2018 | <1 | 129.5 (D) | 12.4 | |
| 6/18/2018 | 1.8 | | 14.2 (D) | |
| 6/19/2018 | | 127 | | |
| 11/13/2018 | 12.7 | | | |
| 11/15/2018 | | 60 (D) | 8.1 | |
| 12/7/2018 | | | | 9.6 (D) |
| 2/28/2019 | | | | 10.5 (D) |
| 4/25/2019 | 5.8 | 50 | | 8.8 |
| 4/29/2019 | | | 10 | |
| 8/13/2019 | | | | 7.35 (D) |
| 10/9/2019 | 6.3 | 57 | 8.05 (D) | 7.1 |
| Mean | 4.263 | 68.56 | 16.61 | 8.67 |
| Std. Dev. | 3.961 | 37.69 | 9.662 | 1.452 |
| Upper Lim. | 8.053 | 102.7 | 26.85 | 11.1 |
| Lower Lim. | 0.8725 | 36.5 | 6.365 | 6.236 |

Non-Parametric Confidence Interval

Compliance Limit is not exceeded.



Constituent: Cobalt, Total Analysis Run 12/17/2019 8:24 AM

Client: Consumers Energy Data: JHC_Sanitas_19.11.14

Confidence Interval

Constituent: Cobalt, Total (ug/L) Analysis Run 12/17/2019 8:25 AM


Client: Consumers Energy Data: JHC_Sanitas_19.11.14

JHC-MW-15003

| | |
|------------|---------|
| 4/18/2017 | <15 |
| 6/20/2017 | <15 |
| 8/14/2017 | <15 |
| 4/25/2018 | <15 |
| 6/18/2018 | <15 (D) |
| 11/15/2018 | 23.6 |
| 4/29/2019 | <6 |
| 10/9/2019 | 42 (D) |
| Mean | 18.33 |
| Std. Dev. | 10.66 |
| Upper Lim. | 42 |
| Lower Lim. | 6 |

Parametric Confidence Interval

Compliance Limit is not exceeded. Per-well alpha = 0.01. Normality Test: Shapiro Wilk, alpha based on n.



Constituent: Lithium, Total Analysis Run 12/10/2019 5:36 PM

Client: Consumers Energy Data: JHC_Sanitas_19.11.14

Confidence Interval


Constituent: Lithium, Total (ug/L) Analysis Run 12/10/2019 5:37 PM

Client: Consumers Energy Data: JHC_Sanitas_19.11.14

| | JHC-MW-15002 | JHC-MW-15005 |
|------------|--------------|--------------|
| 11/15/2016 | 11 | 49 |
| 6/20/2017 | <10 (D) | 39 |
| 8/14/2017 | 8 (D) | 36 |
| 4/25/2018 | 28 (D) | 61 |
| 6/19/2018 | 19 | 35 |
| 11/15/2018 | 67.5 (D) | 28 |
| 4/25/2019 | 96 | 38 (D) |
| 10/9/2019 | 240 | 50 |
| Mean | 59.31 | 42 |
| Std. Dev. | 79.81 | 10.56 |
| Upper Lim. | 126 | 53.19 |
| Lower Lim. | 2.756 | 30.81 |

Parametric and Non-Parametric (NP) Confidence Interval

Compliance Limit is not exceeded. Per-well alpha = 0.01 except as noted. Normality Test: Shapiro Wilk, alpha based on n.



Constituent: Molybdenum, Total Analysis Run 12/10/2019 5:37 PM

Client: Consumers Energy Data: JHC_Sanitas_19.11.14

Confidence Interval


Constituent: Molybdenum, Total (ug/L) Analysis Run 12/10/2019 5:38 PM

Client: Consumers Energy Data: JHC_Sanitas_19.11.14

| | JHC-MW-15003 | JHC-MW-15005 |
|------------|--------------|--------------|
| 11/15/2016 | 24 | 15 |
| 6/20/2017 | 21.1 | 14 |
| 8/14/2017 | 28.2 | 10 |
| 4/25/2018 | 19.3 | 31.2 |
| 6/18/2018 | 52.1 (D) | |
| 6/19/2018 | | 15.7 |
| 11/15/2018 | 65.3 | 222 |
| 4/25/2019 | | 885 (D) |
| 4/29/2019 | 20 | |
| 10/9/2019 | 120 (D) | 370 |
| Mean | 43.75 | 195.4 |
| Std. Dev. | 35.16 | 308.4 |
| Upper Lim. | 71.48 | 885 |
| Lower Lim. | 17.13 | 10 |

Parametric Confidence Interval

Compliance Limit is not exceeded. Per-well alpha = 0.01. Normality Test: Shapiro Wilk, alpha based on n.



Constituent: Selenium, Total Analysis Run 12/10/2019 5:39 PM

Client: Consumers Energy Data: JHC_Sanitas_19.11.14

Confidence Interval


Constituent: Selenium, Total (ug/L) Analysis Run 12/10/2019 5:39 PM

Client: Consumers Energy Data: JHC_Sanitas_19.11.14

| | JHC-MW-15005 | JHC-MW-18005 |
|------------|--------------|--------------|
| 11/15/2016 | 165 | |
| 6/20/2017 | 15.5 | |
| 8/14/2017 | 15.7 | |
| 4/25/2018 | 368 | |
| 6/19/2018 | 14 | |
| 11/15/2018 | 158 | |
| 12/7/2018 | | 39.95 (D) |
| 2/28/2019 | | 34.5 (D) |
| 4/25/2019 | 135 (D) | 16 |
| 8/13/2019 | | 11 (D) |
| 10/9/2019 | 66 | 140 |
| Mean | 117.2 | 48.29 |
| Std. Dev. | 120.2 | 52.69 |
| Upper Lim. | 236.5 | 141.3 |
| Lower Lim. | 13.08 | 0.4224 |

Parametric Confidence Interval

Compliance Limit is not exceeded. Per-well alpha = 0.01. Normality Test: Shapiro Wilk, alpha based on n.



Constituent: Thallium, Total Analysis Run 12/10/2019 5:45 PM

Client: Consumers Energy Data: JHC_Sanitas_19.11.14

Confidence Interval

Constituent: Thallium, Total (ug/L) Analysis Run 12/10/2019 5:45 PM

Client: Consumers Energy Data: JHC_Sanitas_19.11.14

JHC-MW-15005

| | |
|------------|---------|
| 11/15/2016 | 4 |
| 6/20/2017 | <2 |
| 8/14/2017 | <2 |
| 4/25/2018 | 5.8 |
| 6/19/2018 | 2.1 |
| 11/15/2018 | <2 |
| 4/25/2019 | 1.5 (D) |
| 10/9/2019 | 2.9 |
| Mean | 2.413 |
| Std. Dev. | 1.738 |
| Upper Lim. | 4 |
| Lower Lim. | 1.243 |


Appendix H

ACM Extension Certification

A CMS Energy Company

Date: July 12, 2019

To: Operating Record


From: Harold D. Register, Jr., P.E. 

RE: Demonstration for 60-Day Extension for Assessment of Corrective Measures
Professional Engineer Certification
JH Campbell Unit 1&2 Bottom Ash Pond and JH Campbell Pond A

Professional Engineer Certification Statement [§257.96(a)]

Consumers Energy has determined that the analysis of the effectiveness of potential corrective measures in meeting all of the requirements and objectives of a selected remedy described in §257.97 cannot be achieved within the 90-day timeline to complete the Assessment of Corrective Measures for JH Campbell Unit 1&2 Bottom Ash Pond and JH Campbell Pond A due to site-specific conditions that are changing based on initiating closure activities. Notification was made September 7, 2018 and September 17, 2018 for JH Campbell Unit 1&2 Bottom Ash Pond and JH Campbell Pond A, respectively, that closure activities had been initiated. Groundwater monitoring data collected to date indicates changing conditions that can influence factors that must be considered in the assessment, including source evaluation, plume delineation, groundwater assessment, and source control. The final published rule allows for a single 60 day extension based on site-specific conditions or circumstances.

I hereby attest that, having reviewed the detection and assessment monitoring documentation and being familiar with the provisions of Title 40 of the Code of Federal Regulations §257.96, that the demonstration justifying a 60-day time extension to the 90-day completion period of the Assessment of Corrective Measures is accurate for JH Campbell Unit 1&2 Bottom Ash Pond and JH Campbell Pond A in accordance with the requirements of §257.96(a). This will now set the deadline for completing the Assessment of Corrective Measures for September 11, 2019.



Signature

July 12, 2019

Date of Certification

Harold D. Register, Jr., P.E.

Name

6201056266

Professional Engineer Certification Number



07/12/2019

Appendix I

Semiannual Progress Report


January 30th, 2020

Subject:


Initial Semiannual Progress Report - Selection of Final Remedy
JH Campbell Bottom Ash Ponds 1-2 CCR Unit
JH Campbell Pond A CCR Unit

This Semiannual Progress Report, prepared as a requirement of §257.97(a) of the CCR Rule, describes progress toward selecting and designing the final remedy for two CCR units that triggered Assessment of Corrective Measures (ACM) under the CCR Rule at the JH Campbell Solid Waste Disposal Area: Bottom Ash Ponds 1-2 and Pond A. Based on the schedule of self-implementation prescribed in the CCR Rule, a progress report is required to be prepared semiannually upon completion of the Assessment of Corrective Measures Report until the final remedy is selected. It is noteworthy that assessment of corrective measures for the Bottom Ash Ponds 1-2 and Pond A prescribed by the CCR Rule is being undertaken in coordination with a Michigan Department of Environment, Great Lakes, and Energy (EGLE) Consent Agreement 115-01-2018, which was executed on December 28, 2018 to address sitewide corrective actions. Corrective actions for a portion of the ash management area were previously implemented under an Agreement for a Limited Site-Specific, Criteria Based Remedial Action Plan (RAP-LANDUSE-WHMD-2005-02) that was originally executed on July 31, 2005.

As presented in the key milestones timelines below, a groundwater monitoring system was installed for the CCR units and background monitoring commenced in December 2015 under the CCR Rule self-implementing requirements and schedule. The results from this groundwater monitoring program have been reviewed and coordinated with results from the groundwater monitoring program implemented under the existing state requirements for groundwater monitoring and corrective actions. Consumers Energy first reported the potential for statistically significant increases (SSIs) for Appendix IV constituents from the groundwater monitoring system certified under 257.91 (reference) in the "Notification of Appendix IV Constituent Exceeding Groundwater Protection Standard per §257.95(g)" (Consumers Energy Company, January 2019). Subsequently, Assessment of Corrective Measures Reports (TRC, September 2019) were completed on September 11, 2019 for both units.



Key Milestones – Ponds 1-2



Key Milestones – Pond A

Results of 2019 Semi-Annual Sampling Events

Statistical analysis from semiannual groundwater monitoring verified that the only constituent of concern that triggered a statistically significant increase (SSI) and exceeds the established

Groundwater Protection Standard (GWPS) is arsenic. Groundwater monitoring results and statistical evaluations are presented in the appropriate annual groundwater monitoring reports to which this document has been appended.

Progress Towards Remedy Selection

Consumers Energy has not selected a remedy pursuant to §257.97 and R 444 of Part 115 for Ponds 1-2 or for Pond A. However, certain source control measures have been implemented, as detailed below:

Ponds 1-2

Consumers Energy has performed CCR removal at Ponds 1-2 as documented in the “*JH Campbell Generating Facility Bottom Ash Ponds 1-2 Closure Plan*,” (Golder, January 2018). Ponds 1-2 is undergoing closure by removal of CCR in accordance with §257.102(c). Following the cessation of hydraulic loading and the cease of receipt of CCR and non-CCR waste streams, CCR removal activities were completed in October 2018 and Consumers Energy submitted final documentation of CCR removal to the EGLE in August 2019 (Golder, 2019). On October 22, 2019 EGLE provided written concurrence that all bottom ash had been removed from Ponds 1-2 based on multiple lines of evidence described in the approved closure work plan.

Pond A

Pursuant to §257.102, Consumers Energy prepared the “*JH Campbell Generating Facility Pond A Closure Plan, West Olive, Michigan*” (Golder, October 2016) and an updated closure plan detailing the final cover system that was submitted to EGLE in February 2019. Following the cessation of hydraulic loading and the cease of receipt of CCR and non-CCR waste streams, Pond A has undergone closure in place in accordance with the requirements for CCR landfills under RCRA (§257.102(d)) and a RCRA closure certification by the qualified professional engineer is in development. The state closure certification as required by Paragraph 4.2 of Consent Agreement WMRPD No. 115-01-2018 was approved by EGLE on November 25, 2019.

Source Control Impacts

It is expected that the cessation of hydraulic loading and other subsequent source control measures will change groundwater conditions with the potential to affect concentrations of Appendix III and Appendix IV constituents in the groundwater. Consumers Energy will continue to execute the self-implementing groundwater compliance schedule in conformance with §257.90 - §257.98, which includes semiannual assessment monitoring in accordance with §257.95 to monitor site groundwater conditions and inform remedy selection.

On March 18, 2019, Consumers Energy submitted the *Pond A Hydrogeological Monitoring Plan, JH Campbell Power Plant, West Olive, Michigan* (Pond A HMP) (TRC, March 2019; Revised July 2019), which includes the *Pond A Assessment Monitoring Plan* (Pond A AMP), to EGLE to comply with the requirements of Part 115, Rule 299.4905. The Pond A HMP and Pond A AMP were implemented during the fourth quarter of 2019. In addition, quarterly monitoring according to the site's EGLE-approved September 1996 *Hydrogeological Monitoring Plan (HMP) for JH Campbell Ash Storage Facility, Consumers Power Company, Solid Waste Disposal Area, Coal Ash, Type III* for the site continued to be implemented in the fourth quarter of 2019. State and federal monitoring and reporting requirements are being coordinated through the referenced documents.

State of Michigan Agreement

On December 21, 2018 Consumers Energy and the Michigan Department of Environmental Quality (now EGLE) signed WMRPD Agreement No. 115-01-2018 (Agreement). Per paragraph 4.5 of the Agreement, Consumers Energy agreed to submit a revised Remedial Action Plan (RAP) for the site by October 1, 2021. The revised RAP must address all existing-identified corrective actions related to the historic and ongoing management of CCR at the site in conformance with Michigan Part 115 Rules, the approved site Hydrogeological Monitoring Plan, and corrective actions in conformance with groundwater monitoring activities Consumers Energy is performing in accordance with the CCR Rule. The revised RAP is anticipated to comprehensively address groundwater monitoring and corrective action requirements in anticipation of documenting compliance with a state or federal permit program.

Remedy Selection Process

The ACM Report identified five technically feasible groundwater management alternatives to address residual arsenic. In conjunction with the work described in the ACM Report, Consumers Energy is developing a feasibility study to inform the development of the updated RAP for 2021. Additional data collected under the state and federal groundwater monitoring programs will be used to inform remedy selection and the creation of the updated RAP.

The final remedy for Ponds 1-2 and Pond A will be formally selected per §257.97 once the selected option is reviewed and commented on by EGLE and a public meeting is conducted at least 30-days prior to the final selection as required under §257.96(e).

References

- Consumers Energy Company. January 14, 2019. Notification of Appendix IV Constituent Exceeding Groundwater Protection Standard per §257.95(g), JH Campbell Pond A CCR Unit.
- Consumers Energy Company. January 14, 2019. Notification of Appendix IV Constituent Exceeding Groundwater Protection Standard per §257.95(g), JH Campbell Ponds 1-2 CCR Unit.
- Consumers Power Company. September 1996. Hydrogeological Monitoring Plan for JH Campbell Ash Storage Facility, Consumers Power Company, Solid Waste Disposal Area, Coal Ash, Type III
- Golder Associates. October 2016. JH Campbell Generating Facility Pond A Closure Plan, West Olive, Michigan. Prepared for Consumers Energy Company.
- Golder Associates. January 2018. JH Campbell Generating Facility Bottom Ash Ponds 1-2 Closure Plan, West Olive, Michigan. Prepared for Consumers Energy Company.
- Golder Associates. August 9, 2019. JH Campbell Generating Facility Bottom Ash Ponds 1-2 N/S CCR Removal Documentation Report. Prepared for Consumers Energy Company.
- TRC Environmental Corporation. September 2019. Assessment of Corrective Measures, Consumers Energy Company JH Campbell Ponds 1-2 North and 1-2 South and Pond A Coal Combustion Residual Units. Prepared for Consumers Energy Company.
- TRC Environmental Corporation. March 2019; Revised July 2019. Pond A Hydrogeological Monitoring Plan, JH Campbell Power Plant, West Olive, Michigan. Prepared for Consumers Energy Company