



# Inflow Design Flood Control System Plan

## D.E. KARN GENERATING FACILITY

## BOTTOM ASH POND INFLOW DESIGN FLOOD CONTROL SYSTEM PLAN

Essexville, Michigan

Pursuant to 40 CFR 257.82

**Submitted To:** Consumers Energy Company  
1945 W. Parnall Road  
Jackson, Michigan 49201

**Submitted By:** Golder Associates Inc.  
15851 South US 27, Suite 50  
Lansing, Michigan 48906

October 2016

1655284





**CERTIFICATION**

**Professional Engineer Certification Statement [40 CFR 257.82(c)]**

I hereby certify that, having reviewed the attached documentation and being familiar with the provisions of Title 40 of the Code of Federal Regulations Section 257.82 (40 CFR Part 257.82), I attest that this Inflow Design Flood Control System Plan is accurate and has been prepared in accordance with good engineering practices, including the consideration of applicable industry standards, and with the requirements of 40 CFR Part 257.82.


Golder Associates Inc.

  
\_\_\_\_\_  
Signature

October 14, 2016  
\_\_\_\_\_  
Date of Report Certification

John D. Puls, PE  
\_\_\_\_\_  
Name

6201055787  
\_\_\_\_\_  
Professional Engineer Certification Number





## Table of Contents

CERTIFICATION..... C-1  
Professional Engineer Certification Statement [40 CFR 257.82(c)]..... C-1

1.0 INTRODUCTION..... 1  
1.1 Background ..... 1  
1.2 Purpose ..... 1

2.0 FLOOD CONTROL SYSTEM ..... 2  
2.1 External Floodwater Protection ..... 2  
2.2 Internal Flood Control..... 2

3.0 PLAN REVISION AND RECORDKEEPING ..... 4

4.0 REFERENCES..... 5

### List of Tables

Table 2.2.1 Discharge Structure Summary  
Table 2.2.2 Storm Flow Data

### List of Figures

Figure 1 Site Location Map  
Figure 2 Site Plan

### List of Appendices

Appendix A FEMA Flood Elevation and Lake Huron Normal Elevation  
Appendix B Rainfall Data  
Appendix C Hydrologic and Hydraulic Model Output



## 1.0 INTRODUCTION

### 1.1 Background

D.E. Karn Generating Facility (DE Karn) is a coal-fired power generation facility located near Essexville, Michigan as presented on Figure 1 – Site Location Map. Bottom ash is sluiced from the DE Karn Unit 1&2 electrical generating units to the Bottom Ash Pond. An elevated trestle and pipe system hydraulically conveys bottom ash to the pond system. Stored bottom ash is removed via mechanical equipment from the ponds as required to maintain storage capacity on a yearly basis. Water is discharged from the ponds via one 24-inch diameter steel pipe into an internal ditch that conveys the flow to the permitted National Pollutant Discharge Elimination System (NPDES) outfall as provided on Figure 2 - Site Plan.

### 1.2 Purpose

The purpose of the Inflow Design Flood Control System Plan (Plan) is to provide a basis for the certification required by 40 CFR 257.82 Hydrologic and Hydraulic Capacity Requirements for Coal Combustion Residual (CCR) Surface Impoundments. The Bottom Ash Pond has been rated a low hazard potential as determined under 40 CFR 257.73(a)(2). 40 CFR 257.82(a) requires the owner or operator of the low hazard potential CCR surface impoundment to design, construct, operate, and maintain an inflow design flood control system as follows:

- Adequately manage the flow into the CCR unit during and following the peak discharge of the inflow of the 100-year flood event
- Adequately manage the flow from the CCR unit to collect and control the peak discharge resulting from the 100-year flood event
- Handle discharge from the CCR unit in accordance with the surface water requirements under 40 CFR 257.3-3



## 2.0 FLOOD CONTROL SYSTEM

To meet the requirements of 40 CFR 257.82(a), the flood control system must provide flood protection to the CCR unit during the inflow design flood (100-year event) for two cases: 1) floodwater from outside the unit from the Saginaw River and from Saginaw Bay, and 2) controlling internal water levels within the unit.

### 2.1 External Floodwater Protection

The Bottom Ash Pond is surrounded by a perimeter berm that provides external flood water protection. Based on borings completed in 2016, the berm is generally constructed of sand and CCR.

A publicly available 100-year flood elevation for Saginaw Bay has been determined by Federal Emergency Management Agency (FEMA). Based on FEMA Firm Map Numbers 26017C0239E, both Saginaw River and Saginaw Bay have 100-year flood elevations of 585.00 feet (NAVD88) as provided in Appendix A – FEMA Flood Elevation and Lake Huron Normal Elevation. The lowest elevation along the perimeter berm is 598.17 feet (NAVD88), which allows for 13.17 feet of freeboard during the 100-year flood event. Therefore, the Saginaw Bay and Saginaw River should not to be an inflow source to the Bottom Ash Pond.

### 2.2 Internal Flood Control

The only inflow other than process water will be precipitation directly falling on the Bottom Ash Pond and surrounding drainage areas from a 100-year 24-hour storm event of 5.99 inches, as provided in Appendix B - Rainfall Data. The discharge structure in the perimeter berm includes one 24-inch steel pipe. Table 2.2.1 below provides a summary of the outflow structures as surveyed in June 2016.

**Table 2.2.1 - Discharge Structure Summary**

Discharge Structure	Type	Size (Inches)	Length (Feet)	Upstream Invert (NAVD88)	Downstream Invert (NAVD88)	Slope (%)
Bottom Ash Pond	Steel	24	60	591.60	591.00	1.00

Table 2.2.2 below provides a storm flow summary that indicates that the Bottom Ash Pond is contained with 4.20 feet of freeboard and a peak discharge rate of 17.07 cubic feet per second (cfs) during the design storm event (100-year 24-hour). The modeled results indicate that:

- The inflow design flood control system adequately manages flow from the CCR unit to collect and control the peak discharge resulting from the inflow design flood (100-year 24-hour storm event)

The hydrologic and hydraulic model output is provided in Appendix C - Hydrologic and Hydraulic Model Output. It should be noted that the pond elevations presented in Table 2.2.2 were used to assess the maximum storage pool loading condition pursuant to 40 CFR 257.73(e)(1)(i).



**Table 2.2.2 – Storm Flow Data**

<b>Area</b>	<b>Perimeter Berm Elevation (NAVD 88)</b>	<b>Pond Elevation 100-year,24-hour (NAVD 88)</b>	<b>Peak Outflow (cfs)</b>
Bottom Ash Pond	598.17	593.97	17.07



### 3.0 PLAN REVISION AND RECORDKEEPING

Per 40 CFR 257.82(c)(2); “The owner or operator of the CCR unit may amend the written inflow design flood control system plan at any time provided the revised plan is placed in the facility's operating record as required by Section 257.105(g)(4). The owner or operator must amend the written inflow design flood control system plan whenever there is a change in conditions that would substantially affect the written plan in effect.”

Per 40 CFR 257.82(c)(4); “The owner or operator must prepare periodic inflow design flood control system plans required by paragraph (c)(1) of this section every five years. The date of completing the initial plan is the basis for establishing the deadline to complete the first periodic plan. The owner or operator may complete any required plan prior to the required deadline provided the owner or operator places the completed plan into the facility's operating record within a reasonable amount of time. In all cases, the deadline for completing a subsequent plan is based on the date of completing the previous plan. For purposes of this paragraph (c)(4), the owner or operator has completed an inflow design flood control system plan when the plan has been placed in the facility's operating record as required by Section 257.105(g)(4).”



## 4.0 REFERENCES

FEMA (Federal Emergency Management Agency). 2010. Flood Insurance Study, Bay County, Michigan. Effective September 17, 2010. Flood Insurance Study Number 26017CV000A.

USEPA (US Environmental Protection Agency). 2015. Disposal of Coal Combustion Residuals from Electric Utilities; Final Rule. 40 CFR Part 257. Effective Date October 19, 2015.



## FIGURES



Channel Island

Windy Point

Gull Island

SITE LOCATION

CHESTNUT ST

Saginaw

WEADOCK HWY

JTELL RD

NES RD

TACEY RD




SITE LOCATION

MICHIGAN COUNTIES  
NOT TO SCALE

**REFERENCE(S)**

BASE MAP TAKEN FROM USGS 7.5 MINUTE QUADRANGLE  
BAY CITY NE, MICHIGAN  
DATED 2014



CLIENT  
**CONSUMERS ENERGY COMPANY**  
2742 NORTH WEADOCK HIGHWAY  
ESSEXVILLE, MI. 48732

PROJECT  
**D.E. KARN UNITS #1 AND #2**  
BOTTOM ASH POND

CONSULTANT	YYYY-MM-DD	2016-08-22
	DESIGNED	MAL
	PREPARED	MAL
	REVIEWED	JRP
	APPROVED	MAB




TITLE  
**SITE LOCATION MAP**

PROJECT NO.  
**1655284**

REV.  
**0**

FIGURE  
**1**



**SURVEY NOTES**  
 1. THIS DRAWING REPRESENTS THE SITE CONDITIONS AS SURVEYED ON MAY 23-25, 2016.  
 2. OVERHEAD LINES ARE APPROXIMATE ONLY.

**BASIS OF BEARING**  
 MICHIGAN STATE PLANE COORDINATE SYSTEM, SOUTH ZONE  
 NORTH AMERICAN DATUM 1983,  
 1994 ADJUSTMENT - NAD83 (94) SITE  
 COMBINED SCALE FACTOR = 0.99996843

**BASIS OF ELEVATION**  
 NORTH AMERICAN VERTICAL DATUM OF 1988 - NAVD88  
 1' CONTOUR INTERVAL

\*SEE DATUM NOTES\*

**DATUM NOTES**  
 THE VERTICAL DATUM FOR THIS SURVEY IS NAVD88. "EXTREME" CAUTION SHOULD BE TAKEN WHEN COMPARING THE ELEVATIONS ON THIS DRAWING TO OTHER RECORD DRAWINGS, BOTH SURVEY AND PLANT. IT IS IMPERATIVE THAT THE USER RECOGNIZE THAT DIFFERENT DATUMS HAVE BEEN USED AT THIS SITE. SEE CONVERSIONS AND DEFINITIONS BELOW.

MSPC = MICHIGAN STATE PLANE COORDINATE SYSTEM, NAD83(1994), SOUTH ZONE, INTERNATIONAL FEET.  
 PLANT = ORIGINAL PLANT DATUM AT TIME OF CONSTRUCTION. GROUND COORDINATES REPORTED IN FEET.  
 WP = WORLEY PARSONS DATUM USED FOR THE BAG HOUSE CONSTRUCTION PROJECT STARTING IN 2007. GROUND COORDINATES REPORTED IN FEET.

\*NAVD88 = NORTH AMERICAN VERTICAL DATUM OF 1988  
 \*NGVD29 = NATIONAL GEODETIC VERTICAL DATUM OF 1929  
 \*USLS = UNITED STATE LAKE SURVEY 1935  
 \*IGLD55 = INTERNATIONAL GREAT LAKES DATUM 1955 ADJUSTMENT  
 \*IGLD85 = INTERNATIONAL GREAT LAKES DATUM 1985 ADJUSTMENT  
 \*REPORTED IN UNITS OF FEET.

**CONVERSIONS**  
 NAVD88 TO USLS = +0.92'  
 NAVD88 TO IGLD85 = -0.11'  
 USLS TO IGLD55 = -1.754'  
 USLS TO NGVD29 = -0.297'  
 IGLD55 TO IGLD85 = +0.72'

NOTE: THE CONVERSIONS TO USLS AND TO IGLD DATUMS ONLY APPLY TO THE IMMEDIATE AREA AT THE KARN PLANT AND SHOULD NOT BE USED ELSEWHERE.

**LEGEND**

INCLINOMETER	GAS VALVE	GRAVEL SURFACE / TRAVELED PATHWAY	OVERHEAD ELECTRIC LINE
MONITORING WELL	LIGHT POLE	ASPHALT SURFACE	ABOVE GROUND GAS LINE
OBSERVATION WELL	POWER POLE	CONCRETE SURFACE	UNDERGROUND STORM LINE
PIEZOMETER	POST (WOOD/METAL)		TOP OF BANK
ELECTRIC BOX			TOE OF SLOPE
CATCH BASIN			

CLIENT  
 CONSUMERS ENERGY COMPANY  
 2742 NORTH WEADOCK HIGHWAY  
 ESSEXVILLE, MI. 48732

CONSULTANT

DESIGNED	2016-07-01
PREPARED	MMJ
REVIEWED	MAL
APPROVED	JRP
	JDP



PROJECT  
 D.E. KARN BOTTOM ASH POND

TITLE  
 SITE PLAN

PROJECT NO.	REV.	FIGURE
1655284	----	2

Path: \\usconmem01\share\Share\Work for Other Offices\1655284\_DE Karn Bottom Ash Pond\CIVIL\_3D\1 File Name: 1655284\_2016-06\_Survey.dwg

1 in IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM ANSI B

**APPENDIX A**  
**FEMA FLOOD ELEVATION AND LAKE HURON NORMAL ELEVATION**



**APPENDIX B  
RAINFALL DATA**



**NOAA Atlas 14, Volume 8, Version 2**  
**Location name: Essexville, Michigan, US\***  
**Latitude: 43.6433°, Longitude: -83.8376°**  
**Elevation: 585 ft\***  
 \* source: Google Maps



**POINT PRECIPITATION FREQUENCY ESTIMATES**

Sanja Perica, Deborah Martin, Sandra Pavlovic, Ishani Roy, Michael St. Laurent, Carl Trypaluk, Dale Unruh, Michael Yekta, Geoffrey Bonnin

NOAA, National Weather Service, Silver Spring, Maryland

[PF tabular](#) | [PF graphical](#) | [Maps & aerials](#)



**PF tabular**

<b>PDS-based point precipitation frequency estimates with 90% confidence intervals (in inches)<sup>1</sup></b>										
Duration	Average recurrence interval (years)									
	1	2	5	10	25	50	100	200	500	1000
5-min	0.281 (0.221-0.364)	0.333 (0.262-0.432)	0.421 (0.331-0.548)	0.497 (0.388-0.651)	0.606 (0.458-0.829)	0.693 (0.510-0.963)	0.783 (0.556-1.12)	0.877 (0.595-1.30)	1.01 (0.655-1.54)	1.11 (0.700-1.72)
10-min	0.411 (0.324-0.533)	0.487 (0.384-0.632)	0.617 (0.484-0.803)	0.728 (0.568-0.953)	0.887 (0.670-1.21)	1.02 (0.747-1.41)	1.15 (0.814-1.64)	1.28 (0.872-1.90)	1.47 (0.959-2.25)	1.62 (1.03-2.52)
15-min	0.501 (0.396-0.649)	0.594 (0.469-0.771)	0.752 (0.591-0.979)	0.888 (0.693-1.16)	1.08 (0.817-1.48)	1.24 (0.911-1.72)	1.40 (0.992-2.00)	1.57 (1.06-2.32)	1.80 (1.17-2.75)	1.98 (1.25-3.07)
30-min	0.722 (0.570-0.936)	0.859 (0.678-1.12)	1.09 (0.856-1.42)	1.29 (1.01-1.69)	1.57 (1.19-2.15)	1.80 (1.32-2.49)	2.03 (1.44-2.90)	2.27 (1.54-3.35)	2.60 (1.69-3.97)	2.86 (1.81-4.44)
60-min	0.940 (0.742-1.22)	1.11 (0.877-1.44)	1.41 (1.11-1.84)	1.67 (1.31-2.19)	2.05 (1.56-2.82)	2.37 (1.74-3.30)	2.69 (1.91-3.87)	3.04 (2.07-4.51)	3.52 (2.30-5.40)	3.91 (2.47-6.07)
2-hr	1.16 (0.925-1.48)	1.36 (1.09-1.75)	1.73 (1.38-2.22)	2.05 (1.62-2.65)	2.54 (1.95-3.45)	2.94 (2.19-4.05)	3.36 (2.42-4.78)	3.81 (2.62-5.60)	4.45 (2.94-6.76)	4.96 (3.17-7.63)
3-hr	1.29 (1.04-1.63)	1.51 (1.21-1.91)	1.90 (1.52-2.42)	2.26 (1.80-2.90)	2.81 (2.18-3.81)	3.28 (2.47-4.51)	3.78 (2.74-5.36)	4.33 (3.00-6.33)	5.10 (3.39-7.72)	5.73 (3.69-8.77)
6-hr	1.52 (1.24-1.90)	1.75 (1.43-2.20)	2.19 (1.78-2.75)	2.61 (2.11-3.30)	3.28 (2.59-4.42)	3.86 (2.95-5.27)	4.50 (3.31-6.33)	5.21 (3.66-7.57)	6.24 (4.20-9.37)	7.09 (4.61-10.7)
12-hr	1.78 (1.47-2.20)	2.02 (1.67-2.50)	2.50 (2.06-3.10)	2.98 (2.43-3.71)	3.75 (3.01-5.02)	4.44 (3.45-6.02)	5.22 (3.89-7.28)	6.09 (4.34-8.78)	7.36 (5.02-11.0)	8.43 (5.54-12.6)
24-hr	2.05 (1.71-2.49)	2.31 (1.93-2.81)	2.85 (2.37-3.48)	3.40 (2.81-4.17)	4.29 (3.49-5.67)	5.09 (4.00-6.81)	5.99 (4.53-8.27)	7.01 (5.05-10.0)	8.51 (5.87-12.6)	9.77 (6.49-14.5)
2-day	2.33 (1.97-2.78)	2.64 (2.23-3.16)	3.25 (2.74-3.91)	3.87 (3.25-4.69)	4.88 (4.02-6.37)	5.79 (4.61-7.64)	6.80 (5.20-9.26)	7.94 (5.79-11.2)	9.62 (6.70-14.0)	11.0 (7.39-16.2)
3-day	2.55 (2.17-3.02)	2.86 (2.44-3.40)	3.50 (2.97-4.17)	4.14 (3.49-4.96)	5.18 (4.29-6.69)	6.11 (4.90-7.99)	7.15 (5.50-9.66)	8.32 (6.11-11.7)	10.1 (7.05-14.6)	11.5 (7.76-16.8)
4-day	2.74 (2.35-3.23)	3.06 (2.63-3.61)	3.70 (3.16-4.39)	4.35 (3.69-5.18)	5.39 (4.49-6.91)	6.33 (5.10-8.22)	7.37 (5.70-9.90)	8.55 (6.30-11.9)	10.3 (7.24-14.8)	11.7 (7.95-17.0)
7-day	3.23 (2.81-3.76)	3.59 (3.11-4.19)	4.28 (3.70-5.01)	4.94 (4.24-5.82)	6.00 (5.03-7.55)	6.93 (5.62-8.86)	7.95 (6.20-10.5)	9.09 (6.75-12.5)	10.7 (7.63-15.3)	12.1 (8.29-17.4)
10-day	3.67 (3.20-4.23)	4.07 (3.56-4.71)	4.83 (4.20-5.60)	5.54 (4.79-6.47)	6.64 (5.59-8.26)	7.59 (6.19-9.60)	8.63 (6.76-11.3)	9.77 (7.29-13.3)	11.4 (8.14-16.1)	12.8 (8.78-18.2)
20-day	4.91 (4.35-5.58)	5.49 (4.86-6.25)	6.50 (5.73-7.43)	7.40 (6.48-8.52)	8.75 (7.42-10.6)	9.86 (8.12-12.2)	11.0 (8.73-14.2)	12.3 (9.27-16.5)	14.1 (10.1-19.6)	15.5 (10.8-22.0)
30-day	6.02 (5.37-6.78)	6.73 (6.01-7.59)	7.95 (7.07-9.00)	9.01 (7.95-10.3)	10.5 (8.97-12.6)	11.8 (9.75-14.4)	13.0 (10.4-16.6)	14.4 (10.9-19.0)	16.2 (11.8-22.4)	17.7 (12.4-24.9)
45-day	7.49 (6.75-8.36)	8.38 (7.54-9.36)	9.84 (8.82-11.0)	11.1 (9.84-12.5)	12.7 (10.9-15.1)	14.1 (11.7-17.0)	15.4 (12.3-19.3)	16.7 (12.7-21.9)	18.5 (13.5-25.3)	19.9 (14.0-27.8)
60-day	8.81 (7.99-9.77)	9.84 (8.90-10.9)	11.5 (10.3-12.8)	12.8 (11.5-14.4)	14.6 (12.5-17.0)	15.9 (13.3-19.0)	17.2 (13.8-21.4)	18.5 (14.1-24.0)	20.1 (14.7-27.2)	21.3 (15.1-29.7)

<sup>1</sup> Precipitation frequency (PF) estimates in this table are based on frequency analysis of partial duration series (PDS). Numbers in parenthesis are PF estimates at lower and upper bounds of the 90% confidence interval. The probability that precipitation frequency estimates (for a given duration and average recurrence interval) will be greater than the upper bound (or less than the lower bound) is 5%. Estimates at upper bounds are not checked against probable maximum precipitation (PMP) estimates and may be higher than currently valid PMP values. Please refer to NOAA Atlas 14 document for more information.

[Back to Top](#)

**PF graphical**




[Back to Top](#)

### Maps & aeriels

NOAA Atlas 14, Volume 8, Version 2

Created (GMT): Thu Aug 18 12:43:50 2016

#### Small scale terrain







Large scale terrain



Large scale map



Large scale aerial



[Back to Top](#)

---

[US Department of Commerce](#)  
[National Oceanic and Atmospheric Administration](#)  
[National Weather Service](#)  
[National Water Center](#)  
1325 East West Highway  
Silver Spring, MD 20910

Questions?: [HDSC.Questions@noaa.gov](mailto:HDSC.Questions@noaa.gov)

[Disclaimer](#)

**APPENDIX C**  
**HYDROLOGIC AND HYDRAULIC MODEL OUTPUT**

## Project Description

File Name ..... Karn BaseFLow Pond.SPF

## Project Options

Flow Units ..... CFS  
 Elevation Type ..... Elevation  
 Hydrology Method ..... SCS TR-55  
 Time of Concentration (TOC) Method ..... SCS TR-55  
 Link Routing Method ..... Hydrodynamic  
 Enable Overflow Ponding at Nodes ..... YES  
 Skip Steady State Analysis Time Periods ..... NO

## Analysis Options

Start Analysis On ..... Aug 04, 2016 00:00:00  
 End Analysis On ..... Aug 06, 2016 00:00:00  
 Start Reporting On ..... Aug 04, 2016 00:00:00  
 Antecedent Dry Days ..... 0 days  
 Runoff (Dry Weather) Time Step ..... 0 01:00:00 days hh:mm:ss  
 Runoff (Wet Weather) Time Step ..... 0 00:05:00 days hh:mm:ss  
 Reporting Time Step ..... 0 00:05:00 days hh:mm:ss  
 Routing Time Step ..... 10 seconds

## Number of Elements

	Qty
Rain Gages .....	1
Subbasins.....	1
Nodes.....	2
<i>Junctions</i> .....	0
<i>Outfalls</i> .....	1
<i>Flow Diversions</i> .....	0
<i>Inlets</i> .....	0
<i>Storage Nodes</i> .....	1
Links.....	1
<i>Channels</i> .....	0
<i>Pipes</i> .....	1
<i>Pumps</i> .....	0
<i>Orifices</i> .....	0
<i>Weirs</i> .....	0
<i>Outlets</i> .....	0
Pollutants .....	0
Land Uses .....	0

## Rainfall Details

SN	Rain Gage ID	Data Source	Data Source ID	Rainfall Type	Rain Units	State	County	Return Period (years)	Rainfall Depth (inches)	Rainfall Distribution
1	Rain Gage-01	Time Series	TS-100	Cumulative	inches	Michigan	None	100	5.99	SCS Type II 24-hr

## Subbasin Summary

SN	Subbasin ID	Area (ac)	Weighted Curve Number	Total Rainfall (in)	Total Runoff (in)	Total Runoff Volume (ac-in)	Peak Runoff (cfs)	Time of Concentration (days hh:mm:ss)
1	Sub-01	4.99	98.00	5.99	5.75	28.70	39.26	0 00:05:00

## Node Summary

SN ID	Element Type	Invert Elevation (ft)	Ground/Rim (Max) Elevation (ft)	Initial Water Elevation (ft)	Surcharge Elevation (ft)	Ponded Area (ft <sup>2</sup> )	Peak Inflow (cfs)	Max HGL Elevation Attained (ft)	Max Surcharge Depth Attained (ft)	Min Freeboard Attained (ft)	Time of Peak Flooding Occurrence (days hh:mm)	Total Flooded Volume (ac-in)	Total Time Flooded (min)
1	Out-01 Outfall	591.00					17.07	592.49					
2	Stor-01 Storage Node	591.00	598.00	591.00		0.00	59.16	593.97				0.00	0.00

## Link Summary

SN	Element ID	Element Type	From (Inlet) Node	To (Outlet) Node	Length (ft)	Inlet Invert Elevation (ft)	Outlet Invert Elevation (ft)	Average Slope (%)	Diameter or Height (ft)	Manning's Roughness	Peak Flow (cfs)	Design Flow Capacity (cfs)	Peak Flow/Design Flow Ratio	Peak Flow Velocity (ft/sec)	Peak Flow Depth (ft)	Peak Flow Depth/Total Depth Ratio	Total Time Reported (min)	Reported Condition
1	Link-01	Pipe	Stor-01	Out-01	60.00	591.60	591.00	1.0000	2.000	0.0160	17.07	18.38	0.93	5.87	1.74	0.87	0.00	Calculated

# Subbasin Hydrology

## Subbasin : Sub-01

### Input Data

Area (ac) ..... 4.99  
 Weighted Curve Number ..... 98.00  
 Rain Gage ID ..... Rain Gage-01

### Composite Curve Number

Soil/Surface Description	Area (acres)	Soil Group	Curve Number
-	4.99	-	98.00
Composite Area & Weighted CN	4.99		98.00

### Time of Concentration

TOC Method : SCS TR-55

Sheet Flow Equation :

$$T_c = (0.007 * ((n * L_f)^{0.8}) / ((P^{0.5}) * (S_f^{0.4})))$$

Where :

Tc = Time of Concentration (hr)  
 n = Manning's roughness  
 Lf = Flow Length (ft)  
 P = 2 yr, 24 hr Rainfall (inches)  
 Sf = Slope (ft/ft)

Shallow Concentrated Flow Equation :

V = 16.1345 \* (Sf<sup>0.5</sup>) (unpaved surface)  
 V = 20.3282 \* (Sf<sup>0.5</sup>) (paved surface)  
 V = 15.0 \* (Sf<sup>0.5</sup>) (grassed waterway surface)  
 V = 10.0 \* (Sf<sup>0.5</sup>) (nearly bare & untilled surface)  
 V = 9.0 \* (Sf<sup>0.5</sup>) (cultivated straight rows surface)  
 V = 7.0 \* (Sf<sup>0.5</sup>) (short grass pasture surface)  
 V = 5.0 \* (Sf<sup>0.5</sup>) (woodland surface)  
 V = 2.5 \* (Sf<sup>0.5</sup>) (forest w/heavy litter surface)  
 Tc = (Lf / V) / (3600 sec/hr)

Where:

Tc = Time of Concentration (hr)  
 Lf = Flow Length (ft)  
 V = Velocity (ft/sec)  
 Sf = Slope (ft/ft)

Channel Flow Equation :

$$V = (1.49 * (R^{2/3}) * (S_f^{0.5})) / n$$

R = Aq / Wp  
 Tc = (Lf / V) / (3600 sec/hr)

Where :

Tc = Time of Concentration (hr)  
 Lf = Flow Length (ft)  
 R = Hydraulic Radius (ft)  
 Aq = Flow Area (ft<sup>2</sup>)  
 Wp = Wetted Perimeter (ft)  
 V = Velocity (ft/sec)  
 Sf = Slope (ft/ft)  
 n = Manning's roughness

User-Defined TOC override (minutes): 5


### Subbasin Runoff Results

Total Rainfall (in) ..... 5.99  
 Total Runoff (in) ..... 5.75  
 Peak Runoff (cfs) ..... 39.26  
 Weighted Curve Number ..... 98.00  
 Time of Concentration (days hh:mm:ss) ..... 0 00:05:00




Subbasin : Sub-01

Rainfall Intensity Graph



Runoff Hydrograph



## Pipe Input

SN Element ID	Length (ft)	Inlet Invert Elevation (ft)	Inlet Invert Offset (ft)	Outlet Invert Elevation (ft)	Outlet Invert Offset (ft)	Total Drop (ft)	Average Pipe Slope (%)	Pipe Shape	Pipe Diameter or Height (ft)	Pipe Width (ft)	Manning's Roughness	Entrance Losses	Exit/Bend Losses	Additional Losses	Initial Flap Flow Gate (cfs)	No. of Barrels
1 Link-01	60.00	591.60	0.60	591.00	0.00	0.60	1.0000	CIRCULAR	2.000	2.000	0.0160	0.5000	1.0000	0.0000	0.00 No	1

## Pipe Results

SN Element ID	Peak Flow (cfs)	Time of Peak Flow Occurrence (days hh:mm)	Design Flow Capacity (cfs)	Peak Flow/Design Flow Ratio	Peak Flow Velocity (ft/sec)	Travel Time (min)	Peak Flow Depth (ft)	Peak Flow Depth/Total Depth Ratio	Total Time Surcharged (min)	Froude Number	Reported Condition
1 Link-01	17.07	0 13:00	18.38	0.93	5.87	0.17	1.74	0.87	0.00		Calculated

# Storage Nodes

## Storage Node : Stor-01

### Input Data


Invert Elevation (ft) ..... 591.00  
Max (Rim) Elevation (ft) ..... 598.00  
Max (Rim) Offset (ft) ..... 7.00  
Initial Water Elevation (ft) ..... 591.00  
Initial Water Depth (ft) ..... 0.00  
Ponded Area (ft<sup>2</sup>) ..... 0.00  
Evaporation Loss ..... 0.00

### Storage Area Volume Curves

Storage Curve : Storage-01

Stage	Storage Area	Storage Volume
(ft)	(ft <sup>2</sup> )	(ft <sup>3</sup> )
0	645.95	0.000
1	40027.96	20336.96
2	78931.05	79816.47
3	92303.24	165433.62
4	100810.40	261990.44
5	108844.27	366817.78
6	117750.88	480115.36
7	134728.97	606355.29

### Storage Area Volume Curves



— Storage Area    — Storage Volume

## Storage Node : Stor-01 (continued)

### Output Summary Results

Peak Inflow (cfs) .....	59.16
Peak Lateral Inflow (cfs) .....	59.16
Peak Outflow (cfs) .....	17.07
Peak Exfiltration Flow Rate (cfm) .....	0.00
Max HGL Elevation Attained (ft) .....	593.97
Max HGL Depth Attained (ft) .....	2.97
Average HGL Elevation Attained (ft) .....	592.99
Average HGL Depth Attained (ft) .....	1.99
Time of Max HGL Occurrence (days hh:mm) .....	0 12:59
Total Exfiltration Volume (1000-ft³) .....	0.000
Total Flooded Volume (ac-in) .....	0
Total Time Flooded (min) .....	0
Total Retention Time (sec) .....	0.00

Established in 1960, Golder Associates is a global, employee-owned organization that helps clients find sustainable solutions to the challenges of finite resources, energy and water supply and management, waste management, urbanization, and climate change. We provide a wide range of independent consulting, design, and construction services in our specialist areas of earth, environment, and energy. By building strong relationships and meeting the needs of clients, our people have created one of the most trusted professional services organizations in the world.

Africa	+ 27 11 254 4800
Asia	+ 852 2562 3658
Australasia	+ 61 3 8862 3500
Europe	+ 356 21 42 30 20
North America	+ 1 800 275 3281
South America	+ 56 2 2616 2000

[solutions@golder.com](mailto:solutions@golder.com)  
[www.golder.com](http://www.golder.com)

**Golder Associates Inc.**  
**15851 South U.S. 27, Suite 50**  
**Lansing, MI 48906 USA**  
**Tel: (517) 482-2262**  
**Fax: (517) 482-2460**



**Engineering Earth's Development, Preserving Earth's Integrity**

Golder, Golder Associates and the GA globe design are trademarks of Golder Associates Corporation